

NOV 13 1975

Milling *VSR*

Memo to File

Thru: D. L. Capton, Section Leader
Reactor Projects Section No. 2
Region I, Reactor Operations and Nuclear Support Branch

OYSTER CREEK DRILL

This will document receipt of a call from J. T. Carroll at 10:35 a.m.,
November 13, 1975.

Announced Reporting "Drill"

- (1) INCIDENT AT OYSTER CREEK
- (2) REACTOR SCRAM
- (3) ALL RODS VERIFIED IN
- (4) REACTOR LEVEL 0" AND INCREASING
- (5) CORE SPRAY INITIATION - C₂ S. VALVE OPEN
- (6) STACK RELEASE RATE 5×10^5 COUNTS PER-SECOND
- (7) ONE ISO-CONDENSER INITIATED ONE ISOLATED
- (8) 2 PERSONNEL UNACCOUNTED FOR ONE AT 75' ELEVATION AND ONE ON
95' ELEVATION
- (9) EMERGENCY OFFICER - COMMENCING SEARCH
- (10) NO PERSONNEL INJURY - REGION I QUESTION NO EXPOSURE TO PERSONNEL
OFFSITE

Projects provided verification of licensee call of JCP&L Duty Officer.

Edward G. Greenman

Edward G. Greenman
Reactor Inspector

cc: J. P. O'Reilly *m*
Senior Duty Officer
Emergency Planning Officer
Branch Chiefs
PAO

01724