


0-3126

Jersey Central Power & Light Company



MADISON AVENUE AT PUNCH BOWL ROAD • MORRISTOWN, N. J. 07960 • 201-539-6111

MEMBER OF THE
General  Public Utilities Corporation

September 26, 1975




Mr. Karl R. Goller, Assistant Director
for Operating Reactors
Division of Reactor Licensing
United States Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Mr. Goller:

Subject: Oyster Creek Nuclear Generating Station
Docket No. 50-219
Attachment to letter of September 19, 1975 --
Spent Fuel Pool Modification Plan

On September 19, 1975, we sent to you a letter presenting our design concept for the increase of the Oyster Creek Spent Fuel Pool Storage Capacity and soliciting your comments. The attachment to this September 19 letter was inadvertently not included with the letter. Attached is the letter and the attachment. Thank you for your cooperation in correcting this oversight.

Very truly yours,


Ivan R. Finfrock, Jr.
Vice President

cs

Attachment

81748

1003

V-321

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SEP 25 1975

Docket No. 50-219

Jersey Central Power & Light Company
ATTN: Mr. I. R. Finfrock, Jr.
Vice President - Generation
Madison Avenue at Punch Bowl Road
Morristown, New Jersey 07960


Gentlemen:

By letter dated September 10, 1975, you informed us of an unusual event regarding the Oyster Creek Nuclear Generation Station reactor building to torus vacuum breaker valves V-26-16 and V-26-18 which were found not wired to close on a high drywell pressure signal, contrary to the design criteria stated in the Facility Description and Safety Analysis Report. Your letter stated that the following corrective actions will be accomplished to correct this deficiency:

- (1) Initiate design changes to accomplish closure of V-26-16 and V-26-18 on high drywell pressure.
- (2) Provide interim administrative controls to assure closure of V-26-16 and V-26-18 when required.

To enable us to complete our evaluation of this unusual event, we request that you provide us with the date that the plant modifications will be completed and the details of the interim administrative controls that have been instituted. We request that you provide this additional information by October 21, 1975.

Sincerely,



George Lear, Chief
Operating Reactors Branch #3
Division of Reactor Licensing

cc: See next page

~~8345424287~~ (270)

B1 749

SEP 25 1975

cc:

G. F. Trowbridge, Esquire
Shaw, Pittmar, Potts, Trowbridge & Madden
Barr Building
910 17th Street, N. W.
Washington, D. C. 20006

Jersey Central Power & Light Company
ATTN: Mr. Thomas M. Crimmins, Jr.
Safety and Licensing Manager
GPU Service Corporation
260 Cherry Hill Road
Parsippany, New Jersey 07054

Anthony Z. Roisman, Esquire
Berlin, Roisman & Kessler
1712 N Street, N. W.
Washington, D. C. 20036

Paul Rosenberg, Esquire
Daniel Rappoport, Esquire
2323 S. Broad Street
Trenton, New Jersey 08610

Honorable Joseph W. Ferraro, Jr.
Deputy Attorney General
State of New Jersey
101 Commerce Street - Room 208
Newark, New Jersey 07102

Burtis W. Horner, Esquire
Stryker, Tams and Dill
55 Madison Avenue
Morristown, New Jersey 07960

George F. Kugler, Jr.
Attorney General
State of New Jersey
State House Annex
Trenton, New Jersey 08625

Ocean County Library
15 Hooper Avenue
Toms River, New Jersey 08753