

Yellow

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

34 OCT 31 A 8:42

W. L. STEWART
VICE PRESIDENT
NUCLEAR OPERATIONS

October 25, 1984

Mr. James P. O'Reilly
Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
Suite 2900
101 Marietta St., N.W.
Atlanta, Georgia 30323

Serial No. 184A
NO/JHL:acm
Docket No. 50-339
License No. NPF-7

Dear Mr. O'Reilly:

VIRGINIA ELECTRIC AND POWER COMPANY
NORTH ANNA POWER STATION UNIT NO. 2
SUPPLEMENTAL RESPONSE TO I.E. BULLETIN NO. 84-02

In our response to I.E. Bulletin No. 84-02, dated July 31, 1984, Serial No. 184, Veeco committed to replace the North Anna Unit No. 2 normally de-energized relays during the August, 1984 refueling outage if replacement parts were available.

The replacement HFA relays arrived on-site on October 23, 1984. The relays were receipt inspected by the Quality Control Department and placed on hold due to improper certification documents. This certification must be complete to ensure that only qualified replacement parts are purchased for use in safety related systems. With the Unit 2 outage nearing completion (expected startup date is October 28, 1984), it is not feasible to install the replacement parts and properly test them without having a substantial impact on the scheduled startup date. We propose to install the replacement relays during the next outage of sufficient duration on North Anna Unit No. 2. Until these relays are replaced, we will continue to visually inspect the presently installed relays on a monthly basis as indicated in our July 31, 1984 letter.

Very truly yours,

R. J. Hardwick
for W. L. Stewart

cc: U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Mr. M. W. Branch
NRC Resident Inspector
North Anna Power Station

8411080258 841025
PDR ADDCK 05000339
G PDR

Mr. James R. Miller, Chief
Operating Reactors Branch No. 3
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

IEH 1/0