

FEB 19 1985

Docket Nos.: 50-440
and 50-441

Mr. Murray R. Edelman
Vice President - Nuclear Group
The Cleveland Electric Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

Dear Mr. Edelman:

Subject: Request for Additional Information Re Use of Staff Pipe Clamps
in the Perry Nuclear Power Plant (Units 1 and 2)

The NRC staff has reviewed your response to a question related to the use of stiff pipe clamps in the Perry piping system (Q210.15), submitted by your letter dated October 1, 1984, and finds your response to be incomplete.

Item 4 of your response to Q210.15 states that discussions with E-Systems, Inc. determined that, since many of the specified torque values can be significantly reduced without compromising the load rating, it was not considered necessary to implement special requirements for post-installation/operational verification of those clamps. If the torque values, whether high or low, are required for the functional adequacy of the applicable support, it is requested that your staff provide a further technical justification for not performing post-installation/operational verifications. Specifically, it is requested that the impact of lower pre-load torque values on the required stiffness of the support (as assumed in the piping stress analysis) be addressed in detail. Your response should be provided as an amendment to Q210.15 for eventual documentation in the FSAR.

Please advise the Perry Project Manager when we may expect to receive your response within 5 days after receipt of this letter.

Sincerely,

B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing

cc: See next page

DL:LB#1
JStefano:es
2/15/85

DL:LB#1
BJYoungblood
2/15/85

DIST:

Docket File OELD, Attorney
NRC PDR ACRS (16)
PRC System EJordan
NSIC RHeischman
Local PDR J. P. Knight
LB#1 Rdg R. J. Bosnak
MRushbrook F. C. Cherny
JStefano H. Brammer
D. Terao R. Li

8502260573 850219
PDR ADOCK 05000440
A PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

FEB 19 1985

Docket Nos.: 50-440
and 50-441

Mr. Murray R. Edelman
Vice President - Nuclear Group
The Cleveland Electric Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

Dear Mr. Edelman:


Subject: Request for Additional Information Re Use of Staff Pipe Clamps
in the Perry Nuclear Power Plant (Units 1 and 2)

The NRC staff has reviewed your response to a question related to the use of stiff pipe clamps in the Perry piping system (Q210.15), submitted by your letter dated October 1, 1984, and finds your response to be incomplete.

Item 4 of your response to Q210.15 states that discussions with E-Systems, Inc. determined that, since many of the specified torque values can be significantly reduced without compromising the load rating, it was not considered necessary to implement special requirements for post-installation/operational verification of those clamps. If the torque values, whether high or low, are required for the functional adequacy of the applicable support, it is requested that your staff provide a further technical justification for not performing post-installation/operational verifications. Specifically, it is requested that the impact of lower pre-load torque values on the required stiffness of the support (as assumed in the piping stress analysis) be addressed in detail. Your response should be provided as an amendment to Q210.15 for eventual documentation in the FSAR.

Please advise the Perry Project Manager when we may expect to receive your response within 5 days after receipt of this letter.

Sincerely,


B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing

cc: See next page

PERRY

Mr. Murray R. Edelman, Vice President
Nuclear Operations Group
The Cleveland Electric
Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

cc: Jay Silberg, Esq.
Shaw, Pittman, & Trowbridge
1800 M Street, N. W.
Washington, D. C. 20006

Mr. Larry O. Beck
The Cleveland Electric
Illuminating Company
P. O. Box 97 E-210
Perry, Ohio 44081

Donald H. Hauser, Esq.
The Cleveland Electric
Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

Resident Inspector's Office
U. S. Nuclear Regulatory Commission
Partly at Center Road
Perry, Ohio 44081

Regional Administrator
U. S. NRC, Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Donald T. Ezzone, Esq.
Assistant Prosecuting Attorney
105 Main Street
Lake County Administration Center
Painesville, Ohio 44077

Ms. Sue Hiatt
OCRE Interim Representative
8275 Munson
Mentor, Ohio 44060

Terry J. Lodge, Esq.
618 N. Michigan Street
Suite 105
Toledo, Ohio 43624

John G. Cardinal, Esq.
Prosecuting Attorney
Ashtabula County Courthouse
Jefferson, Ohio 44047