

V-2 P 1

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SEP 5 1975

Gary Snyder, Enforcement Coordinator, IE:I

JERSEY CENTRAL POWER AND LIGHT COMPANY - PROPOSED CIVIL PENALTY

In accordance with our telephone discussion on September 2, 1975, the amounts of the monetary penalty for each item of noncompliance in the Notice of Violation will be reduced to the extent that all items related to any one Criterion will be equal to the amount set out in the Chapter 0800 guidance for an item of noncompliance in that category.

The items of noncompliance have been reviewed in your office and the Region feels that they are properly categorized.

Although there are items of noncompliance with several of the Criteria in Appendix B of Part 50, it appears that many of the items are procedural in nature and have minimal safety significance. While it is true that a breakdown in Quality Assurance can be demonstrated by establishing items of noncompliance with the requirements of several Criterion in Appendix B, such matters of noncompliance must involve matters of real safety significance. The significance of the items of noncompliance should be commensurate with and justify the conclusion that there is a breakdown in Quality Assurance. It is also noted that the total action points of 86 for this case is somewhat less than the 100 action points normally used as guidance for the civil penalty sanction.

In view of the matters discussed above, please submit to Headquarters a justification for the conclusion that the items of noncompliance demonstrate a breakdown in Quality Assurance. If there is a breakdown in QA, please indicate the justification for not suspending the license in the interest of the public health and safety. Also indicate the justification for the civil penalty sanction based on the 86 action points tabulated for this case.

W. P. Ellis

W. P. Ellis, Enforcement Specialist
Field Coordination and Enforcement Br.
Office of Inspection and Enforcement




8/26/75

Jersey Central Power & Light Company



MADISON AVENUE AT PUNCH BOWL ROAD • MORRISTOWN, N. J. 07960 • 201-539-6111

MEMBER OF THE
General  Public Utilities Corporation
SYSTEM

September 3, 1975

Mr. R. Haynes
Office of Inspection and Enforcement, Region 1
United States Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Mr. Haynes:

In accordance with our telephone conversation of this date, I am enclosing a xerox copy of our response to IE Bulletin No. 75-06 for the Oyster Creek docket.

I am also enclosing a xerox copy of the response to IE Bulletin No. 75-06 for the Forked River docket.

Very truly yours,

Donald A. Ross, Manager
Generating Stations-Nuclear

CS

Enclosures


B/763

96 04170335 1P

Jersey Central Power & Light Company



MADISON AVENUE AT HUNCH BOWL ROAD • MORRISTOWN, N. J. 07950 • 201-539-6111

General  Public Utilities Corporation

July 3, 1975

Mr. James P. O'Reilly, Director
Office of Inspection and Enforcement, Region 1
United States Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Mr. O'Reilly:

Subject: Oyster Creek Nuclear Generating Station
Pocket No. 50-219
IE Bulletin No. 75-06

In reference to IE Bulletin No. 75-06 dated May 30, 1975, it has been ascertained that Westinghouse Type OF-2 switches are not utilized in safety systems at the Oyster Creek Nuclear Generating Station; therefore, no further action is planned.

Very truly yours,

Donald A. Ross, Manager
Generating Stations-Nuclear

cs


blee:	E. M. Ambler	H. K. Mayer
	R. C. Arnold	T. J. McCluskey
	S. Bartnoff	C. R. Montgomery
	J. T. Carroll	E. F. O'Connor
	W. M. Creitz	W. T. Osborne
	J. C. DeVine	M. B. Peters
	H. M. Dieckamp	J. K. Pickard
	I. R. Einfrock, Jr.	D. A. Ross
	D. P. Gaines	E. J. Sherratt
	K. A. Greene	J. R. Thorpe (2)
	S. W. Laird	G. F. Trowbridge
	J. R. Liberman	W. A. Verrochi
	T. J. Madden	R. L. Williams

9604230159 IP

Jersey Central Power & Light Company



MADISON AVENUE AT PUNCH BOWL ROAD • MORRISTOWN, N. J. 07960 • 201-539-6111

MEMBER OF THE
General  Public Utilities Corporation

September 3, 1975

Mr. R. Haynes
Office of Inspection and Enforcement, Region 1
United States Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Mr. Haynes:

In accordance with our telephone conversation of this date, I am enclosing a xerox copy of our response to IE Bulletin No. 75-06 for the Oyster Creek docket.

I am also enclosing a xerox copy of the response to IE Bulletin No. 75-06 for the Forked River docket.

Very truly yours,

Donald A. Ross, Manager
Generating Stations-Nuclear

cs

Enclosures

B/763


9604170335 HP

Jersey Central Power & Light Company



MADISON AVENUE AT LUNCH BOWL ROAD • MORRISTOWN, N. J. 07960 • 201-539-6111

General Public Utilities Corporation



July 3, 1975

Mr. James P. O'Reilly, Director
Office of Inspection and Enforcement, Region 1
United States Nuclear Regulatory Commission
651 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Mr. O'Reilly:

Subject: Oyster Creek Nuclear Generating Station
Docket No. 50-219
IE Bulletin No. 75-06

In reference to IE Bulletin No. 75-06 dated May 30, 1975, it has been ascertained that Westinghouse Type GT-2 switches are not utilized in safety systems at the Oyster Creek Nuclear Generating Station; therefore, no further action is planned.

Very truly yours,

Donald A. Ross, Manager
Generating Stations-Nuclear

cs

blec: E. M. Ambler
R. C. Arnold
S. Bartnoff
J. T. Carroll
W. M. Creitz
J. C. DeVine
H. M. Dieckamp
I. R. Finfrock, Jr.
D. P. Gaines
K. A. Greene
S. W. Laird
J. B. Liberman
T. J. Madden
H. K. Mayer
T. J. McCluskey
C. R. Montgomery
E. F. O'Connor
W. T. Osborne
M. B. Peters
J. K. Pickard
D. A. Ross
E. J. Sherratt
J. R. Thorpe (2)
G. F. Trowbridge
W. A. Verrochi
R. L. Williams

9604230159 IP