

**GPU Nuclear Corporation**  
Post Office Box 388  
Route 9 South  
Forked River, New Jersey 08731-0388  
609 971-4000  
Writer's Direct Dial Number:

April 18, 1996  
6730-96-2112

U. S. Nuclear Regulatory Commission  
Att: Document Control Desk  
Washington, DC 20555

Gentlemen:

Subject: Oyster Creek Nuclear Generating Station (OCNGS)  
Docket No. 50-219  
Facility Operating License No. DPR-16  
Response to Generic Letter 96-01: Testing of  
Safety-Related Logic Circuits

In accordance with the initial response requirements of NRC Generic Letter (GL) 96-01, "Testing of Safety-Related Logic Circuits", dated January 10, 1996, the following information is provided:

GPU Nuclear will review and compare OCNGS electrical schematic drawings and logic diagrams for those portions of the reactor protection system, emergency diesel generator load shedding and sequencing, and actuation logic for engineered safety features systems required for design basis accident mitigation against the OCNGS Technical Specification surveillance procedures. The purpose of this review is to ensure that all applicable portions of the logic circuitry are adequately covered in the surveillance procedures to fulfill Technical Specification requirements. Surveillance procedure inadequacies identified as part of this review, if any, will be addressed as necessary by surveillance procedure revision or request for technical specification amendment where justified.


240022

9604240147 960418  
PDR ADOCK 05000219  
P PDR

A067  
/10

The above actions will be completed prior to startup from the 17R outage which is the first refueling outage commencing one year after the issuance of GL 96-01. GPU Nuclear will confirm completion of these actions at that time. This schedule is consistent with the Generic Letter 96-01 request. If any additional information is needed, please contact Mr. David J. Distel, Senior Regulatory Affairs Engineer at (201) 316-7955.

Sincerely,



for M. B. Roche  
Vice President and Director,  
Oyster Creek

MBR\DJD\plp

c: Administrator, Region I  
Oyster Creek NRC Resident Inspector  
Oyster Creek NRC Senior Project Manager