



February 21, 1985

Public Service of New Hampshire

SBN- 767
T.F. Q2.2.2

New Hampshire Yankee Division

United States Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, PA 19406

Attention: Mr. Richard W. Starostecki, Director
Division of Project and Resident Programs

References: (a) Construction Permits CPPR-135 and CPPR-136, Docket
Nos. 50-443 and 50-444
(b) Telecon of January 18, 1985, A. L. Legendre, Jr. (YAEC) to
Jim Beall (NRC Region I)
(c) PSNH Letter SBN-723, dated October 26, 1984, "Final
10CFR50.55(e) Report: Gould Molded Case Circuit Breakers -
Non-Reportability Determination", J. DeVincentis to
R. W. Starostecki

Subject: Interim 10CFR50.55(e) Report: Gould Molded Case Circuit
Breakers

Dear Sir:

On January 18, 1985, we reported a potential 10CFR50.55(e) deficiency
[Reference (b)] regarding Gould molded case circuit breakers. This deficiency
has been evaluated and we have determined that it is reportable under the
provisions of 10CFR50.55(e).

Description of Deficiency

The deficiency involves the failure of ten Gould molded case circuit
breakers (40-amp trip, Model HE3M040) to pass the instantaneous overcurrent
trip test performed at Seabrook Station by the Start-Up and Test Department.

A similar failure was reported to Region I on May 16, 1984, at which time
the breakers were returned to the factory for evaluation. The manufacturer
reported that the problem was a result of incorrect calibration. The
incorrect calibration represented an isolated breakdown in the quality control
procedures of Gould's sub-supplier. Based on this, we considered the item as
nonreportable and we informed Region I accordingly [Reference (c)].

Since then, the ten breakers were returned from the factory to
Seabrook Station, and during acceptance testing, six of the ten breakers
failed again to pass the instantaneous overcurrent trip test. The acceptance
criteria of this test are based on the manufacturer's time-current curve
presently on hand.

8502270315 850221
PDR ADDCK 05000443
S PDR

1/0
IE 27

Further investigation on this anomaly has revealed the following: ITE Electrical Products (Division of Siemens Allis), which is Gould's sub-supplier for the subject breakers, has indicated that there is a discrepancy in the magnetic trip range between the published engineering data (time-current curves) and manufacturing data. Manufacturing data indicates that the trip range for this type breaker is 600 to 1,000 amperes; whereas, the published time-current curve indicates 400 to 700 amperes.

The subject breakers were tested successfully, based on the manufacturing data, before they left ITE's factory, but failed when they were tested at Seabrook Site, based on the published time-current curve. Obviously, the discrepancy in tripping ranges accounts for the failure of the subject breakers to pass the test.

Safety Implications


In this specific case, the breakers will perform their intended function as designed, and therefore, there is no safety implication associated with the subject deficiency, due to the small difference in the instantaneous tripping range between the published range (400 to 700 amperes), and the actual as-constructed range (600 to 1000 amperes). We do, however, view the failure of Gould's sub-supplier to provide the proper information on tripping ranges, and the failure of Gould to identify the subject deficiency before returning the circuit breakers to Seabrook Station as significant breakdowns in the Quality Control procedures of both Gould and Gould's sub-supplier for the breakers.

Corrective Action

To prevent the recurrence of the subject deficiency, Gould will review purchase orders to assure that Class 1E requirements are clearly specified. Gould will also test all 1E circuit breakers, prior to shipment, to the requirements of NEMA AB-2, and issue objective evidence for each tested circuit breaker. Gould's sub-supplier for the circuit breakers will issue corrected time-current curves specifying the proper magnetic tripping range.

We will inform Region I when the corrective action has been completed. This letter is being filed pursuant to the interim reporting provisions of 10CFR50.55(e)(3).

Very truly yours,



John DeVincentis, Director
Engineering and Licensing

cc: Atomic Safety and Licensing Board Service List

Director, Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

William S. Jordan, III
Diane Curran
Harmon, Weiss & Jordan
20001 S Street N.W.
Suite 430
Washington, D.C. 20009

Robert G. Perlis
Office of the Executive Legal Director
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Robert A. Backus, Esquire
116 Lowell Street
P.O. Box 516
Manchester, NH 03105

Philip Ahrens, Esquire
Assistant Attorney General
Department of the Attorney General
Augusta, ME 04333

Mr. John B. Tanzer
Designated Representative of
the Town of Hampton
5 Morningside Drive
Hampton, NH 03842

Roberta C. Pevear
Designated Representative of
the Town of Hampton Falls
Drinkwater Road
Hampton Falls, NH 03844

Mrs. Sandra Gavutis
Designated Representative of
the Town of Kensington
RFD 1
East Kingston, NH 03827

Jo Ann Shotwell, Esquire
Assistant Attorney General
Environmental Protection Bureau
Department of the Attorney General
One Ashburton Place, 19th Floor
Boston, MA 02108

Senator Gordon J. Humphrey
U.S. Senate
Washington, DC 20510
(Attn: Tom Burack)

Diana P. Randall
70 Collins Street
SEabrook, NH 03874

Donald E. Chick
Town Manager
Town of Exeter
10 Front Street
Exeter, NH 03833

Brentwood Board of Selectmen
RED Dalton Road
Brentwood, New Hampshire 03833

Edward F. Meany
Designated Representative of
the Town of Rye
155 Washington Road
Rye, NH 03870

Calvin A. Canney
City Manager
City Hall
126 Daniel Street
Portsmouth, NH 03801

Dana Bisbee, Esquire
Assistant Attorney General
Office of the Attorney General
208 State House Annex
Concord, NH 03301

Anne Verge, Chairperson
Board of Selectmen
Town Hall
South Hampton, NH 03842

Patrick J. McKeon
Selectmen's Office
10 Central Road
Rye, NH 03870

Carole F. Kagan, Esq.
Atomic Safety and Licensing Board Panel
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. Angie Machiros
Chairman of the Board of Selectmen
Town of Newbury
Newbury, MA 01950

Town Manager's Office
Town Hall - Friend Street
Amesbury, Ma. 01913

Senator Gordon J. Humphrey
1 Pillsbury Street
Concord, NH 03301
(Attn: Herb Boynton)

Richard E. Sullivan, Mayor
City Hall
Newburyport, MA 01950