



UNITED STATES
 ATOMIC ENERGY COMMISSION
 DIRECTORATE OF REGULATORY OPERATIONS
 REGION 1
 631 PARK AVENUE
 KING OF PRUSSIA, PENNSYLVANIA 19406

APR 19 1974

Jersey Central Power and Light
 Company
 Attention: Mr. Ivan R. Finfrock
 Vice President
 Generation

License No. DPR-16
 Inspection No. 50-219/74-05

Madison Avenue at Punch Bowl Road
 Morristown, New Jersey 07960

Gentlemen:

This refers to the inspection conducted by Mr. Rebelowski of this office on March 27-28, 1974 at Oyster Creek, Forked River, New Jersey of activities authorized by AEC License No. DPR-16 and to the discussions of our findings held by Mr. Rebelowski with Mr. Carroll and members of your staff at the conclusion of the inspection.

Areas examined during this inspection are described in the Regulatory Operations Inspection Report which is enclosed with this letter. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspector.

Our inspector verified the steps you had taken to correct the items reported in Abnormal Occurrences 74-11, 74-13, 74-14, 74-15, 74-16, 74-17, 74-18, 74-19, 74-20, 74-21. Continuing corrective action related to these items will be subsequently reviewed.

Abnormal Occurrences 74-10, 74-12, 74-22, and 74-23 involving set points drifting out of Technical Specification requirements were also inspected. These items will be reviewed again upon completion of corrective action.

The inspected items which were found to be apparent violations of AEC requirements are listed in the enclosure to this letter. This letter constitutes a notice sent to you pursuant to the provisions of Section 2.201 of the AEC's "Rules of Practice", Part 2, Title 10, Code of Federal Regulations. We have verified that corrective action is being taken in a timely fashion and, therefore, no response with respect to these apparent violations is required.

B/570

OFFICE	CPSS		<i>acting</i>		
SURNAME	REBELOWSKI/JAS	GREENMAN	BRUNNER	O'REILLY	<i>M McCabe</i>
DATE	<i>4/17/74</i>	<i>4/18/74</i>	<i>4/18/74</i>		<i>4/17</i>

In accordance with Section 2.790 of the AEC's "Rules of Practice", Part 2, Title 10, Code of Federal Regulations, a copy of this letter and the enclosed inspection report will be placed in the AEC's Public Document Room. If this report contains any information that you (or your contractor) believe to be proprietary, it is necessary that you make a written application within 20 days to this office to withhold such information from public disclosure. Any such application must include a full statement of the reasons on the basis of which it is claimed that the information is proprietary, and should be prepared so that proprietary information identified in the application is contained in a separate part of the document. If we do not hear from you in this regard within the specified period, the report will be placed in the Public Document Room.

No reply to this letter is required; however, should you have any questions concerning this inspection, we will be pleased to discuss them with you.

Sincerely,

James P. O'Reilly
Director

Enclosures:
Description of Violations
RO Inspection Report No. 50-219/74-05

cc: Mr. J. T. Carroll
Station Superintendent

bcc: RO Chief, FS&EB
RO:HQ (4)
DL (4)
RO Files
DR Central Files
RS
PDR
Local PDR
NSIC
DTIE
State of New Jersey
Reg Reg Reading Room
OGC

OFFICE▶						
SURNAME▶						
DATE▶						