

7590-01

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NO. 50-445

TEXAS UTILITIES ELECTRIC COMPANY

TEXAS MUNICIPAL POWER AGENCY

RAZOS ELECTRIC POWER COOPERATIVE-

TEX-LA ELECTRIC COOPERATIVE OF TEXAS, INC.

COMANCHE PEAK STEAM ELECTRIC STATION, UNIT NO. 1

NOTICE OF ISSUANCE OF AMENDMENT TO CONSTRUCTION PERMIT

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 8 to Construction Permit No. CPPR-126. The amendment reflects changes to two conditions contained in the Construction Permit CPPR-126 to incorporate modifications authorized by an exemption to the General Design Criterion 4 of 10 CFR 50, Appendix A issued on August 28, 1984. The Amendment makes effective the partial exemption granted by the Commission, exempting the licensee from the requirement to install jet impingement shields in eight locations per loop in the Comanche Peak, Unit 1 primary coolant piping system.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the amendment. Prior public notice of the amendment was not required since the amendment does not involve a significant hazards consideration.

8411090428 841026  
PDR ADDCK 05000445  
A PDR

For further details with respect to this action, see (1) the application for amendment, dated August 20, 1984; (2) Amendment No. 8 to Construction Permit CPPR-126, (3) the Commission's related Safety Evaluation, and (4) Letter to M. D. Spence, Texas Utilities Generating Company from B. J. Youngblood, dated August 28, 1984, Subject: Request for Exemption from a Portion of General Design Criterion 4 of Appendix A to 10 CFR Part 50 regarding the need to Analyze Large Primary Loop Pipe Ruptures as the Structure Design Basis for Comanche Peak Steam Electric Station (Units 1 and 2). All of these items are available for public inspection in the Commission's Public Document Room in 1717 H Street, N. W., Washington, D. C. 20555 and in the Somervell County Public Library, On the Square, P. O. Box 417, Glen Rose, Texas 75403. Items 2, 3 and 4 may be requested in writing to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this 26<sup>th</sup> day of October, 1984.

FOR THE NUCLEAR REGULATORY COMMISSION

*151*  
B. J. Youngblood, Chief  
Licensing Branch No. 1  
Division of Licensing

CONCURRENCES: \*See previous concurrences

DL:LB#1  
MRushbrook:es  
/ /84

DL:LB#1  
JStefano  
/ /84

\*DL:LB#1  
SBurwell  
9/11/84

\*OELD  
JScinto  
9/12/84

\*DL:LB#1  
BJYoungblood  
9/12/84

SUBJECT: AMENDMENT NO. 8 TO CONSTRUCTION PERMIT CPPR-126 - COMANCHE PEAK STEAM  
ELECTRIC STATION, UNIT NO. 1

OCT 26 1984

DISTRIBUTION:

DOCKET FILE 50-445

NRC PDR

Local PDR

PRC System

NSIC

LB#1 Reading

M. Rushbrook

S. Burwell

J. Stefano

J. Saltzman, SAB

G. Mazure

S. Treby

J. Scinto

CMiles

HDenton

WMiller, LFMB

NGrace

EJordan

LHarmon

TBarnhart (4)

Inez Bailey