

# PACIFIC GAS AND ELECTRIC COMPANY

PG&E

77 BEALE STREET • SAN FRANCISCO, CALIFORNIA 94106 • (415) 781-4211 • TWX 910-372-6587

JAMES D. SHIFFER  
VICE PRESIDENT  
NUCLEAR POWER GENERATION

February 4, 1985

PGandE Letter No.: DCL-85-050

Mr. John B. Martin, Regional Administrator  
U. S. Nuclear Regulatory Commission, Region V  
1450 Maria Lane, Suite 210  
Walnut Creek, CA 94596-5368

Re: Docket No. 50-323  
Diablo Canyon Unit 2  
IE Bulletins 79-02 and 79-14

Dear Mr. Martin:

This letter provides PGandE's final responses to IE Bulletins (IEB) 79-02 and 79-14 for Diablo Canyon Unit 2.

IEB 79-02 summarized NRC requirements for pipe support base plate designs using concrete anchors. PGandE's final report for Unit 2 was transmitted to the NRC on February 18, 1983. All information in that letter remains valid except for the completion date of the analysis work which is now scheduled for February 28, 1985.

IEB 79-14, including supplements, summarized NRC requirements for the seismic analysis of as-built safety-related piping systems. PGandE letter to the NRC dated October 17, 1979, responded to Item 1 of the Bulletin for Diablo Canyon Units 1 and 2. PGandE provided a final report for Unit 1 on April 17, 1980 which indicated that a final report for Unit 2 would be provided at a later date. PGandE's final response, which describes the Unit 2 piping review program, is enclosed.


During the weeks of October 22 and November 26, 1984 and January 14, 1985, the NRC Staff conducted audits of Diablo Canyon Unit 2 piping design and analysis work. These audits verified compliance with the concerns and requirements of IEB 79-02 and 79-14.

This letter completes all necessary action on these Bulletins.

Kindly acknowledge receipt of this material on the enclosed copy of this letter and return it in the enclosed addressed envelope.

Sincerely,

8502270448 850204  
PDR ADOCK 05000323  
G PDR



Enclosure

cc: R. T. Dodds  
G. W. Knighton  
H. E. Schierling  
Service List

RECEIVED

IE28

ENCLOSURE

DIABLO CANYON UNIT 2  
FINAL RESPONSE TO IE BULLETIN 79-14

The Internal Review Program (IRP) for Diablo Canyon Unit 2, as described in PGandE letters dated October 5, October 19, and November 2, 1984, was initiated by PGandE in mid-1982. The program included: (1) a walkdown of all seismic Category 1 piping systems which ensured that as-built drawings reflect plant conditions, and (2) seismic reanalyses which used the verified piping geometry and support configurations. The final phase of the reanalysis includes an as-built reconciliation scheduled for completion by February 28, 1985.

PGandE's letter dated October 17, 1979, included Attachments A-E which provided the response to Item 1 of the Bulletin for Units 1 and 2. The walkdowns and seismic reanalyses satisfy the requirements of Items 2 and 3. Item 4 of the Bulletin is not applicable to Unit 2 because reanalyses of all seismic Category 1 piping systems were based on as-built piping and supports.