



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

GEORGIA POWER COMPANY
OGLETHORPE POWER CORPORATION
MUNICIPAL ELECTRIC AUTHORITY OF GEORGIA
CITY OF DALTON, GEORGIA
DOCKET NO. 50-366
EDWIN I. HATCH NUCLEAR PLANT, UNIT NO. 2
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 42
License No. NPF-5

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Georgia Power Company, et al., (the licensee) dated July 12, 1984, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-5 is hereby amended to read as follows:


8502270473 850124
PDR ADOCK 05000366
P PDR

Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 42, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: January 24, 1985

ATTACHMENT TO LICENSE AMENDMENT NO. 42

FACILITY OPERATING LICENSE NO. NPF-5

DOCKET NO. 50-366

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain a vertical line indicating the area of change. The corresponding overleaf page is also provided to maintain document completeness.

Remove

3/4 4-1

--

Insert

3/4 4-1

3/4 4-1a

3/4.4 REACTOR COOLANT SYSTEM

3/4.4.1 RECIRCULATION SYSTEM

RECIRCULATION LOOPS

LIMITING CONDITION FOR OPERATION

3.4.1.1 Two reactor coolant recirculation loops shall be in operation with each recirculation pump operating and the pump discharge valves OPERABLE.

APPLICABILITY: CONDITIONS 1* and 2*.

ACTION:

- a. With one recirculation loop not in operation, initiate action within 15 minutes and continue action to reduce reactor power to or below the limit specified in Figure 3.4.1.1-1 within 2 hours and restore both loops to operation within 12 hours or be in at least HOT SHUTDOWN within the next 12 hours.
- b. With no recirculation loops in operation, place the reactor mode switch in the Shutdown position.

SURVEILLANCE REQUIREMENTS

4.4.1.1 Each pump discharge valve shall be demonstrated OPERABLE by cycling each valve through at least one complete cycle of full travel:


- a. Each startup** prior to THERMAL POWER exceeding 25% of RATED THERMAL POWER, and
- b. During each COLD SHUTDOWN which exceeds 48 hours,**

* See Special Test Exception 3.10.4.

**If not performed within the previous 31 days.

FIGURE 3.4.1.1-1

THERMAL POWER LIMITATIONS DURING OPERATION WITH LESS THAN TWO REACTOR COOLANT SYSTEM RECIRCULATION LOOPS IN OPERATION



REACTOR COOLANT SYSTEM

JET PUMPS

LIMITING CONDITION FOR OPERATION

3.4.1.2 All jet pumps shall be OPERABLE.

APPLICABILITY: CONDITIONS 1 and 2.

ACTION:

With less than 20 jet pumps OPERABLE, be in at least HOT SHUTDOWN within 12 hours.

SURVEILLANCE REQUIREMENTS

4.4.1.2 Each of the above required jet pumps shall be demonstrated OPERABLE prior to THERMAL POWER exceeding 25% of RATED THERMAL POWER and at least once per 24 hours by verifying that all of the following conditions do not occur simultaneously.

- a. The recirculation pump flow differs by more than 15% from the established speed-flow characteristics,
- b. The indicated total core flow differs by more than 10% from the core flow value derived from recirculating loop flow measurements, and
- c. The diffuser-to-lower plenum differential pressure reading on any individual jet pump varies from the mean of all jet pump differential pressures, in that loop, by more than 10%.