CEP 2 6 1984

Docket Nos. 50-266 and 50-301

Mr. C. W. Fay, Vice President
Nuclear Power Department
Wisconsin Electric Power Company
231 West Michigan Street
Milwaukee, Wisconsin 53201

Dear Mr. Fay:

DISTRIBUTION:
Docket File ACRS (10)
NRC PDR
Local PDR
ORB#3 Rdg
DEisenhut
OELD
EJordan
JNGrace
TColburn

PMKreutzer

We have completed our review of your June 1, 1984 response to Generic Letter 83-28 with regard to Item 4.3, the design of automatic shunt trip for reactor scram breakers at Point Beach Nuclear Plant Units 1 and 2. The details of our review are contained in the enclosed Safety Evaluation.

We find that the design modifications are acceptable with the following exceptions: 1) Breaker position indication for the bypass breakers should be provided on the main control board and in a manner that will provide unambiguous indication of the bypass condition of the reactor trip breakers (for example, utilizing a breaker cell switch interlock). 2) Also, we request that you confirm that test procedures will test the bypass breaker undervoltage trip and will verify the operation of the bypass breaker position indication including the unambiguous indication of reactor trip breaker bypass conditions.

3) We understand that the seismic qualification of the shunt trip attachment is being reviewed by the Westinghouse Owners Group (WOG). We request that you notify the staff of the results of the WOG qualification program when complete and confirm that the shunt trips for Point Beach Units 1 and 2 are seismically qualified. 4) Last, we remind you that, as a separate item covered by Generic Letter 83-28, technical specifications will be required for the proposed modifications when completed.

Sincerely,

Original signed by:

James R. Miller, Chief Operating Reactors Branch #3 Division of Licensing

Enclosure: Safety Evaluation

cc: See next page

8411120068 841026 PDR ADOCK 05000266 PDR

ORB#3.0L PMKreutzer 9/2./84 ORB#3:DL TColburn:dd 9/24/84

JHolonich 90 /84 ORB#3:DL JRMiller 9/ /84