



GPU Nuclear Corporation
Post Office Box 388
Route 9 South
Forked River, New Jersey 08731-0388
609 971-4000
Writer's Direct Dial Number:

February 19, 1985

Mr. John Gaston, Director
Division of Water Resources
Department of Environmental Protection
P.O. Box CN-029
Trenton, NJ 08625


Dear Mr. Gaston:

Subject: GPU Nuclear Corporation
Oyster Creek Nuclear Generating Station
NJPDES Permit No. NJ 000 5550

Enclosed is the Discharge Monitoring Report for the subject permit for the month of January 1985. Please note that there were two noncompliances with a maximum effluent limitation during this reporting period. Copies of Noncompliance Report Nos. 000/5550/85/01, 02 and 03 are enclosed.

If you have any further questions concerning this report, please contact Mr. Douglas Moore of our Licensing and Regulatory Affairs Department at (609) 971-4630.

Very truly yours,


Peter B. Fiedler
Vice President & Director
Oyster Creek

PBF:DFM:dsm
Enclosures

(cc: Page 2)

8502270577 850219
PDR ADOCK 05000219
S PDR

50-219

IE25
1/1

To: John Gaston, Director
Dept. of Environmental Protection
Re: Discharge Monitoring Report
Page 2

cc: U.S. Environmental Protection Agency
Room 432
26 Federal Plaza
New York, NY 10278
Attn: Permits Administration Branch
Marion Burger

U.S. Army Corps of Engineers
Custom House
Second & Chestnut Streets
Philadelphia, PA 19106

Dr. Thomas E. Murley, Administrator
Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

Director
~~Office of Nuclear Reactor Regulations~~
U.S. Nuclear Regulatory Commission
Washington, DC 20555
c/o Distribution Services Branch, DDC, ADM

GPU Nuclear Corporation

Comments for Oyster Creek - January 1985

1. The Oyster Creek Nuclear Generating Station operated all days during the month of January.
2. Circulating water pumps 1-1, 1-2, 1-3, and 1-4 were operated all days during the month except as noted in item 3.
3. As permitted by condition 9b(1)b of the permit, the discharge-intake temperature difference exceeded the 23°F limit as a result of maintenance activities due to severe icing at the intake structure requiring the following circulating water pumps to be removed from service.
 - a. January 9, 1985 Circulating water pump 1-4 removed from service at 0635 hours. It was returned to service on 1-10-85 at 0401 hours. The delta temperature was exceeded from 0700 hours on 1-9-85 to 0430 hours on 1-10-85.
 - b. January 17, 1985 Circulating water pump 1-4 removed from service at 1208 hours. It was returned to service on 1-17-85 at 1345 hours. The delta temperature was exceeded from 1230 hours to 1415 hours on 1-17-85.
 - c. January 21, 1985 Circulating water pump 1-2 was removed from service at 2349 hours. It was returned to service at 1538 hours on 1-22-85, removed from service again at 1659 hours on 1-22-85. The delta temperature was exceeded from 0000 hours on 1-22-85 to 1545 hours on 1-23-85 when pump 1-2 was returned to service.
4. Dilution pump 1-1 was not operated during the month. Dilution pumps 1-2 and 1-3 were operated all days during the month.
5. The main condensers were not chlorinated during January.
6. The value reported for total suspended solids, discharge DMW is the average value of the analysis of two aliquots of the same sample.
7. Noncompliance with 9b(6)b Augmented Offgas-New Radwaste cooling water discharge-intake temperature difference exceeded.
8. Noncompliance with item 1 unauthorized discharge of a pollutant.
9. Noncompliance with 9b(1)b condenser cooling water discharge-intake delta temperature difference exceeded.