



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

FEB 19 1985

Docket File

Docket Nos.: 50-322/50-341/50-352/50-353/50-354/50-373/50-374/50-410
50-416/50-417/50-440/50-441/50-458/50-459/50-461/50-462

Mr. John F. Carolyn
Chairman
LRG Instrumentation Setpoint
Methodology Group
Philadelphia Electric Company
2301 Market Street
Mail Code N3-1
Philadelphia, Pennsylvania 19101

Dear Mr. Carolyn:

Subject: Interim Staff Evaluation Findings Pertaining to Setpoint
Methodology for General Electric Supplied Protection Systems
Instrumentation

The purpose of this letter is to provide you with the NRC staff's interim evaluation of the General Electric Owners Licensing Review Group (LRG) information, transmitted by your letter dated September 24, 1984, in which the staff's review and analysis of that information was requested before proceeding further with the setpoint methodology program.

During the latter part of CY1982, the NRC staff requested several Operating License applicants with General Electric nuclear steam supply systems to document the methodology used to establish the protection system actuation instrumentation setpoints in plant Technical Specifications. On January 31, 1984, the staff met with the LRG and GE to hear a presentation on this issue.

A staff report was issued on May 15, 1984 which contained the findings that resulted from its review of the information presented by the LRG and GE during meetings held in Bethesda on July 14, 1983 and January 31, 1984, relative to the GE-supplied protection system instrumentation setpoint methodology. That report identified areas of the proposed setpoint methodology which needed to be further evaluated by GE to fully resolve the staff's concerns. Section 5 of that report summarized the areas of concern, and provided the staff's recommendations for resolution. The areas of concern stated therein were:

- Environmental effects
- Validation of design allowables
- Technical Specification trip setpoints and allowable values
- Extrapolation of manufacturer's performance specifications
- Calibration error validation
- Statistical methods
- Computer modeling conservatisms
- Safety limits
- Instrument setpoints outside the NSSS
- Documentation

8502270596 850219
PDR ADOCK 05000322
P PDR

*IDAR-5
Fac-Lic.
X RD-82
GE*

FEB 19 1985

-2-

Several of these areas of concern were new, reflecting the results of the review of material presented for the first time at the January 31, 1984 meeting. They highlighted the staff's underlying concern that, although the use of the setpoint methodology developed up to that time had not resulted in transients exceeding safety limits, for limiting cases, the margins had been inadequately justified or supported.

Confirming agreements reached at a subsequent meeting between the staff and the LRG on April 12, 1984, during which time a draft of the May 15, 1984 staff report was screened for proprietary information, the LRG was to provide the staff a plan of action scoping the additional work to be contracted with GE to address the unresolved areas listed above and detailed in the staff's May 15, 1984 report. The LRG plan was submitted by your letter to T. M. Novak dated June 29, 1984, in which the staff's concurrence with the work scope was requested before commissioning GE to proceed. The staff's concurrence with the LRG work scope was communicated in my letter to you dated July 23, 1984.

Prior to issuance of the staff's report, the LRG presented information needed to resolve a number of concerns transmitted in your most recent letter dated September 24, 1984. That letter provided interim information regarding three of the ten areas of concern discussed in the staff's report which were: (1) NRC Concern 5.6, Statistical Methods; (2) NRC Concern 5.7, Computer Code Modeling Conservatism; and (3) NRC Concern 5.8, Safety Limits.

The staff has reviewed the interim information provided relative to Sections 5.6, 5.7 and 5.8 of the May 15, 1984 report, and it has concluded that these concerns are satisfactorily resolved. The staff's detailed findings are enclosed. As previously noted, the staff would like to emphasize however, that each LRG member should perform a confirmatory review of their plant-specific Technical Specifications, predicated on the revised GE methodology, and the results documented in a report to the NRC. The report should be submitted within 6 months after being notified of the staff's acceptance of the revised GE methodology.

The staff has suggested that another meeting with the LRG would be helpful in resolving the remaining concerns addressed in Section 5 of the staff's report. It is therefore requested that you advise Mr. John J. Stefano of my staff when such a meeting can be scheduled.

Sincerely,

Paul W. Youngblood for BSY
B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing

Enclosure: As stated

cc: See next page

FEB 19 1985

-2-

Several of these areas of concern were new, reflecting the results of the review of material presented for the first time at the January 31, 1984 meeting. They highlighted the staff's underlying concern that, although the use of the setpoint methodology developed up to that time had not resulted in transients exceeding safety limits, for limiting cases, the margins had been inadequately justified or supported.

Confirming agreements reached at a subsequent meeting between the staff and the LRG on April 12, 1984, during which time a draft of the May 15, 1984 staff report was screened for proprietary information, the LRG was to provide the staff a plan of action scoping the additional work to be contracted with GE to address the unresolved areas listed above and detailed in the staff's May 15, 1984 report. The LRG plan was submitted by your letter to T. M. Novak dated June 29, 1984, in which the staff's concurrence with the work scope was requested before commissioning GE to proceed. The staff's concurrence with the LRG work scope was communicated in my letter to you dated July 23, 1984.

Prior to issuance of the staff's report, the LRG presented information needed to resolve a number of concerns transmitted in your most recent letter dated September 24, 1984. That letter provided interim information regarding three of the ten areas of concern discussed in the staff's report which were: (1) NRC Concern 5.6, Statistical Methods; (2) NRC Concern 5.7, Computer Code Modeling Conservatism; and (3) NRC Concern 5.8, Safety Limits.

The staff has reviewed the interim information provided relative to Sections 5.6, 5.7 and 5.8 of the May 15, 1984 report, and it has concluded that these concerns are satisfactorily resolved. The staff's detailed findings are enclosed. As previously noted, the staff would like to emphasize however, that each LRG member should perform a confirmatory review of their plant-specific Technical Specifications, predicated on the revised GE methodology, and the results documented in a report to the NRC. The report should be submitted within 6 months after being notified of the staff's acceptance of the revised GE methodology.

The staff has suggested that another meeting with the LRG would be helpful in resolving the remaining concerns addressed in Section 5 of the staff's report. It is therefore requested that you advise Mr. John J. Stefano of my staff when such a meeting can be scheduled.

Sincerely,

BJ
B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing

Enclosure: As stated

cc: See next page

[Handwritten signature]
DL:LB#1
JStefano:es
2/19/85

[Handwritten signature]
DL:LB#1
BJYoungblood
2/19/85

*See next page for Distribution

DIST: w/o attachment

Docket File

NRC PDR

Local PDR

PRC System

NSIC

LB#1 Rdg

MRushbrook

JStefano

OELD, Attorney

ACRS (16)

EJordan

RHeischman

H. Thompson/F. Miraglia

R. Bernero

T. Novak

R. Houston

F. Rosa

J. Mauck

W. L. Brooks

S. B. Sun

E. Butcher

D. Brinkman

A. Schwencer

w/attachment

B. Siegel (Clinton)

D. Lynch (Fermi-2)

A. Bourria (LaSalle)

R. Caruso (Shoreham)

M. Haughey (Nine Mile Point-2)

D. Wagner (Hope Creek 1)

E. Weinkam (River Bend)

L. Kintner (Grand Gulf)

R. Martin (Limerick)

Mr. Al Wegele
Detroit Edison Company
6400 N. Dixie Hwy
Mail Drop 346 NOC
Newport, Michigan 48166

Mr. John Morin
Long Island Lighting Company
Shoreham Nuclear Power Station
P. O. Box 618
Wading River, NY 11792

Mr. Charles Schroeder
Commonwealth Edison Company
P. O. Box 767
One First National Plaza
Chicago, Illinois 60690

Mr. John Fowler
Mississippi Power & Light Company
P. O. Box 1640
Jackson, Mississippi 39205

Mr. Dale Holtzscher
Illinois Power Company
500 S. 27th Street
Mail Code F-33
Decatur, Illinois 62525

Ms. Eileen Buzzelli
Cleveland Electric Illuminating Company
P. O. Box 84
Perry, Ohio 44081

Mr. John Price
Gulf States Utilities
P. O. Box 2951
Beaumont, Texas 77704

Mr. Gerald Tenenbaum
Public Service Electric & Gas
80 Park Plaza
T-21B
Newark, New Jersey 07101

Mr. Tony Zallnick
Niagara Mohawk Power Corporation
300 Eric Blvd, West
Syracuse, N. Y. 13202

Mr. Roger Boyd
KMC, Inc.
801 18th Street, N. W.
Suite 300
Washington, D. C. 20006

Mr. Dave Foreman
General Electric Company
175 Curtner Ave.
Mail Stop 682
San Jose, California 95125

SHOREHAM (1)

Lawrence Brenner, Esq.*
Administrative Judge
Atomic Safety & Licensing Board
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Dr. George A. Ferguson
Administrative Judge
School of Engineering
Howard University
2300 6th Street, NW
Washington, DC 20059

Dr. Peter A. Morris*
Administrative Judge
Atomic Safety & Licensing Board
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Alan S. Rosenthal, Esq., Chairman*
Atomic Safety & Licensing Appeal Board
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Howard L. Blau, Esq.
217 Newbridge Road
Hicksville, New York 11801

W. Taylor Reveley III, Esq.
Hunton & Williams
707 East Main Street
P. O. Box 1535
Richmond, Virginia 23212

Howard A. Wilber*
Atomic Safety & Licensing Appeal Board
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Eleanor L. Frucci, Esq.
Atomic Safety & Licensing Board
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Stephen B. Latham, Esq.
John F. Shea, III, Esq.
Twomey, Latham & Shea
Attorneys at Law
P. O. Box 398
33 West Second Street
Riverhead, New York 11901

Atomic Safety & Licensing
Board Panel*
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Atomic Safety & Licensing Appeal
Board Panel*
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Gary J. Edles, Esq.*
Atomic Safety & Licensing
Appeal Board
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Gerald C. Crotty, Esq.
Ben Wiles, Esq.
Counsel to the Governor
Executive Chamber
State Capitol
Albany, New York 12224

Herbert H. Brown, Esq.
Lawrence Coe Lanpher, Esq.
Karla J. Letsche, Esq.
Kirkpatrick, Lockhart, Hill,
Christopher & Phillips
1900 M Street, NW - 8th Floor
Washington, DC 20036

Leon Friedman, Esq.
Costigan, Hyman & Hyman
120 Mineola Boulevard
Mineola, New York 11501

James B. Dougherty, Esq.
3045 Porter Street, NW
Washington, DC 20008

Fabian G. Palomino, Esq.
Special Counsel to the Governor
Executive Chamber - State Capitol
Albany, New York 12224

Edward M. Barrett, Esq.
General Counsel
Long Island Lighting Company
250 Old County Road
Mineola, New York 11501

Mr. Brian McCaffrey
Long Island Lighting Company
Shoreham Nuclear Power Station
P. O. Box 618
North Country Road
Wading River, New York 11792

Marc W. Goldsmith
Energy Research Group, Inc.
400-1 Totten Pond Road
Waltham, Massachusetts 02154

Martin Bradley Ashare, Esq.
Suffolk County Attorney
H. Lee Dennison Building
Veteran's Memorial Highway
Hauppauge, New York 11788

Ken Robinson, Esq.
New York State Department of Law
2 World Trade Center - Room 4615
New York, New York 10047

Resident Inspector
Shoreham NPS, U. S. NRC
Post Office Box B
Rocky Point, New York 11778

Mr. William Steiger
Acting Plant Manager
Shoreham Nuclear Power Station
P. O. Box 628
Wading River, New York 11792

MHB Technical Associates
1723 Hamilton Avenue - Suite K
San Jose, California 95125

Hon. Peter Cohalan
Suffolk County Executive
County Executive/Legislative Bldg.
Veteran's Memorial Highway
Hauppauge, New York 11788

Mr. Jay Dunkleberger
New York State Energy Office
Agency Building 2
Empire State Plaza
Albany, New York 12223

Ms. Nora Bredes
Shoreham Opponents Coalition
195 East Main Street
Smithtown, New York 11787

Chris Nolin
New York State Assembly
Energy Committee
626 Legislative Office Building
Albany, New York 12248

Ezra I. Bialik, Esq.
Assistant Attorney General
Environmental Protection Bureau
New York State Department of Law
2 World Trade Center
New York, New York 10047

FERMI

Dr. Wayne Jens
Vice President - Nuclear Operations
The Detroit Edison Company
2000 Second Avenue
Detroit, Michigan 48226

cc: Mr. Harry H. Voigt, Esq.
LeBoeuf, Lamb, Leiby & MacRae
1333 New Hampshire Avenue, N. W.
Washington, D. C. 20036

Peter A. Marquardt, Esq.
Co-Counsel
The Detroit Edison Company
2000 Second Avenue
Detroit, Michigan 48226

Mr. William J. Fahrner
Project Manager - Fermi 2
The Detroit Edison Company
2000 Second Avenue
Detroit, Michigan 48226

Mr. O. Keener Earle
Supervisor-Licensing
The Detroit Edison Company
Enrico Fermi Unit 2
6400 No. Dixie Highway
Newport, Michigan 48166

Mr. Paul Byron
U. S. Nuclear Regulatory Commission
Resident Inspector's Office
6450 W. Dixie Highway
Newport, Michigan 48166

Mr. Harry Tauber
Group Vice President
The Detroit Edison Company
2000 Second Avenue
Detroit, Michigan 48226

Ronald C. Callen
Adv. Planning Review Section
Michigan Public Service Commission
6545 Mercantile Way
P. O. Box 30221
Lansing, Michigan 48909

Regional Administrator
U. S. NRC, Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

LIMERICK

Mr. Edward G. Bauer, Jr
Vice President & General Counsel
Philadelphia Electric Company
Philadelphia, Pennsylvania 19101

Troy B. Conner, Jr., Esquire
Conner and Wetterhahn
1747 Pennsylvania Ave, N.W.
Washington, D. C. 20006

Zori G. Ferkin
Assistant Counsel
Governor's Energy Council
1625 N. Front Street
Harrisburg, Pennsylvania 17105

Federic M. Wentz
County Solicitor
County of Montgomery
Courthouse
Norristown, Pennsylvania 19404

Eugene J. Bradley
Philadelphia Electric Company
Associate General Counsel
2301 Market Street
Philadelphia, Pennsylvania 19101

Mr. Vincent Boyer
Senior Vice President
Nuclear Operations
Philadelphia Electric Company
2301 Market Street
Philadelphia, Pennsylvania 19101

Mr. Suresh Chaudhary
Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 47
Sanatoga, PA 19464

James Wiggins, SR. R.I.
U. S. Nuclear Regulatory Commission
P. O. Box 47
Sanatoga, Pennsylvania 19464

Mr. Marvin I. Lewis
6504 Bradford Terrace
Philadelphia, Pennsylvania 19149

Frank R. Romanc, Chairman
Air & Water Pollution Patrol
61 Forest Avenue
Ambler, Pennsylvania 19002

Charles W. Elliott, Esquire
Brose & Poswistilo, 1101 Bldg.
325 N. 10th Street
Easton, Pennsylvania 18402

Ms. M. Mulligan
Limerick Ecology Action
762 Queen St.
Pottstown, Pennsylvania 19464

Mr. Karl Abraham
Public Affairs Officer
Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19806

Thomas Gerusky, Director
Bureau of Radiation Protection
Dept. of Environmental Resources
5th Floor, Fulton Bank Bldg.
Third and Locust Streets
Harrisburg, Pennsylvania 17120

Sugarman, Denworth & Hellegers
16th Floor Center Plaza
101 North Broad Street
Philadelphia, Pennsylvania 19106

Robert L. Anthony
Friends of the Earth
Delaware Valley
103 Vernon Lane, Box 186
Moylan, Pennsylvania 19065

Martha W. Bush
Deputy City Solicitor
Municipal Services Bldg.
15th and JFK Blvd.
Philadelphia, Pennsylvania 19107

David Wersan, Esq.
Assistant Consumer Advocate
Office of Consumer Advocate
1425 Strawberry Square
Harrisburg, Pennsylvania 17120

Steven P. Hershey, Esq.
Community Legal Services, Inc.
Law Center North Central - Bevery Bldg.
3701 North Board Street
Philadelphia, Pennsylvania 19140

Mr. J. T. Robb, NS-1
Philadelphia Electric Company
2301 Market Street
Philadelphia, Pennsylvania 19101

Timothy R. S. Campbell, Director
Department of Emergency Services
14 East Biddle Street
West Chester, Pennsylvania 19380

Director, Pennsylvania Emergency
Management Agency
Basement, Transportation &
Safety Building
Harrisburg, Pennsylvania 17120

Angus Love, Esq.
107 East Main Street
Norristown, Pennsylvania 19402

Helen F. Hoyt, Chairman
Administrative Judge
Atomic Safety & Licensing Board
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dr. Jerry Harbour
Administrative Judge
Atomic Safety & Licensing Board
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dr. Richard F. Cole
Administrative Judge
Atomic Safety & Licensing Board
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. Spence W. Perry, Esq.
Associate General Counsel
Federal Emergency Management Agency
Room 840
500 C St., S.W.
Washington, D. C. 20472

Hope Creek

Mr. R. L. Mittl, General Manager
Nuclear Assurance & Regulation
Public Service Electric & Gas Company
P. O. Box 570 T22A
Newark, New Jersey 07101

cc:

Troy B. Conner, Jr. Esquire
Conner & Wetterhahn
1747 Pennsylvania Avenue W.
Washington, D.C. 20006

Richard Fryling, Jr., Esquire
Associate General Solicitor
Public Service Electric & Gas Co.
P. O. Box 570 T5E
Newark, New Jersey 07101

Mr. R. Blough
Resident Inspector
U.S.N.R.C.
P. O. Box 241
Hancocks Bridge, New Jersey 08038

Richard F. Engel
Deputy Attorney General
Division of Law
Environmental Protection Section
Richard J. Hughes Justice Complex CN-112
Trenton, New Jersey 08625

Mr. Robert J. Touhey, Acting Director
DNREC - Division of Environmental Control
89 Kings Highway
P. O. Box 1401
Dover, Delaware 19903

Mr. R. S. Salvesen
General Manager-Hope Creek Operation
Public Service Electric & Gas Co.
P.O. Box A
Hancocks Bridge, New Jersey 08038

Mr. B. A. Preston
Project Licensing Manager
Public Service Electric & Gas Co.
P. O. Box 570 T22A
Newark, New Jersey 07101

Susan C. Remis
Division of Public Interest Advocacy
New Jersey State Department of
the Public Advocate
Richard J. Hughes Justice Complex
CN-850
Trenton, New Jersey 08625

Gregory Minor
Richard Hubbard
Dale Bidenbaur
MHR Technical Associates
1723 Hamilton Avenue, Suite K
San Jose, California 95125

Office of Legal Counsel
Department of Natural Resources
and Environmental Control
89 Kings Highway
P.O. Box 1401
Dover, Delaware 19903

Mr. K. W. Burrowes, Project Engineer
Bechtel Power Corporation
50 Beale Street
P. O. Box 3965
San Francisco, California 94119

Mr. J. M. Ashley
Senior Licensing Engineer
c/o PSE&G Company
Bethesda Office Center, Suit 550
4520 East-West Highway
Bethesda, Maryland 20814

Mr. A. E. Giardino
Manager - Quality Assurance E&C
Public Service Electric & Gas Co.
P. O. Box A
Hancocks Bridge, New Jersey 08038

La Salle

Mr. Dennis L. Farrar
Director of Nuclear Licensing
Commonwealth Edison Company
P.O. Box 767
Chicago, Illinois 60690

cc: Philip P. Steptoe, Esquire
Suite 4200
One First National Plaza
Chicago, Illinois 60603

John W. McCaffrey
Chief, Public Utilities Division
160 North LaSalle Street, Room 900
Chicago, Illinois 60601

Assistant Attorney General
188 West Randolph Street
Suite 2315
Chicago, Illinois 60601

Michael J. Jordan, Resident Inspector
La Salle, NPS, U.S.N.R.C.
P.O. Box 224
Marseilles, Illinois 61364

Chairman
La Salle County Board of Supervisors
La Salle County Courthouse
Ottawa, Illinois 61350

Attorney General
500 South 2nd Street
Springfield, Illinois 62701

The Honorable Tom Corcoran
United States House of Representatives
Washington, D.C. 20515

Chairman
Illinois Commerce Commission
Leland Building
527 East Capitol Avenue
Springfield, Illinois 62706

Mr. Gary N. Wright, Manager
Nuclear Facility Safety
Illinois Department of Nuclear Safety
1035 Outer Park Drive, 5th Floor
Springfield, Illinois 62704

Nine Mile Point 2

Mr. B. G. Hooten
Executive Director, Nuclear Operations
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, New York 13202

cc: Mr. Troy B. Conner, Jr., Esq.
Conner & Wetterhahn
Suite 1050
1747 Pennsylvania Avenue, N.W.
Washington, D.C. 20006

Richard Goldsmith
Syracuse University
College of Law
E. I. White Hall Campus
Syracuse, New York 12223

Ezra I. Bialik
Assistant Attorney General
Environmental Protection Bureau
New York State Department of Law
2 World Trade Center
New York, New York 10047

Resident Inspector
Nine Mile Point Nuclear Power Station
P. O. Box 99
Lycoming, New York 13093

Mr. John W. Keib, Esq.
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, New York 13202

Jay M. Gutierrez, Esq.
U. S. Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

Norman Rademacher,
Licensing
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, New York 13202

GRAND GULF

Mr. J. B. Richard
Senior Vice President, Nuclear
Mississippi Power & Light Company
P.O. Box 23054
Jackson, Mississippi 39205

cc: Robert B. McGehee, Esquire
Wise, Carter, Child, Steen and Caraway
P.O. Box 651
Jackson, Mississippi 39205

The Honorable William J. Guste, Jr.
Attorney General
Department of Justice
State of Louisiana
Baton Rouge, Louisiana 70804

Nicholas S. Reynolds, Esquire
Bishop, Liberman, Cook, Purcell
and Reynolds
1200 17th Street, N.W.
Washington, D. C. 20036

Mr. Ralph T. Lally
Manager of Quality
Middle South Energy, Inc.
225 Baronne Street
P.O. Box 61000
New Orleans, Louisiana 70161

Mr. Larry Dale, Director
Nuclear Licensing and Safety
Mississippi Power & Light Company
P.O. Box 23054
Jackson, Mississippi 39205

Mr. R. W. Jackson, Project Engineer
Grand Gulf Nuclear Station
Bechtel Power Corporation
Gaithersburg, Maryland 20760

Mr. Alan G. Wagner
Senior Resident Inspector
Route 2, Box 399
Port Gibson, Mississippi 39150

J. Nelson Grace, Regional Admin.
U.S. Nuclear Regulatory Commission,
Region II
101 Marietta Street, N.W., Suite 2900
Atlanta, Georgia 30323

Mr. J. E. Cross, General Manager
Grand Gulf Nuclear Station
P.O. Box 756
Port Gibson, Mississippi 39150

PERRY

Mr. Murray R. Edelman, Vice President
Nuclear Operations Group
The Cleveland Electric
Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

cc: Jay Silberg, Esq.
Shaw, Pittman, & Trowbridge
1800 M Street, N. W.
Washington, D. C. 20006

Mr. Larry O. Beck
The Cleveland Electric
Illuminating Company
P. O. Box 97 E-210
Perry, Ohio 44081

Donald H. Hauser, Esq.
The Cleveland Electric
Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

Regional Inspector's Office
U. S. Nuclear Regulatory Commission
Partly at Center Road
Perry, Ohio 44081

Regional Administrator
U. S. NRC, Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Donald T. Ezzone, Esq.
Assistant Prosecuting Attorney
105 Main Street
Lake County Administration Center
Painesville, Ohio 44077

Ms. Sue Hiatt
OCRE Interim Representative
8275 Munson
Mentor, Ohio 44060

Terry J. Lodge, Esq.
618 N. Michigan Street
Suite 105
Toledo, Ohio 43624

John G. Cardinal, Esq.
Prosecuting Attorney
Ashtabula County Courthouse
Jefferson, Ohio 44047

River Bend Station

Mr. William J. Cahill, Jr.
Senior Vice President
River Bend Nuclear Group
Gulf States Utilities Company
Post Office Box 2951
Beaumont, Texas 77704
ATTN: Mr. J. E. Booker

cc: Troy B. Conner, Jr., Esq.
Conner and Wetterhahn
1747 Pennsylvania Avenue, N. W.
Washington, D.C. 20006

Mr. William J. Reed, Jr.
Director - Nuclear Licensing
Gulf States Utilities Company
Post Office Box 2951
Beaumont, Texas 77704

H. Anne Plettinger
3456 Villa Rose Dr.
Baton Rouge, Louisiana 70806

Richard M. Troy, Jr., Esq.
Assistant Attorney General in Charge
State of Louisiana Department of Justice
234 Loyola Avenue
New Orleans, Louisiana, 70112

Dwight D. Chamberlain
Resident Inspector
Post Office Box 1051
St. Francisville, Louisiana 70775

Gretchen R. Rothschild
Louisianians for Safe Energy, Inc.
1659 Glenmore Avenue
Baton Rouge, Louisiana 70775

James W. Pierce, Jr., Esq.
P. O. Box 23571
Baton Rouge, Louisiana 70893

Ms. Linda B. Watkins/Mr. Steven Irving
Attorney at Law
355 Napoleon Street
Baton Rouge, Louisiana 70802

Mr. David Zaloudek
Nuclear Energy Division
Louisiana Department of
Environmental Quality
Post Office Box 14690
Baton Rouge, Louisiana 70898

Mr. J. David McNeill, III
William G. Davis, Esq.
Department of Justice
Attorney General's Office
7434 Perkins Road
Baton Rouge, Louisiana 70808

Clinton

Mr. Frank A. Spangenberg
Director of Nuclear Licensing &
Configuration Management
Clinton Power Station
P. O. Box 306
Mail Code V920
Clinton, Illinois 61727

Mr. D. P. Hall
Vice President
Clinton Power Station
P. O. Box 678
Clinton, Illinois, 61727

Mr. H. R. Victor
Manager-Nuclear Station Engineering Dpt.
Clinton Power Station
P. O. Box 678
Clinton, Illinois 61727

Sheldon Zabel, Esquire
Schiff, Hardin & Waite
7200 Sears Tower
233 Wacker Drive
Chicago, Illinois 60606

Mr. Fred Christenson
Resident Inspector
U. S. Nuclear Regulatory Commission
RR 3, Box 229 A
Clinton, Illinois 61727

Mr. R. C. Heider
Project Manager
Sargent & Lundy Engineers
55 East Monroe Street
Chicago, Illinois 60603

Mr. L. Larson
Project Manager
General Electric Company
175 Curtner Avenue, N/C 395
San Jose, California 95125

Mr. Allen Samuelson, Esquire
Assistant Attorney General
Environmental Control Division
Southern Region
500 South Second Street
Springfield, Illinois 62706

Jean Foy, Esquire
511 W. Nevada
Urbana, Illinois 61801

Richard B. Hubbard
Vice President
Technical Associates
1723 Hamilton Ave. - Suite K
San Jose, CA 95125

EVALUATION OF LRG
INTERIM REPORT ON SETPOINT METHODOLOGY
(SEPTEMBER 24, 1984)

NRC Concern 5.6, Statistical Methods

As discussed in Section 4.0 of the report, for certain instrument channels, statistical methods were used to combine instrument uncertainty allowances to show the margin provided between the trip setpoint and the analytic limit. It is the staff's concern that the statistical methods used may have included certain non-conservative aspects. One non-conservatism already discussed is the neglecting of environmental effects (See Section 5.1 of the report). Another is the treatment of certain variables as independent.

As discussed in Section 5.5 of the report, calibration error can be attributed to a number of factors including those related to human factor considerations, calibration equipment, and procedural requirements. These error factors, in combination with component drift, tend to come together as a singular error component in their effects on the input/output relationship of a transmitter or trip unit. When summing these errors statistically they should be added into one unit; that total error may then be used in a statistical summation. If, for example, the square root of the sum of the squares method were used, the following would be an appropriate method to consider the dependent variables associated with drift $[(\text{sensor drift} + \text{human factor calibration considerations} + \text{calibration equipment inaccuracy} + \text{error band allowed by procedure})^2 + (\text{trip unit drift} + \text{human factor calibration considerations} + \text{calibration equipment inaccuracy} + \text{error band allowed by procedure})^2 + (x)^2 + (y)^2 + (z)^2]^{1/2}$. In this equation, x, y and z represent independent error

contributors to the total channel error. It was the staff's recommendation that the methods described above or other appropriate methods be used to treat the dependent variables associated with drift and calibration inaccuracy.

To facilitate referring to these terms, the following definitions and expressions should be used:

For the measurement signal, v:

v1 = sensor drift

v2 = human factor calibration considerations (applicable to the sensor)

v3 = equipment calibration inaccuracy (applicable to sensor)

v4 = error band allowed by procedure (in calibration of sensor)

For the reference signal, w:

w1 = trip unit drift

w2 = human factor calibration considerations (applicable to the trip unit)

w3 = calibration equipment inaccuracy (applicable to the trip unit)

w4 = error band allowed by procedure (in calibration of trip unit)

For the (measurement - reference) signal difference:

x = an independent error contributor to total channel error

y = an independent error contributor to total channel error

z = an independent error contributor to total channel error

The expression in the first paragraph now can be written as:

$$((v_1 + v_2 + v_3 + v_4)^2 + (w_1 + w_2 + w_3 + w_4)^2 + x^2 + y^2 + z^2)^{1/2}.$$

Terms v_1 and w_1 involve drift; and v_2-4 and w_2-4 involve the calibration procedures. To further facilitate discussion, this expression can be broken down into two major algebraic expressions which are:

$$v_1 + v_2 + v_3 + v_4 \text{ and } w_1 + w_2 + w_3 + w_4.$$

According to General Electric's definitions, these terms are defined as follows:

Drift, terms v_1 and w_1 , is a selected number of standard deviations in the distribution of random values which characterize the difference between initial and final indicated signal values, as that value might change over a relatively long period of time between calibration and check due to some type of sensor deterioration, for example, exclusive of the parts of the initial and final indications which reflect random error due to all aspects of the calibration procedure and to instrument accuracy. Thus, drift is "pure" long term change in indication for the same true value. Its value exists conceptually; it could be found in practice by averaging many initial readings and many final readings before taking the difference. (Thus, GE infers that "drift" is different from the "drift allowance" or "reading-difference allowance" which appears in the GE setpoint methodology as the adjustment on Allowable Value to reach to Nominal Trip Setpoint (NTSP)).

Human factor calibration considerations, terms v_2 and w_2 , is a selected number of standard deviations in the distribution of random errors introduced in the calibration process, both initial and check, by the human element. These errors have to do with the ability of the operator to interpret the procedure and accurately read the calibration instruments. GE has taken the position that these errors are totally unrelated to, and independent of, either drift or factors affecting the correctness of the calibration equipment.

Calibration equipment inaccuracy, terms v_3 and w_3 , is a selected number of standard deviations in the distribution of random errors in the calibration process due to any physical instability or incorrectness of the equipment used in the calibration. GE believes that this term is totally equipment related, and independent of drift or human factors involved in use of the equipment.

Error band allowed by the procedure, terms v_4 and w_4 , involves a practice in which there is a range, upon a check calibration, within which no adjustment of the calibration would be made. It is anticipated that such a range would be a reflection of the random errors affecting the indicated value due to the calibration process and to instrument accuracy at the times of both the initial and check calibrations. GE has accounted for these errors in the other terms discussed above, and believes there is no need to account for them a second time. Therefore, GE has chosen to omit this term.

In a given application, the number of standard deviations selected must be consistent for each term. GE ordinarily uses two standard deviations. Typically, the NRC staff has accepted 95% as a probability limit for errors. That is, of the observed distribution of values for a particular error component in the empirical data base, 95% of the data points will be bounded by the value selected if the data base follows a "normal" distribution. This corresponds to an error distribution approximately equal to a "two sigma" value.

In general, the error values discussed above are consequences of one or more physical causes. GE has taken the approach that different physical causes account for the values of each of the error terms in the above expressions, and that those causes operate independently to assign a random error value to each term, at a point in time. Based on our review of this information, the staff has concluded that the probability of occurrence of two or more events (errors) is not influenced by the occurrence of any of them on the other and, therefore, the staff agrees with the LRG that these errors are independent. The error values for the above discussed terms cannot reasonably be expected to move in concert. Thus, different error values apply to each term and these can be chosen from their distributions independently.

The selection of the method to be used for analyzing and combining uncertainties in determining the allowable value for the safety limit may be based on the "square root of the sum of the squares" method since the above terms are independent and no common error source exists. Therefore, the expression can be written as the sum of squared standard deviations rather than as an absolute sum. The expression now becomes $(v_1^2 + v_2^2 + v_3^2 + w_1^2 + w_2^2 + x^2 + y^2 + z^2)^{1/2}$.

The staff has concluded that this portion of the setpoint methodology meets the relevant Commissions regulations. (General Design Criterion 20, 10 CFR Part 50.36 and Part 50.46). Further, the LRG has followed the guidance contained in Regulatory Guide 1.105, "Instrumentation Setpoints," including the additional information provided in ISA Standard S67.04, "Setpoints for Nuclear Safety-Related Instrumentation Used in Nuclear Power Plants."

NRC Concern 5.7, Computer Code Modeling Conservatism

As discussed in Section 4.0 of the report for the APRM scram functions evaluated, the statistically determined sum of the instrument channel bias and uncertainty exceeded the analytic limit. To justify the proposed setpoints credit was taken for conservatism in the core transient models. NEDO-24154, "Qualification Of The One-Dimensional Core Transient Model For Boiling Water Reactors" (ODYN) October 1978 and NEDO-24011 PA Rev. 6 "GESTAR - Reload Licensing Topical Report" contained the codes used.

By letter dated February 4, 1981 from R. Tedesco (NRC) to G. Sherwood (GE), the NRC documented its findings on ODYN in an SER. As discussed in the staff's SER, the code represents a best estimate calculation. From the review of the test program undertaken by General Electric to verify ODYN's analytical methods, the staff found that the code either over or under predicted peak pressures at various reactor coolant system locations. A review of the test results indicated that all model conservatisms claimed by General Electric such as those associated with the calculation of the steam dome pressures and neutron flux, the collapsing of 3-D core neutronics and thermal hydraulics, the gap conductance input parameters and any other conservatism claimed in the computer model are either so small that it did not make any difference in the calculated delta Critical Power Ratio (CPR) for these tests or all of these claimed conservatisms are offset by an unidentified nonconservatism somewhere else, perhaps in calculation of vessel flow. Based on a review of the evaluation of the codes contained in the SER, the staff finds that the credit taken

in the instrument setpoint evaluation for code modeling conservatisms has not been justified. Therefore, it was the staff's recommendation that the instrument setpoints be revised or that an equivalent margin from some other source be shown to account for the instrument bias and uncertainty.

By letter dated April 13, 1983 from C. Thomas (NRC) to J. Charnley (GE), the NRC documented its findings on GESTAR in an SER. As discussed in the staff's SER, the review focused on the barrier fuel design. It was not apparent that the 3-D transient modeling code was thoroughly addressed in GESTAR. As such, the staff recommended that the LRG provide a discussion of the code and any test programs undertaken to verify its analytical methods, or the instrument setpoints be revised, or an equivalent margin from some other source be shown to account for the instrument bias and uncertainty.

By letter dated September 24, 1984 from John F. Carolan to B. J. Youngblood, the LRG provided a response to this concern which consisted mostly of General Electric Company Proprietary Information. In this response GE presented a discussion and an analysis that illustrated the model conservatisms claimed were less than the actual model conservatism. While we disagree somewhat with the setpoint methodology that GE has used, the staff concludes that the calculated model conservatisms as shown are acceptable. However, the staff is very much interested (as part of GE's final response to this concern)

in reviewing the computer model conservatisms calculated for the reactor trip caused by an increasing reactor power event. Therefore, we request that the computer code modeling conservatisms for this event be calculated by GE and included as part of its final response. The staff is currently verifying the GE analysis, the values assumed for the various parameters, and the resulting consequences.

NRC Concern 5.8, Safety Limits

As discussed in Section 4.0 of the report, the reactor high pressure trip setpoint was evaluated to show that with the combined design allowances for uncertainties, the trip function would be accomplished prior to exceeding a 1500 psig safety limit. At the January 31, 1984 meeting, the staff questioned the LRG's basis for choosing 1500 psig as a safety limit. The LRG stated that this value represented 125 percent of the reactor vessel design pressure.

As discussed in Sections 3 and 4 of the report, each facility's technical specifications define plant specific safety limits. For reactor vessel pressure, 110 percent of vessel design pressure is the safety limit which is 1375 psig for the BWRs currently undergoing licensing review. Therefore, it was the staff's requirement that safety limits as defined in the technical specifications must be used in the setpoint methodology calculations.

GE stated that for most transient events presented in the FSAR are in the moderate category (Service Level B* or Upset), the criteria stated in the FSAR

*The ASME Boiler and Pressure Vessel Code, Section III, Nuclear Power Plant Components, recognizes the difference between more and less frequent situations. This is the reason for the categories of events called Service Level A, B, C and D in ASME code paragraph NCA-242.2. Earlier usage called the categories Normal, Upset, Emergency, and Faulted.

clearly applies to that type of event. The criteria states (among other details) that the peak pressure must be limited to less than 110% of the design pressure of the vessel. For GE BWRs, vessel design is usually at 1250 psig, so this Upset limit is 1375 psig. The plant is designed and evaluated to show that the combination of scram and safety-relief valves maintains peak pressure within this limit. Chapter 5 of each FSAR shows that this limit is met for the worst upset category events.

For all current plants, the worst event is the MSIV closure with failure of the position switch scram. High flux scram and the safety-relief valves must provide protection below the Upset limit. However, this event plus the failures is a very remote situation. It is expected to be in the low-frequency range which is considered by the ASME to be Emergency; however, it is conservatively evaluated in the current FSARs as an Upset event. The case discussed in the setpoint methodology review (noted above) assumed even further failures, i.e., an APRM high flux scram failure. GE believes the likelihood of this event along with the additional failures is beyond the upset (service level B) range and based on the ASME code this scenario would be classified service level D or faulted. GE has conservatively applied the service level C or emergency overpressure criteria.

The ASME code, Paragraph NB-3224.1 allows the equivalent of 120% overpressure in this category, which is 1500 psig for all current GE BWRs. GE has stated that ASME vessel design practice has always recognized these categories and vessel design stress analyses include several Emergency and Faulted situations.

No relaxation of limits for the more frequent events is proposed, in fact the setpoint methodology presentation explicitly includes the Upset limit for the APRM high neutron flux setpoint evaluation. The 1500 psig limit application of the ASME Emergency limit is only being used by GE for an event that is clearly in that remote range of occurrence. GE has provided calculations that show the failure of two reactor protection system functions clearly fit this category. The staff has reviewed the LRG response to this concern and concludes that the information is valid and that the safety limit of 1500 psig chosen for the event analyzed (service level C) is acceptable. However, the staff is currently verifying the accuracy of the risk analysis used to reach the LRG's conclusion.