

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) LaSalle County Nuclear Station Unit 2	DOCKET NUMBER (2) 0 5 0 0 0 3 7 4	PAGE (3) 1 OF 2
--	--------------------------------------	--------------------

TITLE (4)
HPCS Suction Valve Swap

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)			
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES			DOCKET NUMBER(S)
0 1	2 2	8 5	8 5	0 0 6	0 0	0 2	1 3	8 5				0 5 0 0 0
												0 5 0 0 0

OPERATING MODE (9) 1	POWER LEVEL (10) 0 8 5	THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR § (Check one or more of the following) (11)									
		<input type="checkbox"/> 20.402(b)	<input type="checkbox"/> 20.408(a)	<input checked="" type="checkbox"/> 20.73(a)(2)(iv)	<input type="checkbox"/> 73.71(b)						<input type="checkbox"/> 73.71(c)
		<input type="checkbox"/> 20.408(a)(1)(i)	<input type="checkbox"/> 20.30(a)(1)	<input type="checkbox"/> 20.73(a)(2)(v)						OTHER (Specify in Abstract below and in Text, NRC Form 305A)	
		<input type="checkbox"/> 20.408(a)(1)(ii)	<input type="checkbox"/> 20.30(a)(2)	<input type="checkbox"/> 20.73(a)(2)(vi)							
		<input type="checkbox"/> 20.408(a)(1)(iii)	<input type="checkbox"/> 20.73(a)(2)(i)	<input type="checkbox"/> 20.73(a)(2)(vii)(A)							
		<input type="checkbox"/> 20.408(a)(1)(iv)	<input type="checkbox"/> 20.73(a)(2)(ii)	<input type="checkbox"/> 20.73(a)(2)(vii)(B)							
		<input type="checkbox"/> 20.408(a)(1)(v)	<input type="checkbox"/> 20.73(a)(2)(iii)	<input type="checkbox"/> 20.73(a)(2)(ix)							

LICENSEE CONTACT FOR THIS LER (12)						TELEPHONE NUMBER					
NAME Harold T. Vinyard, extension 323						AREA CODE 8 1 5 3 5 7 6 7 6 1					

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRPDS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRPDS
B	B G Z	1 9 9 9	Z 1 9 9 9	N					

SUPPLEMENTAL REPORT EXPECTED (14)	EXPECTED SUBMISSION DATE (15)	MONTH DAY YEAR
<input type="checkbox"/> YES (If yes, complete EXPECTED SUBMISSION DATE)	<input checked="" type="checkbox"/> NO	

ABSTRACT (Limit to 1000 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

On January 22, 1985, at 0347 with Unit 2 operating at 85% power, the HPCS pump suction valve to the condensate storage tank closed and the suction from the Suppression Pool opened.

The cause for the suction valve transfer was an actual high Suppression Pool water level. The HPCS system is designed to transfer pump suction to the Suppression Pool in the event of a high Suppression Pool water level. Since the system performed its designed function, the consequences of this event were minimal.

The Suppression Pool water level was lowered and a normal suction path from the cycled condensate storage tank was reestablished.

8502270673 850213
PDR ADOCK 05000374
S PDR

IE 22
111

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1) LaSalle County Station Unit 2	DOCKET NUMBER (2) 0 5 0 0 0 3 7 4	LER NUMBER (6)			PAGE (3)	
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		
		85	006	00	02	OF 02

TEXT (If more space is required, use additional NRC Form 388A's) (17)

I. EVENT DESCRIPTION

On January 22, 1985, at 0347 with Unit 2 operating at 85% power, the HPCS (BG) pump suction valve to the Suppression Pool opened while the normal suction valve to the condensate storage tank (KA) closed. This is a normal action of the HPCS system when a high Suppression Pool level (700' 1" setpoint per Technical Specifications) is reached.

II. CAUSE

The cause for the suction valve transfer was attributed to actual high Suppression Pool level. The HPCS (BG) pump suction valves are designed to transfer to a suction path from the Suppression Pool when the water level reaches 26' 9 1/4". Suppression Pool level tends to drift up due to minor valve leakage and valve cycling for Operating Surveillances. The Narrow Range Suppression Pool Level Indicator is not sufficiently accurate to adequately warn the Operator to reject the pool before reaching the actuation point.

III. PROBABLE CONSEQUENCES OF THE OCCURRENCE

The HPCS (BG) pump normally takes a suction from the cycled condensate storage tank (KA) but will transfer its suction path to the Suppression Pool if either 1) a low water level (5' 1") exists in the condensate storage tank, or 2) a high water level (26' 9 1/4") exists in the Suppression Pool. Since the system performed its design function, the consequences of this event were minimal.

IV. CORRECTIVE ACTION

The Suppression Pool water level was lowered to normal level and the normal HPCS pump suction to the cycled condensate storage tank was restored. Suppression Pool water level is being periodically monitored locally and recorded in a special log to track pool level. This will allow the Suppression Pool level to be lowered before suction valve transfer takes place. A Work Request has been written to repair the Narrow Range Suppression Pool Level Indicator.

V. PREVIOUS OCCURRENCES

Similar occurrences are documented in LER's 374/84-078, 84-087, 85-001, 373/84-081, 84-087, 84-90, 85-002.

VI. NAME AND TELEPHONE NUMBER OF PREPARER

Harold T. Vinyard, 815/357-6761, extension 323.



Commonwealth Edison
LaSalle County Nuclear Station
Rural Route #1, Box 220
Marseilles, Illinois 61341
Telephone 815/357-6761

February 13, 1985

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Dear Sir:

Reportable Occurrence Report #85-006-00, Docket #050-374 is being submitted to your office in accordance with 10CFR 50.73.

for R.D. Budy
G. J. Diederich
Superintendent
LaSalle County Station

GJD/MLD/kg

Enclosure

xc: NRC, Regional Director
INPO-Records Center
File/NRC

IE22
11