

NOTICE OF VIOLATION

Commonwealth Edison Company
LaSalle County Station
Unit 2

Dockets No. 50-373; 50-374
Licenses No. NPF-11, NPF-18

During an NRC inspection conducted on January 13 through February 28, 1996, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," NUREG-1600, the violation is listed below:

10 CFR 20.1501 requires that each licensee make or cause to be made surveys that may be necessary for the licensee to comply with the regulations in Part 20 and that are reasonable under the circumstances to evaluate the extent of radiation levels, concentrations or quantities of radioactive materials, and the potential radiological hazards that could be present.

Pursuant to 10 CFR 20.1003, *survey* means an evaluation of the radiological conditions and potential hazards incident to the production, use, transfer, release, disposal, or presence of radioactive material or other sources of radiation.

Contrary to the above, as of February 14, 1996, the licensee did not make adequate surveys to assure compliance with 10 CFR 20.1201(a)(1)(i), which limits the annual occupational total effective dose equivalent to individual adults to 5 rems. Specifically, on February 14, 1996, ComEd's survey of a valve stem prior to its transfer was not adequate to evaluate the radiological hazards present in that the radiation levels were documented as 0.03 rem per hour on the stem when the levels were actually 0.3 rem per hour.

This is a Severity Level IV violation (Supplement IV).

The NRC has concluded that information regarding the reason for the violation, the corrective actions taken and planned to correct the violation and prevent recurrence and the date when full compliance was achieved is already adequately addressed on the docket in (the attached) Inspection Report 373/374-96002. However, you are required to submit a written statement or explanation pursuant to 10 CFR 2.201 if the description therein does not accurately reflect your corrective actions or your position. In that case, or if you choose to respond, clearly mark your response as a "Reply to a Notice of Violation," and send it to the U. S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D. C. 20555 with a copy to the Regional Administrator, Region III, and a copy to the NRC Resident Inspector at the facility that is the subject of this Notice, within 30 days of the date of the letter transmitting this Notice of Violation (Notice).

Because your response will be placed in the NRC Public Document Room (PDR), to the extent possible, it should not include any personal privacy, proprietary, or safeguards information so that it can be placed in the PDR without redaction. However, if you find it necessary to include such information,

Notice of Violation

-2-

you should clearly indicate the specific information that you desire not to be placed in the PDR, and provide the legal basis to support your request for withholding the information from the public.

Dated at Lisle, Illinois
this 9 day of March 1996 .