

OCT 25 1984

Docket No. 50-317
50-318

CAL 84-19

Baltimore Gas and Electric Company
ATTN: Mr. A. E. Lundvall, Jr.
Vice President, Supply
P. O. Box 1475
Baltimore, Maryland 21203

Gentlemen:

Subject: Confirmatory Action Letter 50-317/84-19 and 50-318/84-19

This refers to the telephone conversation between Mr. L. Russel, and others of your staff, and Mr. J. P. Durr, of my staff, on October 18, 1984, dealing with the failure to comply with the action items of Inspection and Enforcement Bulletin 79-14. The Bulletin requested that all Category I piping systems have verification inspections of supports performed to assure as-built drawing accuracy which were the seismic design analyses inputs. It has come to our attention as a result of our inspection 50-317/84-26 and 50-318/84-26, that the reactor coolant system and the pressurizer surge line were not inspected as requested. Based on the foregoing telephone conversation, we understand you will take the following actions:

1. The reactor coolant system and the pressurizer surge line will be inspected in accordance with IE Bulletin 79-14 criteria not later than the next scheduled refueling outage for Unit Nos. 1 and 2.
2. If either unit achieves cold shutdown, the IE Bulletin 79-14 inspections will be completed.
3. If either unit achieves hot shutdown for a period of 72 hours or greater, the IE Bulletin 79-14 inspections will be completed.

If our understanding of your planned actions as described above is not in accordance with the actual plans and actions being implemented, please contact this office immediately.

The responses directed by this letter are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980 PL 95-511.

Sincerely,

Original Signed By:
Thomas T. Martin

Thomas T. Martin, Director
Division of Engineering and
Technical Programs

8411120303 841025
PDR ADOCK 05000317
Q PDR


IE 310
1/0

cc w/encl:


R. M. Douglass, Manager, Quality Assurance
L. B. Russell, Plant Superintendent
S. M. Davis, General Supervisor, Operations QA
Thomas Magette, Administrator, Nuclear Evaluations
R. C. L. Olson, Principal Engineer
J. A. Tiernan, Manager, Nuclear Power
R. E. Denton, General Supervisor, Training and Technical Services
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
State of Maryland (2)

bcc w/encl:


Region I Docket Room (with concurrences)
Senior Operations Officer (w/o encls)
T. Elsasser, DPRP Section Chief, #3C


RI:DETP
Durr

10/19/84



RI:DETP
Ebnetter

10/19/84



RI:DPRP
Elsasser

10/22/84

OFFICIAL RECORD COPY


RI:DPRP
Wenzinger

10/22/84


RI:DETP
Martin (T)

10/24/84