

October 16, 1984

MEMORANDUM FOR: James R. Miller, Chief
ORB-3, NRR

FROM: Eric H. Johnson, Chief
RPB-1, RIV

SUBJECT: REQUEST FOR PUBLICATION IN MONTHLY FR NOTICE - NOTICE
OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE

Public Service Company of Colorado, Docket No. 50-267, Fort St. Vrain

Nuclear Generating Station, Platteville, Colorado

Date of application for amendment: May 10, 1984

Brief description of amendment: Modification of the sampling and analysis requirements for secondary coolant radioactivity described in the Technical Specifications. Daily sampling is now required when the activity increases to 10% of the limit instead of the 25% value previously imposed while daily sampling is no longer required if the activity increases by 25% over an equilibrium value.

Date of issuance: October 26, 1984

Effective date: October 26, 1984

Amendment No.: 44

Facility Operating License No. DPR-34. Amendment revised the Technical Specifications.

Date of initial notice in Federal Register : June 12, 1984; 49 FR 25372

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated October 26, 1984.

No significant hazards consideration comments received: No.

A005
1/0

Local Public Document Room Location: Greeley Public Library, City Complex
Building, Greeley, Colorado

Original Signed By
E. H. Johnson

Eric H. Johnson, Chief
Reactor Project Branch 1

cc: P. C. Wagner
E. M. Haycraft
T. G. Colburn
G. C. Lainas
P. Kreutzer

EMH
DRS&P
EMHaycraft
10/16/84

PCW
RPB-1:PM
PCWagner
10/22/84

PCWagner for
RPB-1:SC
REIreland
10/27/84

EHJ
RPB-1:BC
EHJohnson
10/23/84

WLB
RIVAtt
WLBrown
10/25/84

DRS&P
D/DRS&P
10/28/84