



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DUQUESNE LIGHT COMPANY

OHIO EDISON COMPANY

PENNSYLVANIA POWER COMPANY

DOCKET NO. 50-334

BEAVER VALLEY POWER STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 80
License No. DPR-66

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Duquesne Light Company, Ohio Edison Company, and Pennsylvania Power Company (the licensees) dated May 21, 1984, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-66 is hereby amended to read as follows:


8502280226 850125
PDR FOIA PDR
GRABER85-9

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 80, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This amendment is effective on issuance, to be implemented no more than 30 days after issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: October 9, 1984

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 80 TO FACILITY OPERATING LICENSE NO. DPR-66

DOCKET NO. 50-334

Revise Appendix A as follows:

Remove Pages

3/4 3-56

3/4 4-4

3/4 4-11

3/4 4-12

3/4 7-14

5-1b

Insert Pages

3/4 3-56

3/4 4-4

3/4 4-11

3/4 4-12

3/4 7-14

5-1b

TABLE 3.3-12 (Continued)

TABLE NOTATION

- ACTION 23 - With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases may be resumed provided that prior to initiating a release:
1. At least two independent samples are analyzed in accordance with specification 4.11.1.1.1, and;
 2. At least two technically qualified members of the Facility Staff independently verify the release rate calculations and discharge valving;
- Otherwise, suspend release of radioactive effluents via this pathway.
- ACTION 24 - With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continue provided that at least once per 8 hours grab samples are analyzed for gross radioactivity (beta or gamma) at a Lower Limit of Detection (LLD) of at least 10^{-7} μ Ci/ml.
- ACTION 25 - With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continue provided the flow rate is estimated at least once per 4 hours during actual releases. Pump curves may be used to estimate flow.
- ACTION 26 - With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, liquid additions to this tank may continue provided the tank liquid level is estimated during all liquid additions to the tank.

REACTOR COOLANT SYSTEM

ISOLATED LOOP STARTUP

LIMITING CONDITION FOR OPERATION

3.4.1.5 A reactor coolant loop shall remain isolated until:

- a. The isolated loop has been operating on a recirculation flow of ≥ 125 gpm for at least 90 minutes and the temperature at the cold leg of the isolated loop is within 20°F of the highest cold leg temperature of the operating loops.
- b. The reactor is subcritical by at least 1 percent $\Delta k/k$.

APPLICABILITY: ALL NODES.*

ACTION:

With the requirements of the above specification not satisfied, suspend startup of the isolated loop.

SURVEILLANCE REQUIREMENTS

4.4.1.5.1 The isolated loop cold leg temperature shall be determined to be within 20°F of the highest cold leg temperature of the operating loops within 30 minutes prior to opening the cold leg stop valve.

4.4.1.5.2 The reactor shall be determined to be subcritical by at least 1 percent $\Delta k/k$ within 30 minutes prior to opening the cold leg stop valve.

* With fuel in the vessel.

REACTOR COOLANT SYSTEM

3/4.4.6 REACTOR COOLANT SYSTEM LEAKAGE

LEAKAGE DETECTION SYSTEMS

LIMITING CONDITION FOR OPERATION

3.4.6.1 The following Reactor Coolant System leakage detection systems shall be OPERABLE:

- a. The containment atmosphere particulate radioactivity monitoring system,
- b. The containment sump discharge flow measurement system or narrow range level instrument, and
- c. Containment atmosphere gaseous radioactivity monitoring system.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

- a. With one of the above required radioactivity monitoring leakage detection systems inoperable, operations may continue for up to 30 days provided:
 1. The other two above required leakage detection systems are OPERABLE, and
 2. Appropriate grab samples are obtained and analyzed at least once per 24 hours:

otherwise, be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With the containment sump discharge flow measurement system and narrow range level instrument inoperable, restore at least one inoperable system to OPERABLE status within 7 days or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- c. The provisions of specification 3.0.4 are not applicable in Modes 1, 2 and 3.

SURVEILLANCE REQUIREMENTS

4.4.6.1 The leakage detection systems shall be demonstrated OPERABLE by:

- a. Containment atmosphere particulate and gaseous monitoring system-performance of CHANNEL CHECK, CHANNEL CALIBRATION and CHANNEL FUNCTIONAL TEST at the frequencies specified in Table 4.3-3,

REACTOR COOLANT SYSTEM

SURVEILLANCE REQUIREMENTS (Continued)

- b. Containment sump discharge flow measurement system-performance of CHANNEL CALIBRATION TEST at least once per 18 months.
- c. Logging the narrow range level indication every 12 hours. |

PLANT SYSTEMS

3/4.7.5 ULTIMATE HEAT SINK - OHIO RIVER

LIMITING CONDITION FOR OPERATION

- 3.7.5.1 The ultimate heat sink shall be OPERABLE with:
- a. A minimum water level at or above elevation 654 Mean Sea Level, at the intake structure, and
 - b. An average water temperature of $\leq 86^{\circ}\text{F}$.

APPLICABILITY: MODES 1, 2, 3 and 4.


ACTION:

With the requirements of the above specification not satisfied, be in at least HOT STANDBY within 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.7.5.1 The ultimate heat sink shall be determined OPERABLE at least once per 24 hours by verifying the average water temperature and water level to be within their limits.

SITE BOUNDARY FOR GASEOUS EFFLUENTS FOR THE BEAVER VALLEY POWER STATION



BEAVER VALLEY - UNIT 1

FIGURE 5.1-1

5-1b

Amendment No. 80