

Appendix

NOTICE OF VIOLATION

Commonwealth Edison Company
Quad Cities Station

License No. 50-265

As a result of the inspection conducted on September 24 through September 28, 1984, and in accordance with the General Policy and Procedures for NRC Enforcement Actions (10 CFR Part 2, Appendix C), the following violation was identified:

10 CFR 20.203(c)(2) states: "Each entrance or access point to a high radiation area shall be:

"Equipped with a control device which shall cause the level of radiation to be reduced below that at which an individual might receive a dose of 100 millirems in 1 hour upon entry into the area; or

"Equipped with a control device which shall energize a conspicuous visible or audible alarm signal in such a manner that the individual entering the high radiation area and the licensee or a supervisor of the activity are made aware of the entry; or maintained locked except during periods when access to the area is required, with positive control over each individual entry."


Contrary to the above, on September 25, 1984, the R-gate to the northeast residual heat removal area was unlocked, without control devices, alarms, or positive access control.

This is a Severity Level IV violation (Supplement IV).

The inspection showed that action had been taken to correct the identified item of noncompliance and to prevent recurrence. Consequently, no reply to this item of noncompliance is required and we have no further questions regarding this matter.

Date

10-16-84



W.D. Shafer, Chief
Projects Branch 2

8411130375 841016
PDR ADOCK 05000254
PDR
Q