



THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

P.O. BOX 5000 - CLEVELAND, OHIO 44101 - TELEPHONE (216) 622-9800 - ILLUMINATING BLDG. - 55 PUBLIC SQUARE

Serving The Best Location in the Nation

October 23, 1984

MURRAY R. EDELMAN
VICE PRESIDENT
NUCLEAR

PRINCIPAL STAFF	
MA	✓
D/RA	✓
RC	
PAO	
SGA	
EIC	
DRNA	

orig¹

Mr. James G. Keppler
Regional Administrator, Region III
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

RE: Perry Nuclear Power Plant
Docket Nos. 50-440; 50-441
Deficiency in Nine 480 Volt
AC Circuit Breakers Supplied
by Brown Boveri Electric
[RDC 108(84)]

Dear Mr. Keppler:

In our final report, dated September 7, 1984, concerning Brown Boveri Electric 480 Volt AC Circuit Breakers, we stated that corrective action would include procurement of the necessary solid state trip devices and that installation would be completed by October 30, 1984.

The procurement documents for the purchase of the solid state trip devices were prepared, approved and released to Brown Boveri Electric August 31, 1984.

Brown Boveri Electric is currently assembling the order. It is now anticipated that all actions required for resolution of this problem will be completed by January 25, 1985.

Please call if there are any additional questions.

Sincerely,

Murray R. Edelman
Murray R. Edelman

8411130395 841023
PDR ADOCK 05000440
S PDR

MRE:pab

cc: Mr. J. A. Grobe
USNRC, Site Office

Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission
c/o Document Management Branch
Washington, D.C. 20555

Records Center, SEE-IN
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339

OCT 26 1984
1/0 IF27