

Florida Power

CORPORATION

Crystal River Unit 3
Docket No. 50-302

April 23, 1996
3F0496-27

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Subject: Engineering Evaluation of Performance Test PT-630

Reference: NRC/FPC Meeting Notes dated February 15, 1996.

Dear Sir:

As agreed upon at a meeting between Florida Power Corporation (FPC) and NRC staff on February 8, 1996 and documented in the reference meeting notes, FPC has completed a performance test to confirm the design adequacy of Operating Procedure OP-103B, Curve 8, 'Max. MUT Operating Pressure vs. Level'. Enclosed is an FPC Interoffice Correspondence dated April 22, 1996, which documents the evaluation of the test data against the curve. It also includes an independent evaluation of the test data by MPR Associates. Both evaluations conclude that the pressure loss coefficients used in Calculation M94-0053 are conservative and the curve is sufficiently accurate and conservative to protect the HPI pumps against ingestion of hydrogen during emergency operation.

To assist the NRC in their review, two points of clarification of the information are offered below regarding the information at the top of page 1 of Table 2:

1. Table 2 refers to flow rates from Table 1. Reactor Building Spray (BS) pump flow is not found in Table 1 since no computer data was available for this flow rate. BS flow was set to 1500 GPM with the installed flow controller.
2. Table 2 refers to '14" flow'. This value represents total flow in the BWST suction line to the three pumps which draw suction from that tank. It is the summation of 'LPI flow', 'BS flow', and '6" flow' (not 'HPI flow'). The

CRYSTAL RIVER ENERGY COMPLEX • 15760 W. Power Line Street • Crystal River • Florida 34428-6708 • (352) 795-6486
A Florida Progress Company

9604290208 960423
PDR ADOCK 05000302
P PDR

Aad
1/1

U. S. Nuclear Regulatory Commission

3F0496-27

Page 2 of 2

difference between '6" flow' and 'HPI flow' is the amount of flow through the HPI pumps which is being drawn from the makeup tank (MUT). '6" flow' was calculated by converting BWST level change into flow rate since the LPI and BS pumps were recirculating flow back to the BWST. This was the most accurate way to distinguish between HPI flow from the BWST and the MUT and quantify the HPI portion of total flow in the 14-inch diameter BWST suction line.

Please contact FPC if additional information is required.

Sincerely,




L. C. Kelley, Director
Nuclear Operations Site Support

LCK/BG:ff

Enclosure

xc: Regional Administrator, Region II
 Senior Resident Inspector
 NRR Project Manager



Florida
Power
CORPORATION

INTEROFFICE CORRESPONDENCE

Nuclear Engineering Design
OFFICE

NA2J
MAC

240-3606
TELEPHONE

SUBJECT: Crystal River Unit 3
PT-630/M94-0053 Rev. 3 Comparison
File: M94-0053, IOC NED96-0234

Attention: This document supercedes document IOC NED96-0234

TO: G. H. Halnon


DATE: April 22, 1996
NED96-0259

Please find attached Verified and Approved Comparison of Pt-630 Data and M94-0053 Rev. 3 Head Loss Predictions. This comparison documents FPC's determination that the factors used in M94-0053 Rev. 3 for Head Loss calculations are conservative when compared to Measured Values obtained in performance of PT-630. In addition, the same type of comparison with similar results performed by MPR is also included as an attachment to the FPC comparison.

The FPC and MPR comparisons have minor differences in; 1) the flows used to calculate head losses and 2) the Plant evaluation of the test gage on MUV-287. These differences are discussed below and have insignificant impact on the validation determination, (0.3ft less than FPC's at the same flows).

- 1) MPR used summation of REDAS HPI flows while FPC used the level change in BWST to determine flows because some of the HPI flow was from the MUT during the PT. In addition, MPR used the same K factors for all flow rates while FPC adjusted the 6" piping K factor because of the velocity changes through the splitting tee.
- 2) MPR used a test gauge differential from the tie-ins of 3.25ft and a tie-in elevation of 104.50ft EL while FPC used 3ft and 104.75 respectively.

In addition to the above comparison, there is attached a data sheet taken during PT-630 and sketch showing relative piping elevations and test gages for PT-630. If there are any questions or comments please let me know.



P.R. Tanguay, Director

Nuclear Engineering & Projects

cc: R.E. Clauson
D.A. Shook
J. R. Maseda
Records Management

28.3ft, 147.97ft EL, W/□ error
BWST
13ft, 132.67ft EL, W/□ error
7.8ft, 127.47ft EL, W/□ error
5ft, 124.67ft EL, W/□ error

IND.

30.3ft

106.75 ft EL
2ft MARGIN



15ft

9.8ft

7ft

119 ft EL

0in Ind.
122.36ft EL
W/Error



"A" TRAIN
ECCS

"B" TRAIN
ECCS

DATA TABLE Time: 0005 0009 0012 0017 0026

	Initial	DHP Recirc	DHP/BSP Recirc	MUP DHP/BSP Recirc	HPI 200 GPM	HPI 300 GPM	HPI 400 GPM	HPI 500 GPM	HPI 540 GPM
ACTUAL HPI FLOW					200	300	400	500	537
DHP-1B Suct DH-4-PI2	26	25	24	24	24	24	23.5	23.5	23.5
DHP-1B Disch DH-5-PI2		180	170	167.5	167.5	165	165	165	165
BSP-1B Suct BS-9-PI2	42	41	25 243 3076	25	25	25	25	25	25
BSP-1B DISCH BS-2-PI2			215	215	215	215	215	215	215
MUP-1B SUCT MU-9-PI2	30	30	30	28.5	20	16.5	15.5	14.5	14
MUP-1B DISCH MU-22-PI2				2975	2800	2550	2200	1625	1350
MUV-287 TEST GAUGE	28	28	28	27	15.2	14.8	14.1	13.3	12.9
BWST VAPOR TEST GAUGE	.2" H ₂ O	.2" H ₂ O	.2" H ₂ O	.2" H ₂ O	.2" H ₂ O	.2" H ₂ O	.2" H ₂ O	.2" H ₂ O	.2" H ₂ O

COMPARISON OF M94-0053 Rev. 3 TO PT-630 DATA

File: M94-0053 Rev. 3

ATTACHMENTS:

TABLE #1

REDAS DATA FROM PT-630 COLUMNS A THROUGH K
LOCAL DATA TAKEN DURING PT-630 COLUMNS N, T, U, & V
ALL OTHER COLUMNS ARE CALCULATIONS OF ABOVE DATA

TABLE #2

THIS TABLE TAKES PT-630 FLOW RATES AND USING M94-0053
Rev. 3 METHODOLOGY AND K FACTORS CALCULATES A RESULTING
HEAD LOSS FOR THE FLOW FROM THE BWST. IN ADDITION, THE
RESULTS OF THE MPR REVIEW IS PRESENTED AND A COMPARISON
OF MPR K FACTORS USING SPECIFIC PT-630 FLOWS.

CHART #1

PLOT OF MUT AND BWST LEVELS WITH TIME DURING PT-630.
BWST Level is given in inches less 270" in order to plot
on the same chart.

CHART #2

PLOT OF HPI FLOW FROM BWST AND MUT WITH TIME DURING PT-
630.

CHART #3

PLOT OF REDAS PRESSURE AND LEVEL FOR THE MUT DURING PT-
630 AND THE COMPUTER ALARM CURVE OF OP-103B.

MPR TELECOPY

MPR's evaluation of PT-630 data to their independent
calculation of BWST to Tie-In head loss.

CONCLUSION:


Table #2 page 2 shows that the calculated head losses using M94-0053 Rev. 3 methodology to be 2.8 to 4.9 ft higher than that measured during PT-630. In addition, Table #1 Column 0 shows the additional head loss of the check valve in the 4" line from the MUT to be 0.51ft to 0.77ft which was not included in the M94-0053 Calculation and provides additional margin/conservatism. The flow rates calculated from level changes in Table #1 were used in the Table #2 account for a portion of the HPI flow coming from the MUT during the lower flow rates of the PT.

The data plots are responses expected under the PT conditions and show how the MUT initially supplies the MUP flow until level reduction and resulting pressure decrease cause the BWST to become the major source of water for the MUP.

Based on the Conservatism of the Calculated Head Losses (MPR and FPC) compared with Actual measured values of PT-630 the results of M94-0053 Rev. 3 is an acceptable basis for determination of the Allowable MUT Overpressures.


R.E. Clauson
Design Engineer

02-R-Ledzian 4/10/96
Verification Engineer
K.R. Ledzian


J.W. Austin
Engineering Supervisor
T.V. AUSTIN

PT-630 RESULTS

TABLE #2

PT-630 Flow Rates taken from Table #1				
LPI flow	3077	3105	3096	3086
BSP flow	1500	1500	1500	1500
HPI flow	298	413	478	530
6" flow	268	392	462	526
14" flow	4845	4997	5058	5112
BWST Water temperature of 88F used in head loss calc.				
density	62.14			
viscosity	0.78			
psi to ft conversion	2.3175			
(f) FACTORS FOR 14 in PIPING FROM BWST TO HPI TEE				
Re 14" @4845 gpm	= 50.6 * 4845 * 62.14 / 13.25 / 0.78	1.47E+06		
f =	0.0135			
Re 14" @4997 gpm	= 50.6 * 4997 * 62.14 / 13.25 / 0.78	1.52E+06		
f =	0.0134			
Re 14" @5058 gpm	= 50.6 * 5058 * 62.14 / 13.25 / 0.78	1.54E+06		
f =	0.0134			
Re 14" @5112 gpm	= 50.6 * 5112 * 62.14 / 13.25 / 0.78	1.56E+06		
f =	0.0134			
(f) FACTORS FOR 6 in PIPING FROM BWST TO HPI TEE				
Re 6" @268gpm	= 50.6 * 268 * 62.14 / 6.065 / 0.78	1.78E+05		
f =	0.018			
Re 6" @392 gpm	= 50.6 * 392 * 62.14 / 6.065 / 0.78	2.61E+05		
f =	0.0172			
Re 6" @462 gpm	= 50.6 * 462 * 62.14 / 6.065 / 0.78	3.07E+05		
f =	0.0169			
Re 6" @526 gpm	= 50.6 * 526 * 62.14 / 6.065 / 0.78	3.50E+05		
f =	0.0167			
(K) FACTORS FOR FLOW SPLITTING TEE				
(Values from Miller Paper, Attachment 12 to M94-0053 Rev. 3)				
14" Flow rate (gpm)	4845	4997	5058	5112
6" Flow rate (gpm)	268	392	462	526
A1/A3 = 28.89/137.88 =	0.20953	0.20953	0.20953	0.20953
Q1/ Q4	0.06	0.08	0.09	0.10
K 32	1.040	1.100	1.110	1.14


PT-630 RESULTS
TABLE #2

CALCULATION OF "B" TRAIN HEAD LOSSES FOR PT-630 FLOWS						
14" flow rate (gpm)			4845	4997	5058	5112
Friction factor			0.0135	0.0134	0.0134	0.0134
Component	QTY	K Eq				
Entrance Loss	1	0.5	0.500	0.500	0.500	0.500
14" Pipe	30.55	f X L/D	0.374	0.371	0.371	0.371
Elbow 90	1	14f	0.189	0.188	0.188	0.188
Elbow 45	2	7f	0.189	0.188	0.188	0.188
Tee Run	1	20f	0.270	0.268	0.268	0.268
Reducer "T" w/Flow Split		Miller	1.040	1.100	1.110	1.140
Reducer "T" Run		20f	0.000	0.000	0.000	0.000
	Total K's		2.562	2.614	2.624	2.654
Hd Loss = 0.00259 x k x flow^2 / Pipe ID^4			5.053	5.485	5.641	5.828
6" Flow Rate (gpm)			268	392	462	526
Friction factor			0.018	0.0172	0.0169	0.0167
Reducer 6" Tee Branch	0	60f	0	0	0	0
14" x 6" Reducer	0	.5 x (1-B)	0	0	0	0
6" Pipe	166	f X L/D	5.912	5.649	5.551	5.485
Elbow 90	12	14f	3.024	2.890	2.839	2.806
1/2 Tee Run	1	20f	0.180	0.172	0.169	0.167
Tee Run Flow Split		Miller	0.000	0.000	0.000	0.000
Elbow 45	3	7f	0.378	0.361	0.355	0.351
Gate Valve MUV-58	1	8f	0.144	0.138	0.135	0.134
CK Valve MUV-60	1	50f	0.900	0.860	0.845	0.835
Tee Branch	1	60f	1.080	1.032	1.014	1.002
	Total K's		11.618	11.102	10.908	10.779
Hd Loss = 0.00259 x k x flow^2 / Pipe ID^4			1.597	3.265	4.457	5.708
6" Flow Rate (gpm)			268	392	462	526
Friction factor			0.018	0.0172	0.0169	0.0167
6" Pipe	12.6	f X L/D	0.449	0.429	0.421	0.416
Gate Valve MUV-62	1	8f	0.144	0.138	0.135	0.134
Gate Valve MUV-63	1	8f	0.144	0.138	0.135	0.134
1/2 Tee Run	2x1/2	20f	0.360	0.344	0.338	0.334
1/2 'Tee Run	1	20f	0.000	0.000	0.000	0.000
Velocity Head Loss		1	1.000	1.000	1.000	1.000
	Total K's		2.097	2.048	2.030	2.018
Hd Loss = 0.00259 x k x flow^2 / Pipe ID^4			0.288	0.602	0.829	1.068
	Total Calculated Head Loss		6.938	9.352	10.927	12.605
PT-630 Total Measured Head Loss TABLE 1			4.1	5.6	7.23	7.66
	Delta		2.838	3.752	3.697	4.945


PT-630 RESULTS
TABLE #2

CALCULATION OF HEAD LOSSES USING MPR'S K FACTORS							
MPR Flow 14"	5075	BWST L	145.79	Measured (psig)	12.9		
14" Velocity	11.80779	TIE-IN	-104.5	Corrected (psig)	14.30		
MPR Flow 6"	493	DELT H	41.29				
6" Velocity	5.475259	HL	11.41188				
MPR Calc. Head Loss	11.41188	Press (ft)	29.88	DELTA (psig)	1.41		
		Press (psig)	12.89	DELTA (ft)	3.27		
COMPARISON OF MPR K FACTORS WITH FPC FLOWS							
14" F	4845	4997	5058	5112			
14" V	11.27266	11.62632	11.76824	11.89388			
6" F	268	392	462	526			
6" V	2.976409	4.353553	5.130973	5.841757			
HL	6.86588	9.128017	10.67482	12.28901			
FPC CALCULATED	6.938	9.352	10.927	12.605			


PT-630 RESULTS
CHART #1



PT-630 RESULTS
CHART #2



PT-630 RESULTS
CHART #3





32
YEARS OF
EXCELLENCE
1964-1996

Date: April 22, 1996

To: Paul Tanguay From: Dwight H. Harrison 

Company: Florida Power Company

Fax Number: 352-563-4697 Verification: 352-563-4481

Subject: CR3 Evaluation of Test Data Related to Max Allowable Makeup Tank

Pages: 12 including this cover sheet

Message:



April 22, 1996

Mr. Paul Tanguay
Director, Nuclear Engineering and Projects
Florida Power Corporation
Crystal River Energy Complex
15760 West Power Line St.
Crystal River, Florida 34428-6708

Subject: Crystal River Unit 3 — Evaluation of Test Data Related to Maximum Allowable Makeup Tank Pressure

- References:
- (a) MPR Calculation 102075RCS01, Rev. 0, Comparison of Calculated and Measured Pressures at Junction of Makeup Tank Surge Line and Pump Suction Pipe
 - (b) MPR letter from R. C. Sanders to Mr. Paul Tanguay, Florida Power Company dated April 8, 1996

Dear Mr. Tanguay:

This letter forwards a revised version (Rev. 1) of the calculation, Reference (a), that was forwarded to you by Reference (b). The calculation has been revised to reflect a vacuum of 0.2 inch of water in the borated water storage tank (BWST), rather than a positive pressure of 0.2 inch of water. The information clarifying the test data was provided to MPR (Harrison) by FPC (Clauson) in a telephone conversation on April 22, 1996.

As would be expected, this change is very minor and does not affect the conclusions of our letter and the original calculations, References (a) and (b). That is, evaluation of the data confirms that the pressure loss coefficients used in the calculational technique are conservatively high.

If you have questions on the enclosed calculation or this letter, please do not hesitate to contact us.

Sincerely,

A handwritten signature in black ink, appearing to read "Dwight H. Harrison".

Dwight H. Harrison

Enclosure: MPR Calculation 102075RCS01, Rev. 1

cc: Mr. R. Clauson, Florida Power, w/encls