

WISCONSIN ELECTRIC

POWER COMPANY

POINT BEACH NUCLEAR PLANT

UNIT NOS. 1 AND 2

ANNUAL
MONITORING REPORT

JANUARY 1995 through DECEMBER 1995

U.S. Nuclear Regulatory Commission
Docket Nos. 50-266 and 50-301
Facility Operating License Nos.
DPR-24 and DPR-27

9604290375 960422
PDR ADOCK 05000266
R PDR

ANNUAL MONITORING REPORT

January 1, 1995 to December 31, 1995

PREFACE

This Annual Monitoring Report for the period of January 1, 1995, through December 31, 1995, is submitted in accordance with Point Beach Nuclear Plant Unit Nos. 1 and 2 Technical Specification 15.7.8.4 and filed under Docket Nos. 50-266 and 50-301 for Facility Operation License Nos. DPR-24 and DPR-27, respectively.

TABLE OF CONTENTS

1.0	Radioactive Liquid Releases	3
2.0	Radioactive Airborne Releases	7
3.0	Radioactive Solid Waste Shipments	11
4.0	New and Spent Fuel Shipments and Receipts	12
5.0	Nonradioactive Chemical Releases	13
6.0	Circulating Water System Operation	13
7.0	Leak Testing of Radioactive Sources	14
8.0	Miscellaneous Reporting Requirements	14
9.0	Radiological Environmental Monitoring	15

TABLE OF TABLES

Table 1-1	Summary Of Circulating Water Discharges	4
Table 1-2	Isotopic Composition Of Circulating Water Discharges	5
Table 1-3	Subsoil System Drains - Tritium Summary	6
Table 1-4	Sewage Sludge Land Application	7
Table 2-1	Radioactive Airborne Release Summary	9
Table 2-2	Isotopic Composition Of Airborne Releases	10
Table 3-1	Quantities And Types Of Waste Shipped From PBNP	11
Table 3-2	Estimated Solid Waste Major Radionuclide Composition	12
Table 6-1	Circulating Water System Operation For 1995	13
Table 9-1	PBNP Radiological Environmental Sample Collection Frequency	17
Table 9-2	Radiological Environmental Sampling Locations	18
Table 9-3	PBNP Radiological Environmental Sample Analysis And Frequency	21
Table 9-4	Radiological Environmental Monitoring Results	24

TABLE OF FIGURES

Figure 9-1	Point Beach Nuclear Plant Radiological Environmental Monitoring Program Sites	19
Figure 9-2	Site Map for Point Beach Nuclear Plant	20

1.0 RADIOACTIVE LIQUID RELEASES

The total radioactive liquid release, excluding tritium for this reporting period, was 1.51E-01 curies. This included 3.11E-02 curies in processed radioactive waste, 7.40E-02 curies in Unit 1 steam generator blowdown, 4.46E-02 curies in Unit 2 steam generator blowdown and 1.74E-03 curies in retention pond effluent.

The total tritium release for this reporting period was 5.29E+02 curies. This included 5.25E+02 curies in processed radioactive waste, 4.83E-02 curies in Unit 1 steam generator blowdown, 3.09E+00 curies in Unit 2 steam generator blowdown and 1.31E+00 curies in retention pond effluent.

1.1 Circulating Water Radionuclide Release Summary

1.1.1 Releases During Current Reporting Period

Radioactive liquid releases via the circulating water discharge are summarized by individual source and total curies released on a monthly basis and presented in Table 1-1. Table 1-1 also contains the comparison between the annual Appendix I dose limits for liquid effluent and the corresponding highest doses calculated according to the ODCM using the annual isotopic composition of the liquid discharge.

1.1.2 Additions to Previous Semiannual Monitoring Report

The following information was not available at the time of the previous report preparation and should be added to Table 1-1 of the Semiannual Monitoring Report for July 1, 1994, through December 31, 1994.

	December	6-Month Total
Total Activity Released [Ci]		
Gross Alpha	2.10E-07	1.54E-06
Strontium	2.94E-07	1.36E-05
Average Diluted Discharge Concentration [uCi/cc]		
Gross Alpha	6.35E-15	
Strontium	8.89E-15	

Table 1-1

SUMMARY OF CIRCULATING WATER DISCHARGES
JANUARY 1, 1995 THROUGH DECEMBER 31, 1995

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Total Activity Released [Ci]													
Gamma Scan plus Fe-55	7.70E-02	5.96E-03	5.53E-03	5.99E-03	5.64E-03	5.93E-03	3.48E-03	2.67E-03	8.24E-03	2.03E-02	2.99E-03	6.40E-03	1.50E-01
Gross Alpha	0.00E+00	0.00E+00	3.52E-07	2.37E-07	0.00E+00	1.00E-07	7.03E-08	0.00E+00	7.09E-05	6.25E-05	8.22E-07	0.00E+00	1.35E-04
Tritium	7.16E+01	2.89E+01	5.75E+01	5.04E+01	3.40E+01	1.58E+01	4.54E+01	7.19E+01	2.42E+01	6.96E+01	1.60E+01	4.43E+01	5.30E+02
Strontium	0.00E+00	0.00E+00	1.05E-05	5.60E-05	0.00E+00	5.02E-07	8.43E-07	4.56E-07	3.15E-05	9.46E-04	1.44E-06	4.58E-07	1.05E-03
Total Volume Released [gal]													
Processed Waste	1.71E+05	1.05E+05	1.55E+05	2.09E+05	5.26E+04	2.65E+04	6.19E+04	7.08E+04	3.68E+04	1.81E+05	7.85E+04	1.10E+05	1.26E+06
U1 Steam Generator Blowdown	2.66E+06	2.42E+06	9.81E+05	2.52E+06	3.69E+06	2.88E+06	3.39E+06	2.92E+06	2.16E+06	2.23E+06	2.16E+06	2.17E+06	3.02E+07
U2 Steam Generator Blowdown	2.67E+06	2.41E+06	3.46E+06	3.08E+06	2.68E+06	2.59E+06	2.60E+06	2.51E+06	2.14E+06	5.20E+05	0.00E+00	3.84E+06	2.85E+07
Retention Pond	3.12E+06	2.61E+06	5.23E+06	5.86E+06	6.00E+06	5.04E+06	6.13E+06	7.57E+06	5.05E+06	5.90E+06	3.24E+06	2.98E+06	5.87E+07
Total	8.62E+06	7.55E+06	9.83E+06	1.17E+07	1.24E+07	1.05E+07	1.22E+07	1.31E+07	9.39E+06	8.83E+06	5.48E+06	9.10E+06	1.19E+08
Volume of Dilution Water [cc]													
	3.31E+13	3.00E+13	4.04E+13	5.54E+13	5.75E+13	5.56E+13	5.76E+13	5.75E+13	5.56E+13	5.84E+13	4.17E+13	3.31E+13	5.76E+14
Average Diluted Discharge Concentration [uCi/cc]													
Gamma Scan plus Fe-55	2.30E-09	1.99E-10	1.37E-10	1.08E-10	9.81E-11	1.07E-10	6.04E-11	4.64E-11	1.48E-10	3.48E-10	7.17E-11	1.93E-10	2.61E-10
Gross Alpha	0.00E+00	0.00E+00	8.71E-15	4.28E-15	0.00E+00	1.80E-15	1.22E-15	0.00E+00	1.28E-12	1.07E-12	1.97E-14	0.00E+00	2.34E-13
Tritium	2.16E-06	9.63E-07	1.42E-06	9.10E-07	5.91E-07	2.84E-07	7.88E-07	1.25E-06	4.35E-07	1.19E-06	3.84E-07	1.34E-06	9.20E-07
Strontium	0.00E+00	0.00E+00	2.60E-13	1.01E-12	0.00E+00	1.01E-14	1.46E-14	7.93E-15	5.67E-13	1.62E-11	3.45E-14	1.38E-14	1.82E-12
Maximum Discharge Concentration [uCi/cc]													
Gross Gamma	1.23E-09	3.21E-10	3.05E-10	8.69E-10	3.29E-10	7.12E-10	4.69E-10	4.11E-10	1.08E-08	1.12E-08	2.36E-09	3.13E-10	
Tritium	4.29E-05	3.78E-05	4.42E-05	3.56E-05	4.88E-05	1.15E-05	3.87E-05	4.05E-05	3.41E-05	3.05E-05	4.14E-05	3.62E-05	

Note: Dissolved noble gasses detected in liquid effluents are included in airborne release totals

COMPARISON OF LIQUID EFFLUENT DOSES TO ANNUAL APPENDIX I DOSE OBJECTIVES

Annual Limit [mrem]	January-December Highest Total Calculated Dose [mrem]	% of 10 CFR 50, Appendix I, Dose Objective
6 (whole body)	4.19E-03 (infant)	7.0E-02
20 (any organ)	4.28E-03 (infant thyroid)	2.1E-02

Table 1-2
ISOTOPIC COMPOSITION OF CIRCULATING WATER DISCHARGES
JANUARY 1, 1995 THROUGH DECEMBER 31, 1995

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Isotope	[Ci]	[Ci]	[Ci]	[Ci]	[Ci]	[Ci]	[Ci]	[Ci]	[Ci]	[Ci]	[Ci]	[Ci]	[Ci]
H-3	7.16E+01	2.89E+01	5.75E+01	5.04E+01	3.40E+01	1.58E+01	4.54E+01	7.19E+01	2.42E+01	6.96E+01	1.60E+01	4.43E+01	5.30E+02
ALPHA			3.52E-07	2.37E-07		1.00E-07	7.03E-08		7.09E-05	6.25E-05	3.22E-07		1.35E-04
F-18	3.12E-03	4.12E-03	4.49E-03	4.41E-03	3.98E-03	4.01E-03	2.61E-03	1.75E-03	1.41E-03	8.06E-04	8.01E-05	4.87E-03	3.57E-02
NA-24	7.30E-02											1.99E-04	7.32E-02
CR-51				3.08E-05					1.74E-04				2.05E-04
MN-54									1.20E-05	1.41E-04	1.01E-05		1.63E-04
FE-55										1.00E-03	1.33E-03		2.33E-03
MN-56											5.12E-06	0.00E+00	5.12E-06
CO-57		8.32E-06							1.11E-05			1.31E-06	2.07E-05
CO-58			1.48E-04	1.02E-04	2.81E-05	1.05E-04	9.87E-05	8.06E-05	2.10E-04	1.68E-03	4.83E-04	1.87E-04	3.12E-03
CO-60	3.56E-05	4.89E-05	4.60E-05	2.44E-04	9.34E-05	5.90E-04	9.19E-05	1.45E-04	4.37E-04	1.21E-03	6.66E-04	3.27E-05	3.64E-03
SR-89													0.00E+00
SR-90			1.05E-05	5.60E-05		5.62E-07	8.43E-07	4.56E-07	3.15E-05	9.46E-04	1.44E-06	4.58E-07	1.05E-03
NB-95									1.59E-05				1.59E-05
ZR-97									7.28E-06				7.28E-06
RU-103						4.03E-06			8.11E-06				1.21E-05
AG-110M	3.14E-05	2.85E-05	7.89E-05	1.18E-04	3.91E-05	1.60E-04	6.36E-05	7.44E-05	2.72E-04	4.93E-04	3.49E-04	5.28E-05	1.76E-03
SB-124									4.43E-04	1.20E-03			1.64E-03
SB-125									4.81E-03	1.32E-02	2.18E-05		1.80E-02
TE-132				1.30E-04	1.15E-04					2.40E-06			2.47E-04
CS-134												6.65E-05	6.65E-05
CS-136											5.83E-06		5.83E-06
CS-137	3.15E-06	2.11E-04	3.61E-04	9.81E-06	3.58E-04	3.16E-05	3.69E-06	6.08E-05	1.02E-04	2.33E-04	2.24E-05	3.33E-04	1.73E-03
BA-139											1.18E-05		1.18E-05
BA-140	1.02E-05												1.02E-05
I-131		1.58E-04											1.58E-04
I-133	7.80E-04	1.38E-03	4.17E-04	9.34E-04	1.03E-03	1.03E-03	6.09E-04	5.61E-04	3.33E-04	4.07E-04		6.63E-04	8.14E-03

Note: Dissolved noble gasses detected in liquid effluents are included in airborne release totals

1.2 Isotopic Composition of Circulating Water Discharges

1.2.1 Releases During Current Reporting Period

The isotopic composition of circulating water discharges during the current reporting period is presented in Table 1-2.

1.2.2 Additions to Previous Semiannual Monitoring Report

The following information was not available at the time of report preparation and should be added to Table 1-2 of the Semiannual Monitoring Report for July 1, 1994, through December 31, 1994.

<u>Nuclide</u>	<u>December</u>	<u>6-Month Total</u>
SR-89 [Ci]	<MDA	8.51E-06
SR-90 [Ci]	2.94E-07	1.36E-05

1.3 Subsoil Drain System Releases of Tritium

1.3.1 Releases During Current Reporting Period

Table 1-3 indicates that there were no tritium releases via the subsoil drain system during the current reporting period.

TABLE 1-3

SUBSOIL SYSTEM DRAINS - TRITIUM SUMMARY
January 1, 1995 through December 31, 1995

	S1	S3	S9	S10	Total
First Quarter					
H-3 [uCi/cc]	0.0E+00	0.0E+00	0.0E+00	0.0E+00	
Ave. Flow [gpd]	8.7E+03	9.5E+03	0.0E+00	1.3E+04	2.8E+06
Second Quarter					
H-3 [uCi/cc]	0.0E+00	0.0E+00	0.0E+00	0.0E+00	
Ave. Flow [gpd]	5.2E+03	1.9E+03	0.0E+00	1.3E+04	1.8E+06
Third Quarter					
H-3 [uCi/cc]	0.0E+00	0.0E+00	0.0E+00	0.0E+00	
Ave. Flow [gpd]	1.4E+03	8.2E+02	0.0E+00	1.6E+04	1.6E+06
Fourth Quarter					
H-3 [uCi/cc]	0.0E+00	0.0E+00	0.0E+00	0.0E+00	
Ave. Flow [gpd]	2.4E+03	1.6E+03	9.6E+00	1.5E+04	1.7E+06
Annual Totals					
Released [Ci]	0.0E+00	0.0E+00	0.0E+00	0.0E+00	0.0E+00
Flow [gal]	1.6E+06	1.3E+06	8.8E+02	5.1E+06	8.0E+06

1.4 Land Application of Sewage Sludge

The Wisconsin Department of Natural Resources has approved the land-application of sewage sludges on various Wisconsin Electric Power Company properties surrounding the Point Beach Nuclear Plant. These sewage sludges, which may contain trace amounts of radionuclides, are applied in accordance with methodologies approved on January 13, 1988, pursuant to 10 CFR 20.302. The amounts discharged in the sewage during this reporting period are presented in Table 1-4.

TABLE 1-4

SEWAGE SLUDGE LAND APPLICATIONS
January 1, 1995 through December 31, 1995

<u>Date of Application</u>	<u>Gallons</u>	<u>Site</u>	<u>Activity Released [Ci]</u>
June 27	5300	PB-02	<MDA
December 12	5000	PB-02	<MDA

2.0 RADIOACTIVE AIRBORNE RELEASES

The release paths contributing to radioactive airborne release totals during this reporting period were the auxiliary building vent stack, drumming area vent stack, gas stripper building vent stack, Unit 1 containment purge stack, Unit 2 containment purge stack, combined air ejector decay duct exhaust and turbine building ventilation exhaust.

There were three gas decay tank releases during this reporting period.

2.1 Radioactive Airborne Release Summary

2.1.1 Release During Current Reporting Period

Radioactivity released in airborne effluents for the current reporting period are summarized in Table 2-1. Table 2-1 also contains the comparison of the annual Appendix I dose limits for atmospheric effluents to the highest organ dose and the noble gas doses calculated using ODCM methodology.

2.1.2 Additions to Previous Semiannual Monitoring Report

The following information was not available at the time of the last report preparation and should be added to Table 2-1 of the Semiannual Monitoring Report for July 1, 1994 through December 31, 1994.

<u>Total Particulates</u>	<u>October</u>	<u>November</u>	<u>December</u>	<u>6-Month Total</u>
Strontium [Ci]	<MDA	<MDA	<MDA	<MDA

2.2 Isotopic Airborne Releases

2.2.1 Releases During Current Reporting Period

The monthly isotopic airborne releases for the current reporting period are presented in Table 2-2.

2.2.2 Additions to Previous Semiannual Monitoring Report

The following information was not available at the time of previous report preparation and should be added to Table 2-2 of the Semiannual Monitoring Report, covering the period July 1, 1994, through December 31, 1994.

<u>Nuclide</u>	<u>April</u>	<u>May</u>	<u>June</u>	<u>6-Month Total</u>
SR-89 [Ci]	<MDA	<MDA	<MDA	<MDA
SR-90 [Ci]	<MDA	<MDA	<MDA	<MDA

TABLE 2-1

RADIOACTIVE AIRBORNE RELEASE SUMMARY
 JANUARY 1, 1995 THROUGH DECEMBER 31, 1995

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Total Noble Gasses [Ci] [1]	2.56E-01	1.26E+00	2.66E+00	7.14E-01	1.82E-01	8.06E-01	1.20E-01	1.08E+00	1.03E+00	3.72E+00	1.23E+01	4.29E-01	2.46E+01
Total Radioiodines [Ci]	2.52E-06	4.73E-04	4.76E-06	9.30E-07	1.56E-07	1.44E-06	0.00E+00	8.86E-06	1.09E-06	1.23E-04	0.00E+00	1.87E-10	6.16E-04
Total Particulates [Ci]	1.08E-05	5.83E-04	3.34E-03	0.00E+00	8.34E-10	7.54E-06	0.00E+00	5.36E-07	1.22E-06	6.93E-05	9.32E-07	3.21E-04	4.33E-03
Alpha [Ci]	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.07E-08	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.07E-08
Strontium [Ci]	1.59E-07	1.53E-07	1.69E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.91E-07
All Others (Gamma) [Ci]	1.08E-05	5.83E-04	3.34E-03	0.00E+00	8.34E-10	7.52E-06	0.00E+00	5.36E-07	1.22E-06	6.93E-05	9.32E-07	3.21E-04	4.33E-03
Total Tritium [Ci]	5.93E+00	4.51E+00	6.54E+00	7.44E+00	1.03E+01	4.57E+00	2.25E+00	3.48E+00	4.49E+00	7.61E+00	1.99E+01	7.75E+00	8.48E+01
Max Hourly Ave Release [Ci/sec]	2.10E-06	7.27E-05	6.77E-05	1.12E-06	7.08E-07	5.67E-07	9.82E-08	4.93E-05	5.70E-06	2.69E-04	7.30E-06	7.02E-05	

[1] Includes noble gas contribution from liquid releases.

COMPARISON OF EFFLUENT DOSES TO APPENDIX I LIMITS

Category	Annual Appendix I Dose Objective	January-December Calculated Dose [mrem]	Percent of Appendix I Dose Objective
Particulate	30 mrem/organ	1.15E-01	3.8E-01
Noble Gas	40 mrad (β air)	2.76E-03	6.9E-03
Noble Gas	20 mrad (γ air)	4.54E-03	2.3E-02
Noble Gas	30 mrem (skin)	3.01E-03	1.0E-02
Noble Gas	10 mrem (whole body)	5.53E-03	5.5E-02

CORRECTIONS TO TABLE 2-1
 RADIOACTIVE AIRBORNE RELEASE SUMMARY
 JANUARY 1, 1994 THROUGH JUNE 30, 1994

	JAN ¹	FEB	MAR	APR	MAY	JUN	TOTAL
Total Particulates (Ci)		2.06E-05	3.21E-05	3.21E-05	1.18E-04	4.49E-05	2.71E-04
All Others (Ci)		8.63E-06	3.96E-07	7.43E-06	2.81E-05	1.75E-07	6.36E-05

¹ No corrections needed for January 1994

TABLE 2-2

ISOTOPIC COMPOSITION OF RADIOACTIVE AIRBORNE RELEASES
JANUARY 1, 1995 THROUGH DECEMBER 31, 1995

Isotope	Jan [Ci]	Feb [Ci]	Mar [Ci]	Apr [Ci]	May [Ci]	Jun [Ci]	Jul [Ci]	Aug [Ci]	Sep [Ci]	Oct [Ci]	Nov [Ci]	Dec [Ci]	Total [Ci]
H-3	5.93E+00	4.51E+00	6.54E+00	7.44E+00	1.03E+01	4.57E+00	2.25E+00	3.48E+00	4.49E+00	7.61E+00	1.99E+01	7.75E+00	8.48E+01
ALPHA						2.07E-08							2.07E-08
F-18	1.06E-05	2.81E-04	1.14E-03			7.45E-06			7.74E-07				1.44E-03
MN-54		7.09E-07											7.09E-07
CO-58			5.33E-10								1.94E-10	2.79E-10	1.01E-09
CO-60		2.54E-07											2.54E-07
BR-82		2.13E-09	1.85E-09		6.16E-10	7.44E-10			6.89E-10	4.78E-10	1.32E-09	7.91E-10	8.62E-09
RB-88			9.20E-07										9.20E-07
SR-89	1.69E-07	1.53E-07	1.69E-07										4.91E-07
SR-90													0.00E+00
CE-141					2.18E-10								2.18E-10
CS-134												9.43E-05	9.43E-05
CS-137		3.01E-04	2.20E-03					4.45E-07	4.44E-07	6.93E-05	9.31E-07	2.27E-04	2.80E-03
CS-138	1.28E-08					7.22E-08		9.13E-08				4.40E-09	1.81E-07
I-131	6.02E-07	6.50E-05	5.67E-07	9.01E-07	1.55E-07	5.62E-07		8.73E-07	1.52E-10	4.18E-05		1.87E-10	1.10E-04
I-132	1.06E-06		8.88E-07										1.95E-06
I-133	8.57E-07	4.08E-04	3.29E-06	2.86E-08	6.16E-10	8.75E-07		7.98E-06	1.09E-06	8.16E-05			5.04E-04
I-135			9.29E-09										9.29E-09
AR-41	1.78E-01	4.70E-01	9.51E-01	8.70E-02	1.27E-01	2.87E-01	5.83E-02	3.68E-01	3.36E-01	9.77E-01	7.42E-02	1.87E-01	4.10E+00
KR-85		5.10E-02	4.00E-02							5.71E-02		1.27E-02	1.61E-01
KR-85M	2.03E-03	3.10E-02	6.51E-02	2.73E-03	7.99E-04	2.02E-02	1.75E-03	2.85E-02	2.62E-02	1.11E-01	9.95E-03	7.40E-03	3.06E-01
KR-87	4.93E-03	7.14E-02	1.54E-01	6.64E-03	1.94E-03	4.76E-02	4.13E-03	6.67E-02	6.27E-02	2.60E-01	1.97E-02	1.66E-02	7.16E-01
KR-88	7.57E-03	7.68E-02	1.64E-01	6.82E-03	2.30E-03	4.92E-02	4.38E-03	7.17E-02	6.62E-02	2.78E-01	2.15E-02	1.78E-02	7.66E-01
XE-131M											9.72E-05	3.90E-05	1.36E-04
XE-133	2.53E-02	2.55E-02	5.69E-02	5.58E-01	3.39E-02	3.62E-02	1.82E-02	3.41E-02	4.66E-02	5.54E-02	1.13E+01	4.88E-02	1.22E+01
XE-133M		2.52E-03	6.23E-03	1.02E-04	8.68E-06	1.37E-03	7.72E-05	1.33E-03	3.32E-03	1.59E-04	6.55E-04	1.78E-03	1.76E-02
XE-135	1.01E-02	1.35E-01	2.99E-01	1.51E-02	5.63E-03	9.37E-02	1.03E-02	1.47E-01	1.24E-01	5.12E-01	8.63E-01	4.76E-02	2.26E+00
XE-135M	6.38E-03	9.04E-02	2.05E-01	9.10E-03	2.56E-03	6.50E-02	5.44E-03	9.06E-02	8.58E-02	3.38E-01	2.54E-02	2.05E-02	9.44E-01
XE-138	2.16E-02	3.10E-01	7.21E-01	2.92E-02	8.25E-03	2.06E-01	1.70E-02	2.75E-01	2.77E-01	1.13E+00	8.53E-02	6.91E-02	3.15E+00

3.0 RADIOACTIVE SOLID WASTE SHIPMENTS

3.1 Type, volume, and activity of shipped solid waste

The following types, volumes, and activity of solid waste was shipped from PBNP for offsite disposal or burial during 1995. No irradiated fuel was shipped offsite. The volume, activity, and type of waste is listed in Table 3-1.

Table 3-1

QUANTITIES AND TYPES OF WASTE SHIPPED FROM PBNP

Type of waste	Units	Quantity
A. Spent resins, filter sludges, evaporator bottoms, etc.	m ³ Ci	1.77E+01 2.23E+02
B. Dry compressible waste, contaminated equip, etc. ¹	m ³ Ci	1.10E+01 4.49E-01
C. Irradiated components, control rods, etc.		None
D. Other (describe)		None

¹ Volume after incineration or compaction

3.2 Major nuclide composition (by type of waste)

The major radionuclide content of the solid waste was determined by gamma isotopic analysis and by scaling to certain indicator radionuclides based on the measured isotopic content of representative waste stream samples. The estimated isotopic content is presented in Table 3-2 in decreasing order of activity.

3.3 Solid Waste Disposition

There were seventeen solid waste shipments from PBNP to Barnwell, SC via truck.

TABLE 3-2
ESTIMATED SOLID WASTE MAJOR RADIONUCLIDE COMPOSITION

Type A Spent resins, filter sludges, etc.		Type B Dry compressible waste, etc.	
Nuclide Name	Percent Abundance	Nuclide Name	Percent Abundance
Ni-63	4.64E+01	Fe -55	2.79E+01
Co-60	3.13E+01	Co-60	1.64E+01
Cs-137	7.54E+00	Ni-63	1.28E+01
Fe-55	4.95E+00	Co-58	1.27E+01
Sb-125	2.36E+00	Nb-95	8.70E+00
Cs-134	2.19E+00	Be-7	7.15E+00
Co-58	1.91E+00	Cr-51	5.62E+00
Mn-54	1.89E+00	Zr-95	4.95E+00
Ni-59	4.97E-01	Cs-137	1.64E+00
Cr-51	3.27E-01	Sb-125	9.59E-01
Ag-110m	1.52E-01	Pu-241	5.42E-01
Pu-241	8.20E-02	C-14	1.68E-01
H-3	6.40E-02	Sr-90	1.13E-01
Sr-90	5.40E-02	H-3	7.20E-02
Zr-95	2.50E-02	Ni-59	6.40E-02
Nb-95	2.30E-02	Cm-242	7.00E-03
Am-241	1.00E-03	Ce-144	1.00E-03
Cm243/44	1.00E-03	Pu-238	1.00E-03
Pu-238	1.00E-03		

4.0 NEW AND SPENT FUEL SHIPMENTS AND RECEIPTS

During this reporting period, a total of 64 new fuel assemblies were received from Westinghouse Electric Corporation. 32 new fuel assemblies were received for the Unit 1 spring refueling, and 32 new fuel assemblies were received for the Unit 2 fall refueling.

There were no spent fuel shipments made from Point Beach Nuclear Plant during this reporting period.

5.0 NONRADIOACTIVE CHEMICAL RELEASES

5.1 Scheduled Chemical Waste Releases

Scheduled chemical waste releases to the circulating water system from January 1, 1995, to December 31, 1995, included 8.32E+06 gallons of neutralized wastewater. The wastewater contained 3.89E+02 pounds of suspended solids and 6.85E+05 pounds of dissolved solids. Scheduled chemical waste releases are based on the average analytical results obtained from sampling a representative number of neutralizing tanks.

5.2 Miscellaneous Chemical Waste Releases

Miscellaneous chemical waste releases from the retention pond (based on effluent analyses) to the circulating water for January 1, 1995, to December 31, 1995, included 5.88E+07 gallons of clarified wastewater. The wastewater contained 4.01E+03 pounds of suspended solids.

Miscellaneous chemical waste released directly to the circulating water, based on amount of chemicals used from January 1, 1995, to December 31, 1995, included 7.59E+05 pounds of sodium bisulfite and 6.00E+04 pounds of sodium hypochlorite.

6.0 CIRCULATING WATER SYSTEM OPERATION

The circulating water system operation during this reporting period for periods of plant operation is described in Table 6-1.

Table 6-1

CIRCULATING WATER SYSTEM OPERATION FOR 1995

	UNIT	JAN	FEB	MAR	APR	MAY	JUN
Average Volume Cooling Water Discharge [Mgal/day] ³	1	282.2	282.9	277.4 ¹	397.0 ¹	490.1	489.6
	2	282.2	279.2	367.8	488.0	469.9	486.6
Average Cooling Water Intake Temperature [°F]	1	37	36	35 ¹	43 ¹	47	56
	2	37	36	38	41	47	56
Average Cooling Water Discharge Temperature [°F]	1	69	68	62 ¹	59 ¹	66	74
	2	73	66	61	61	68	77
Average Ambient Lake Temperature [°F]		33	34	36	40	46	54

¹ Unit 1 refueling shutdown from March 11, 1995 to April 17, 1995

³ For days with cooling water discharge flow

Table 6-1(continued)

CIRCULATING WATER SYSTEM OPERATION FOR 1995

	UNIT	JUL	AUG	SEP	OCT	NOV	DEC
Average Volume Cooling Water Discharge [Mgal/day] ³	1	457.3	489.6	489.6	498.0	365.2	282.2
	2	491.3	489.6	489.6	436.7 ²	205.8 ²	282.2 ²
Average Cooling Water Intake Temperature [°F]	1	53	68	60	48	39	35
	2	54	68	60	48 ²	36 ²	35 ²
Average Cooling Water Discharge Temperature [°F]	1	71	87	78	67	64	69
	2	74	89	79	65 ²	36 ²	62 ²
Average Ambient Lake Temperature [°F]		52	67	58	48	38	34

² Unit 2 refueling shutdown from October 8, 1995 to December 3, 1995

³ For days with cooling water discharge flow

7.0 LEAK TESTING OF RADIOACTIVE SOURCES

During this reporting period, all applicable sealed radioactive sources were leak tested in accordance with Technical Specification 15.4.12. Leak test results were all <0.005 µCi.

8.0 MISCELLANEOUS REPORTING REQUIREMENTS

8.1 Revisions to the PBNP Office Dose Calculation Manual (ODCM) and Process Control Program (PCP)

The Environmental Manual and ODCM were revised during this reporting period. EM revisions were the change in the frequency of the monitoring report from semiannual to annual and changes in QA auditing requirements. The ODCM (Appendix G, Modification #2) removed the sludge application restriction of 4000 gallons per acre.

8.2 Interlaboratory Comparison Program

The analytical laboratory contracted to perform the radioanalyses of the PBNP environmental samples participated in the EPA Interlaboratory Comparison Program during this reporting period.

8.3 Deviations from Specified Environmental Sample Types, Locations, and Frequencies

During this reporting period, there were no deviations from the sampling frequency specified in Table 15.7.7-1 of the Technical Specifications.

8.4 Summary of Unachievable Specified Environmental LLDs

All LLDs listed in Table 15.7.7-2 of the PBNP Technical Specifications were achieved during this sampling period.

8.5 Special Circumstances

No special circumstances report regarding operation of the explosive gas monitor for the waste gas holdup system was needed during this reporting period.

9.0 **RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM (REMP)**

9.1 Introduction

The REMP results in this Annual Report are presented in the new format which was initiated with the January - June 1992 Semiannual Monitoring Report. Results are reported directly as measured, including negative and zero values. This eliminates the distortion of the results and long-term trends which occurs when the LLD is used to censor results that are below the LLD. This reporting convention follows that recommended in Health Physics Society Committee Report HPSR-1 (1980) released as document EPA 520/1-80-012.

9.2 Objective

The objective of the PBNP REMP is to fulfill the requirements of 10 CFR 20.1302, PBNP General Design Criterion (GDC) 17, GDC 64 of Appendix A to 10 CFR 50, and Sections IV.B.2 and IV.B.3 of Appendix I to 10 CFR 50. Therefore, the REMP collects samples from various environmental media in order to provide data on measurable levels of radiation and radioactive materials in the principal pathways of environmental exposure.

For the water exposure pathway, the samples include water as well as the biological integrators, fish and filamentous algae. Because of their migratory behavior, fish are wide area integrators. In contrast, the filamentous algae periphyton are attached to shoreline rocks and concentrate nuclides from the water flowing by their point of attachment.

The air-grass-cow-milk exposure pathway is important because of the many dairy farms around PBNP. Therefore, the REMP includes samples of air, general grasses, and milk in the PBNP environs.

For the measurement of the levels of ambient environmental radiation that may be affected by direct radiation from PBNP, the REMP employs a series of TLDs which are situated around PBNP.

9.3 Sampling Parameters

Samples are collected at the frequency indicated in Table 9-1 from the locations described in Table 9-2 and shown in Figures 9-1 and 9-2

9.4 Analytical Parameters

The types of analyses and their frequencies are given in Table 9-3. The LLDs for the various analyses are found in Table 9-4 with the summary of the REMP results.

9.5 Summary of REMP Results

A summary of the REMP results are presented in Table 9-4. The table contains the following information:

Sample: the type of sample medium

Description: the type of measurement

LLD: the a priori lower limit of detection

N: the number of samples analyzed

Low: the lowest measured value \pm its associated 2s counting error

Average: the average value \pm the standard deviation of N samples

High: the highest measured value \pm its associated 2s counting error

Units: the units of measurement

Additional information also is presented in Table 9-4. Not all of the results in Table 9-4 are required by the PBNP radiological effluent technical specifications (RETS). Non-RETS items and values are noted by an asterisk (*). For certain analyses, an LLD which is lower than that required by RETS is used. For these analyses, both LLDs are listed with the RETS LLD given in parentheses. Occasionally, anomalous results are obtained which lie well outside of the range of expected values. These results will be investigated and discussed in the narrative portion of this section. Blank values have not been subtracted from the results presented in Table 9-4.

TABLE 9-1

PBNP RADIOLOGICAL ENVIRONMENTAL SAMPLE COLLECTION FREQUENCY

<u>Sample Type</u>	<u>Sample Codes</u>	<u>Collection Frequency</u>
Environmental Radiation Exposure	E-01, -02, -03, -04, -05, -06, -07, -08, -09, -12, -14, -15, -16, -17, -18, -20, -22, -23, -24, -25, -26, -27, -28, -29, -30, -31, -32	Quarterly
Vegetation	E-01, -02, -03, -04, -06, -08, -09, -20	3x/yr as available
Algae	E-05, -12	3x/yr as available
Fish	E-13	3x/yr as available
Well Water	E-10	Quarterly
Lake Water	E-01, -05, -06, -09, -12	E-12 collected weekly for monthly composite. Others collected monthly.
Milk	E-11, -19, -21	Monthly
Air Filters	E-01, -02, -03, -04, -08, -20	Weekly particulate filters and charcoal canisters by continuous air sampler.
Soil	E-01, -02, -03, -04, -06, -08, -09, -20	2x/yr
Shoreline Sediment	E-01, -05, -06, -09, -12	2x/yr

TABLE 9-2

RADIOLOGICAL ENVIRONMENTAL SAMPLING LOCATIONS

<u>Location Code</u>	<u>Location Description</u>
E-01	Meteorological Tower
E-02	Site Boundary Control Center - East Side of Building
E-03	Tapawingo Road, about 0.4 Miles West of Lakeshore Road
E-04	North Boundary
E-05	Two Creeks Park
E-06	Point Beach State Park - Coast Guard Station
E-07	WPSC Substation on County Rt. V, about 0.5 Miles West of Hwy. 42
E-08	G. J. Francar Property, at the Southeast Corner of the Intersection of Hwy. 163 and Zander Road
E-09	Nature Conservancy
E-10	PBNP Site Well
E-11	Dairy Farm (W. Funk), about 3.75 Miles West of Site
E-12	Discharge Flume/Pier
E-13	Pumphouse
E-14	South Boundary, about 0.2 miles East of Site Boundary Control Center
E-15	Southwest Corner of Site
E-16	WSW, Hwy. 42, Bishop Residence, about 0.25 miles North of Nuclear Road
E-17	North of Mishicot, Hwy. 163 and Assman Road, Northeast Corner of Intersection
E-18	Northwest of Two Creeks at Zander and Tannery Roads
E-19	Local Dairy Farm, about 0.2 miles West of Hwy. 42 on the North Side of Two Creeks Road (L. Engelbrecht)
E-20	Reference Location, 17 miles Southwest, at Silver Lake College
E-21	Local Dairy Farm just South of Site (L. Strutz) on Lakeshore and Irish Roads
E-22	West Side of Hwy. 42, about 0.25 miles North of Johaneck Road
E-23	Greenfield Lane, about 4.5 Miles South of Site, 0.5 Miles East of Hwy. 42
E-24	North Side of County Rt. V, near intersection of Saxonburg Road
E-25	South Side of County Rt. BB, about 0.5 miles West of Norman Road
E-26	804 Tapawingo Road, about 0.4 miles East of Hwy. 163, North Side of Road
E-27	Intersection of Saxonburg and Nuclear Roads, Southwest Corner, about 4 Miles WSW
E-28	Nature Trail sign in parking lot on West side of EIC.
E-29	On tree on bluff overlooking Lake Michigan NE of Microwave Tower and due East of MET Tower.
E-30	NE corner at Intersection of Tapawingo and Lakeshore Roads.
E-31	On utility pole North side of Tapawingo Road closest to the gate at the West property line
E-32	On a tree located at the junction of property lines, as indicated by trees and shrubs, about 1000 feet east of the west gate on Tapawingo Road and about 1200 feet south of Tapawingo Road. The location is almost under the power lines between the blue and gray transmission towers.
E-TC	Transportation Control; Reserved for TLDs

FIGURE 9-1




FIGURE 9-2




TABLE 9-3

PBNP RADIOLOGICAL ENVIRONMENTAL SAMPLE ANALYSIS AND FREQUENCY

<u>Sample Type</u>	<u>Sample Codes</u>	<u>Analyses</u>	<u>Frequency</u>
Environmental Radiation Exposure	E-01, -02, -03, -04, -05 -06, -07, -08, -09, -12 -14, -15, -16, -17, -18, -20, -22, -23, -24, -25, -26, -27, -28, -29, -30, -31, -32, -TC	TLD	Quarterly
Vegetation	E-01, -02, -03, -04, -06, -08, -09, -20	Gross Beta Gamma Isotopic Analysis	3x/yr as available
Algae	E-05, -12	Gross Beta Gamma Isotopic Analysis	3x/yr as available
Fish	E-13	Gross Beta Gamma Isotopic Analysis (Analysis of edible portions only)	3x/yr as available
Well Water	E-10	Gross Beta, H-3 Sr-89, 90, I-131 Gamma Isotopic Analysis (on total solids)	Quarterly
Lake Water	E-01, -05, -06, -09, -12	Gross Beta H-3, Sr-89, 90 I-131 Gamma Isotopic Analysis (on total solids)	Monthly Quarterly composite of monthly collections Monthly Monthly
Milk	E-11, -19, -21	Sr-89, 90 I-131 Gamma Isotopic Analysis	Monthly
Air Filters	E-01, -02, -03, -04, -08, -20	Gross Beta I-131 Gamma Isotopic Analysis	Weekly (particulate) Weekly (charcoal) Quarterly (on composite particulate filters)
Soil	E-01, -02, -03, -04, -06, -08, -09, -20	Gross Beta Gamma Isotopic Analysis	2x/yr
Shoreline Sediment	E-01, -05, -06, -09, -12, -33	Gross Beta Gamma Isotopic Analysis	2x/yr

9.6 Discussion

Radiological environmental monitoring conducted at the Point Beach Nuclear Plant from January 1, 1995 through December 31, 1995 consisted of air filters, milk, lake water, well water, soil, fish, shoreline sediments, algae, vegetation, and TLDs.

All TLD results for the reporting period were within the normal range. Site E-12, located on the discharge flume pier continues to exhibit some of the lowest values whereas E-32, approximately 1 mile west of the plant, continues to exhibit some of the highest. The higher values at E-32 have been noted since TLDs were first located at this site. The reason for this result is not known and continues to be tracked. However, during 1995 the TLD results at E-32 have been lower than in the previous years. Therefore, the differences between TLD results from E-32 and from sites E-3 and E-31, located about 1200 feet north of E-32 at about the same distance from the plant, which typically have been 0.1 - 0.4 mR/week, were only 0.1 - 0.2 mR/week in 1995.

The analyses for individual radionuclides reveals that Sr-90 and Cs-137 continue to occur in environmental samples. Sr-90 continues to persist in milk and lakewater. Cs-137 occurs in shoreline sediment deposits, fish, algae, vegetation, and soil. These radionuclides routinely occur in environmental samples collected around the world and are attributable to the large scale atmospheric weapons tests of the 1960's and the less frequent testing in the 70's and 80's, and as well as to the Chernobyl accident. The highest Cs-137 concentrations in soil occurs at E-06, the Point Beach State Forest. This occurs because campfire ashes, from trees which incorporated fallout Cs-137 in the 1960s, is being scattered around various camp sites in the area. The occurrence of Cs-137 in tree ash has been observed in other areas of the United States.

Lake water tritium concentrations continue to be low. These samples are composited monthly for quarterly analysis. Most of the results are in the 100 - 250 pCi/l range. Three of the H-3 results are in the 950 - 5500 pCi/l range. Two of these results were obtained approximately 1.7 and 4 miles north of PBNP with the highest concentration the furthest north. The predominant current along this side of Lake Michigan is from north to south which indicates that PBNP is not the likely source of these elevated H-3 concentrations. One composite result of 1348 pCi/l from the discharge canal, E-12, included a monthly sample taken at the same time as a holdup tank was being discharged in November. Analyses of the monthly samples showed that the October and December H-3 concentrations were less than 175 pCi/l whereas the November concentration from the discharge canal was 3900 pCi/l. Over the past two years, tritium blanks have yielded results in the range of -74.6 ± 80.5 to 148 ± 101 pCi/l. Only the H-3 results from E-01 for the first quarter of 1995 and from E-12 for the 4th quarter appear to be attributable to PBNP discharges. Tritium, in addition to being produced by water-cooled reactors such as PBNP, also is a naturally occurring radionuclide.

All of the isotopic well water results are small positive and negative values indistinguishable from zero. Only the gross beta results, which are attributable to naturally occurring radionuclides, are significantly positive.

For the remaining suite of RETS specified radionuclides, measured concentrations occur as positive and negative values scattered around zero. Although the positive values are usually smaller than their associated error, small, non-zero values (below the associated LLDs) whose $\pm 2s$ error does not overlap zero occur for Co-58 and Co-60 in algae. These cobalt concentrations are low, two to four times lower than the Cs-137 concentrations which are the result of fallout which circulates through the Lake Michigan ecosystem. The October Co-60 concentration is

about two times the 2σ counting error at E-05 (0.023 ± 0.012), about 1.7 miles north of PBNP. This also occurs for Co-58 at the same site in both the August and October samples (0.017 ± 0.011 and 0.043 ± 0.021) and at E-12, near the PBNP discharge (0.029 ± 0.012), in August. Both of these radionuclides were discharged by PBNP during 1995: Co-60 every month during 1995 and Co-58 from March - December. However, as previously discussed with regard to H-3, most of the positive results are obtained north of PBNP and not near the discharge as expected if PBNP were the primary source of these cobalt isotopes. Although no measurable Co-58 or Co-60 were found in the water samples from E-05 during the year, it is known that filamentous algae have cobalt bioaccumulation factors on the order of 250 to 2800. Therefore, it is not surprising that the cobalt isotopes were found in the algae and not in the water. Freshwater fish have a bioaccumulation factor for Co-60 comparable to that of algae, about 1000. However, neither Co-58 nor Co-60 were observed in fish analyzed during the year. Therefore, it is possible that the algae results are false positives. Finally, it should be noted that the Co-58/60 levels found in the algae are at least ten times lower than the applicable LLDs and about 1000 times lower than the NRC notification levels.

9.7 Land Use Census

In accordance with the requirements of Technical Specification 15.7.7.D, a visual verification of animals grazing in the vicinity of the Point Beach Nuclear Plant site boundary was completed in July of 1995 to ensure that the milk sampling locations remain as conservative as practicable. No significant change in the use of pasture lands was noted. Therefore, the existing milk sampling program continues to be acceptable.

9.8 Conclusion

Based on the results of the PBNP REMP for 1995, PBNP effluents had a minimal affect on the PBNP environs. Only the elevated H-3 concentrations in the one water sample from the effluent channel, E-12, and one lakewater sample from E-01, the meteorological tower, are attributable to PBNP effluent. All other positive results are from other sources and from the persistence and recycling of fallout in the environment.

TABLE 9-4

RADIOLOGICAL ENVIRONMENTAL MONITORING RESULTS

Sample	Description	LLD	N	Low	Average	High	Units
TLD	Environmental Radiation	(*)	53	0.70 ± 0.03	0.87 ± 0.13	1.29 ± 0.03	mR/7days
Air	Gross beta	0.01	154	0.008 ± 0.002	0.021 ± 0.010	0.065 ± 0.004	pCi/m ³
	Cs-137	0.01(0.06)	12	-0.0008±0.0009	0.0001±0.0005	0.0008±0.0011	pCi/m ³
	Cs-134	0.05	12	-0.0009±0.0010	0.0001±0.0005	0.0008±0.0009	pCi/m ³
	I-131	0.03(0.07)	154	-0.020 ± 0.017	-0.001 ± 0.007	0.011 ± 0.014	pCi/m ³
	Other gamma emitters(*)	0.1(*)	12	-0.0012±0.0011	-0.0001±0.0005	0.0005±0.0004	pCi/m ³
Milk	I-131	0.5	18	-0.05±0.16	0.09 ± 0.08	0.23 ± 0.27	pCi/l
	Sr-89(*)	5(*)	18	-0.9 ± 0.9	0.0 ± 0.5	0.7 ± 0.8	pCi/l
	Sr-90(*)	1(*)	18	0.8 ± 0.4	1.3 ± 0.3	1.7 ± 0.4	pCi/l
	Cs-134	5(15)	18	-1.9 ± 2.5	-0.3 ± 0.8	1.1 ± 1.3	pCi/l
	Cs-137	5(18)	18	-0.8 ± 2.5	0.8 ± 0.9	2.2 ± 2.4	pCi/l
	Ba-La-140	5(15)	18	-3.2 ± 2.8	-0.1 ± 1.3	1.4 ± 3.4	pCi/l
	Other gamma emitters(*)	15(*)	18	-2.5 ± 2.7	0.1 ± 1.3	1.8 ± 3.3	pCi/l
	Lake water	Gross beta	4	30	1.2 ± 0.4	2.7 ± 1.0	5.6 ± 2.8
I-131		0.5(2)	30	-0.12±0.17	0.05 ± 0.10	0.25 ± 0.27	pCi/l
Mn-54		10(15)	30	-1.8 ± 2.9	0.2 ± 1.0	3.4 ± 4.2	pCi/l
Fe-59		30	30	-7.3 ± 6.2	-0.1 ± 2.7	4.8 ± 6.6	pCi/l
Co-58		10	30	1.5 ± 3.0	-0.0 ± 1.0	2.2 ± 3.1	pCi/l
Co-60		10	30	-2.2 ± 2.2	1.1 ± 1.6	4.1 ± 2.7	pCi/l
Zn-65		30	30	-5.0 ± 3.9	-0.5 ± 2.1	4.7 ± 5.7	pCi/l
Zr-Nb-95		15	30	-2.3 ± 5.3	-0.2 ± 1.2	3.1 ± 10.0	pCi/l
Cs-134		10(15)	30	-2.2 ± 3.5	0.6 ± 1.1	2.7 ± 3.3	pCi/l
Cs-137		10(18)	30	-1.9 ± 2.3	0.2 ± 0.9	2.2 ± 3.2	pCi/l
Ba-La-140		15	30	-9.1 ± 11.4	-2.2 ± 3.3	3.6 ± 4.1	pCi/l
Other gamma emitters(*)		30(*)	30	-3.4 ± 3.6	-0.4 ± 2.1	7.0 ± 24.1	pCi/l
H-3		500(3000)	10	-27 ± 72	126 ± 73.7	223 ± 83	pCi/l
Sr-89(*)		5(*)	10	-0.8 ± 0.8	-0.0 ± 0.5	0.6 ± 0.9	pCi/l
Sr-90(*)		1(*)	10	0.3 ± 0.3	0.6 ± 0.4	1.6 ± 0.5	pCi/l
Algae	Gross beta	0.25	4	2.01 ± 0.25	2.84 ± 0.71	3.55 ± 0.39	pCi/g
	Co-58	0.25	4	0.004±0.015	0.058 ± 0.059	0.137 ± 0.024	pCi/g
	Co-60	0.25	4	0.002±0.009	0.010 ± 0.008	0.020 ± 0.012	pCi/g
	Cs-134	0.25	4	-0.014±0.017	0.001 ± 0.011	0.012 ± 0.012	pCi/g
	Cs-137	0.25	4	0.018±0.011	0.034 ± 0.024	0.069 ± 0.025	pCi/g

TABLE 9-4(continued)

RADIOLOGICAL ENVIRONMENTAL MONITORING RESULTS

Sample	Description	LLD	N	Low	Average	High	Units
Fish	Gross beta(*)	0.5(*)	8	2.36 ± 0.05	3.29 ± 0.47	4.00 ± 0.11	pCi/g
	Mn-54	0.13	8	-0.001±0.006	0.000±0.004	0.004±0.005	pCi/g
	Fe-59	0.26	8	-0.030±0.020	-0.004±0.072	0.023±0.072	pCi/g
	Co-58	0.13	8	-0.002±0.007	0.001±0.003	0.003±0.007	pCi/g
	Co-60	0.13	8	-0.006±0.004	0.003±0.005	0.012±0.117	pCi/g
	Zn-65	0.26	8	-0.008±0.016	0.004±0.008	0.010±0.012	pCi/g
	Cs-134	0.13	8	-0.004±0.027	-0.001±0.002	0.003±0.003	pCi/g
	Cs-137	0.15	8	0.034±0.012	0.054±0.014	0.060±0.015	pCi/g
	Other gamma emitters(*)	0.5(*)	8	-0.005±0.045	0.001±0.005	0.007±0.014	pCi/g
Well water	Gross beta	4	2	1.7 ± 1.3	2.6 ± 1.3	3.5 ± 1.3	pCi/l
	I-131	0.5(2)	2	0.04 ± 0.18	0.11 ± 0.10	0.18 ± 0.18	pCi/l
	Mn-54	10(15)	2	-1.0 ± 2.3	-0.2 ± 1.1	0.6 ± 2.5	pCi/l
	Fe-59	30	2	-1.7 ± 6.6	0.4 ± 2.9	2.4 ± 6.8	pCi/l
	Co-58	10	2	0.5 ± 2.9	0.8 ± 0.8	1.0 ± 2.8	pCi/l
	Co-60	10	2	1.1 ± 2.6	2.2 ± 1.6	3.3 ± 2.0	pCi/l
	Zn-65	30	2	0.3 ± 5.0	1.2 ± 1.2	2.0 ± 5.4	pCi/l
	Zr-Nb-95	15	2	-0.2 ± 5.0	0.3 ± 0.6	0.7 ± 2.9	pCi/l
	Cs-134	10(15)	2	-3.6 ± 9.1	-1.6 ± 2.8	0.4 ± 3.0	pCi/l
	Cs-137	10(18)	2	-0.6 ± 2.9	-0.1 ± 0.8	0.5 ± 3.1	pCi/l
	Ba-La-140	15	2	-3.0 ± 8.3	-2.6 ± 0.6	-2.1 ± 1.1	pCi/l
	Other gamma emitters(*)	30(*)	2	-0.1 ± 0.1	0.8 ± 1.2	1.6 ± 3.8	pCi/l
	H-3	500	2	-27.3 ± 72.6	19.4 ± 66.0	66.0 ± 82.2	pCi/l
	Sr-89(*)	5(*)	2	-0.35 ± 0.44	0.06 ± 0.57	0.46 ± 0.48	pCi/l
Sr-90(*)	1(*)	2	0.10 ± 0.16	0.11 ± 0.30	0.32 ± 0.21	pCi/l	
Soil(*)	Gross beta	2	8	6.5 ± 1.9	18.0 ± 7.5	27.8 ± 3.0	pCi/g
	Cs-137	0.15	8	0.009 ± 0.014	0.286 ± 0.224	0.63 ± 0.06	pCi/g
Shoreline sediment(*)	Gross beta	2	5	3.5 ± 1.5	6.0 ± 1.6	7.7 ± 1.3	pCi/g
	Cs-137	0.15	5	0.019 ± 0.032	0.036 ± 0.020	0.064 ± 0.026	pCi/g
Vegetation	Gross beta(*)	0.25(*)	16	4.3 ± 0.2	6.3 ± 1.7	10.3 ± 0.4	pCi/g
	Cs-134	0.06	16	-0.004±0.012	0.003 ± 0.004	0.008 ± 0.013	pCi/g
	Cs-137	0.08	16	0.019±0.017	0.007 ± 0.009	0.019 ± 0.017	pCi/g
	I-131	0.06	16	-0.009±0.019	0.001 ± 0.005	0.010 ± 0.024	pCi/g