


**TEXAS UTILITIES GENERATING COMPANY**  
SKYWAY TOWER • 400 NORTH OLIVE STREET, L.B. 81 • DALLAS, TEXAS 75201

**BILLY R. CLEMENTS**  
VICE PRESIDENT, NUCLEAR OPERATIONS

October 31, 1984  
TXX-4347



Mr. D.R. Hunter, Chief  
Reactor Project Branch 1  
U.S. Nuclear Regulatory Commission  
Office of Inspection & Enforcement  
611 Ryan Plaza Drive, Suite 1000  
Arlington, TX 76012

Docket Nos: 50-445  
50-446

COMANCHE PEAK STEAM ELECTRIC STATION  
IMPACT OF HELB TEMPERATURES ON  
QUALIFIED EQUIPMENT OUTSIDE CONTAINMENT  
QA FILE: CP-84-12, SDAR-136  
FILE NO.: 10110

Dear Mr. Hunter:

On June 4, 1984 we verbally notified your Mr. D. Hunnicutt of a deficiency regarding the temperature envelope requirements on the environmental qualification of equipment outside containment for high energy line breaks (HELB). We have submitted interim reports, TXX-4212 and TXX-4293, dated July 2, 1984 and August 30, 1984 respectively.

As discussed in our previous report, a Justification for Interim Operation (JIO), based upon representative mass and energy release data provided by Westinghouse, has been submitted to the NRC Nuclear Reactor Regulation (NRR). Plant specific data is expected in mid February, 1985. Upon receipt, a new analysis will be performed which will result in an evaluation to determine reportability under 10CFR50.55(e) and to identify modifications, if required.

We will provide a status report regarding this matter by April 1, 1985.

Very truly yours,

*Richard E. Kahler*  
for Billy R. Clements

BRC:tlg

cc: NRC Region IV - (0 + 1 copy)

Director, Inspection & Enforcement (15 copies)  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

8411130642 841031  
PDR ADOCK 05000445  
S PDR  
A DIVISION OF TEXAS UTILITIES GENERATING COMPANY

110 IE-27