

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

Before Administrative Judges:

Peter B. Bloch, Chairman
Dr. Kenneth A. McCollom
Dr. Walter H. Jordan

DOCKET
USNRC
'84 NOV -9 P4:10

OFFICE OF THE
GENERAL COUNSEL
BRANCH
Docket Nos. 50-445
50-446

OC

In the Matter of

TEXAS UTILITIES ELECTRIC COMPANY

(Application for
Operating License)

(Comanche Peak Steam Electric Station,
Units 1 and 2)

November 9, 1984

MEMORANDUM

SERVED NOV 13 1984

(Official Notice Concerning Pipe Supports)

We take official notice that R. Camp is reported, at pp. 66 and 69 of the Meeting With Tugco and NRC/TRT, October 23, 1984, Bethesda, Maryland:

Included in that next [hot functional testing] heat up will be the thermal expansion test of the deficiencies found the last time. The current status is that we [are] . . . in preparation for ambient measurements for the deficient supports found during hot functional testing.

* * *

At the current time, we plan on finishing these incomplete preoperational tests prior to fuel load, in which case they will be reviewed and approved prior to fuel load. Any kind of technical specification deviations that may be associated with thermal expansion, we don't know the scope or extent of those at this time, and we won't know until we finish the re-tests associated with thermal expansion.

If the parties wish to correct these portions of the transcript, they may file corrections within ten days. The matters mentioned appear to be relevant to the adequacy of the design of pipe supports, to the adequacy of quality assurance for design and to Applicants' testimony that there is a safety factor of 40 in the design of this plant.

8411130717 841109
PDR ADOCK 05000445
G PDR

DS02

FOR THE
ATOMIC SAFETY AND LICENSING BOARD

Peter B. Bloch, Chairman
ADMINISTRATIVE JUDGE

Bethesda, Maryland