

~~PROPRIETARY~~

APPENDIX M
LIMERICK GENERATING STATION

~~PROPRIETARY~~

8503010123 841024
PDR FOIA
SHOLLY84-329 PDR

~~PROPRIETARY~~

TABLES

M-0.0 Index of ASEP events for Limerick Generating Station.....	M-4
M-1.0 Limerick Generation Station ASEP event definitions	M-30
M-2.1 SETS input, Limerick Generating Station, Sequence T_E^{UV}	M-64
M-2.2 Unavailability, Limerick Generating Station, Sequence T_E^{UV}	M-67
M-2.3 Cut set ranking, Limerick Generating Station, Sequence T_E^{UV}	M-67
M-2.4 Event importance, Limerick Generating Station, Sequence T_E^{UV}	M-68
M-3.1 SETS input, Limerick Generating Station, Sequence T_E^{UX}	M-69
M-3.2 Unavailability, Limerick Generating Station, Sequence T_E^{UX}	M-86
M-3.3 Cut set ranking, Limerick Generating Station, Sequence T_E^{UX} ...	M-86
M-3.4 Event importance, Limerick Generating Station, Sequence T_E^{UX}	M-87
M-4.1 SETS input, Limerick Generating Station, Sequence T_F^{QUV}	M-89
M-4.2 Unavailability, Limerick Generating Station, Sequence T_F^{QUV} ... M-119	
M-4.3 Cut set ranking, Limerick Generating Station, Sequence T_F^{QUV}	M-119
M-4.4 Event importance, Limerick Generating Station, Sequence T_F^{QUV}	M-120
M-5.1 SETS input, Limerick Generating Station, Sequences T_F^{QUX} , T_I^{UX} , T_M^{QUX} , and T_T^{QUX}	M-122
M-5.2 Unavailability, Limerick Generating Station, Sequences T_F^{QUX} , T_I^{UX} , T_M^{QUX} , and T_T^{QUX}	M-138
M-5.3 Cut set ranking, Limerick Generating Station, Sequences T_F^{QUX} , T_I^{UX} , T_M^{QUX} , and T_T^{QUX}	M-138
M-5.4 Event importance, Limerick Generating Station, Sequences T_F^{QUX} , T_I^{UX} , T_M^{QUX} , and T_T^{QUX}	M-139

~~PROPRIETARY~~

~~PROPRIETARY~~

TABLE M-0.0. INDEX OF ASEP EVENTS FOR LIMERICK GENERATING STATION

<u>ASEP Event</u>	<u>Page No.</u>
ACCS1APF	M-53
ACCS1APG	M-52
ACCS1APH	M-51
ACCS1APL	M-54
ACCS1APR	M-53
ACCS1APS	M-52
ACCS1CPI	M-53
ACCS1CPM	M-52
ACCS1CPN	M-51
ACCS1CPO	M-53
ACCS1CPV	M-53
ACCS1CPW	M-52
ACCS2BPJ	M-52
ACCS2BPK	M-51
ACCS2BPT	M-53
ACCS2BPU	M-52
ACCS2DPP	M-53
ACCS2DPQ	M-52
ACCS2DPX	M-53
ACCS2DPY	M-52
ACDC1AAV	M-31
ACDC1BAW	M-31
ACDC9AAT	M-30

~~PROPRIETARY~~

~~PROPRIETARY~~

TABLE M-0.0. (continued)

<u>ASEP Event</u>	<u>Page No.</u>
ACOG9BAU	M-31
ACOG11JA	M-40
ACOG12JC	M-40
ACOG13JE	M-40
ACOG14JG	M-41
ACESWAFB	M-60
ACESWBFC	M-60
ACESWCFO	M-60
ACESWDFF	M-60
ACHCCLOS	M-48
ACHCOPOE	M-49
ACHCLSOL	M-46
ACHCLSM	M-46
ACHCOSOO	M-49
ACHCPSOA	M-48
ACHCPSOB	M-48
ACHCPSOC	M-48
ACHCPSOO	M-48
ACHCPSOG	M-48
ACHCPSOH	M-48
ACHCPSOI	M-48
ACHCPSOJ	M-48
ACHCPSOK	M-49

~~PROPRIETARY~~

~~PROPRIETARY~~

TABLE M-0.0. (continued)

<u>ASEP Event</u>	<u>Page No.</u>
ACHCTSOF	M-49
ACHCTSON	M-48
ACHP1BNN	M-48
ACHP1DNP	M-48
ACHP1FNR	M-48
ACHPIHNT	M-48
ACHP2BNO	M-46
ACHP2CNQ	M-46
ACHP2FNS	M-46
ACHP2GNU	M-46
ACRC2AMK	M-58
ACRC2AML	M-58
ACRC2BMI	M-58
ACRC2BMJ	M-58
ACRCCSLP	M-46, -58
ACRCCSLQ	M-46, -58
ACRCCSLT	M-46, -57
ACRCCTLs	M-59
ACRCCTLU	M-56
ACRCICKO	M-60
ACRCICKT	M-59
ACRCIPL0	M-56
ACRCIRKY	M-58

~~PROPRIETARY~~

~~PROPRIETARY~~

TABLE M-0.0. (continued)

<u>ASEP Event</u>	<u>Page No.</u>
ACRCISKZ	M-58
ACRCITKW	M-57
ACRCITLN	M-57
ACRCITLO	M-56
ACRCIVKX	M-58
ACRCPSLA	M-59
ACRCPSLB	M-59
ACRCPSLC	M-59
ACRCPSLD	M-59
ACRCRPLE	M-59
ACRCRPLF	M-59
ACRCRPLG	M-59
ACRCRPLH	M-59
ACRCRWLK	M-59
ACRCRWLL	M-58
ACRCRWLM	M-58
ACRRCAKA	M-55
ACRRCAKB	M-56
ACRRCAKE	M-49
ACRRCBKF	M-56
ACRRCBKG	M-56
ACRRCBKJ	M-50
AOSTRANS	M-63

~~PROPRIETARY~~

~~PROPRIETARY~~

TABLE M-0.0. (continued)

<u>ASEP</u> <u>Event</u>	<u>Page</u> <u>No.</u>
CMDGAL01	M-34
CMHRSOMA	M-45
CMHRSOMH	M-49
ENADCMOG	M-33, -34
ENCICMRA	M-35, -36
ENCSCMPG	M-52, -53
ENCSCMPH	M-51, -52
ENESPCFY	M-62
ENHPCONV	M-48, -53, -54
ENHPCLNW	M-46
ENRCCSLT	M-46, -57
ENRCIRKY	M-58
ENRCISKZ	M-58
ENRCITKW	M-57
ENRCITLO	M-56
ENRCIVKX	M-58
ENRCPSLI	M-57
ENRCRPLJ	M-57
ESAOSMAN	M-63
ESAOSX10	M-63
ESCI1ARZ	M-36
ESCI1TRV	M-36

~~PROPRIETARY~~

~~PROPRIETARY~~

TABLE M-0.0. (continued)

<u>ASEP Event</u>	<u>Page No.</u>
ESCI2BRX	M-36
ESCI2TRT	M-36
ESCICTSP	M-39, -40
ESCIXXRE	M-37, -38
ESCSACPZ	M-51
ESCSCTQA	M-54, -55
ESCSRFAQ	M-54, -55
ESO1AWHW	M-43
ESO1VAGP	M-50
ESO1VBGM	M-50
ESO2AWIA	M-43
ESO2VAGY	M-50
ESO2VBGV	M-50
ESO3AWIE	M-43
ESO3VAHG	M-50
ESO3VBHO	M-50
ESO4AWII	M-43
ESO4VAHO	M-50
ESO4VBHL	M-50
ESESWAEX	M-61
ESESWBEY	M-61
ESESWCEZ	M-61

~~PROPRIETARY~~

~~PROPRIETARY~~

TABLE M-0.0. (continued)

<u>ASEP Event</u>	<u>Page No.</u>
ESESWDFA	M-61
ESHCCTOY	M-45
ESHPCINX	M-45
ESHPCINY	M-45
ESHPCINZ	M-46
ESIAXXAL	M-31
ESRCACMN	M-57
ESRCCTLR	M-46, -57
ESRCICKN	M-57
ESRCICKU	M-57
ESRCICMM	M-46
ESRCSP LZ	M-57
ESRMCX04	M-32
ESRRCAKB	M-56
ESRRCAKH	M-50
ESRRCBKC	M-50
ESRRCBKG	M-56
EXCIXXRE	M-38
HMCSSRAQN	M-54
HMCSSRBQJ	M-55
HMCSSRCQM	M-54

~~PROPRIETARY~~

~~PROPRIETARY~~

TABLE M-0.0. (continued)

<u>ASEP Event</u>	<u>Page No.</u>
HMCSR0QI	M-55
HMHCRCPA	M-50
HMIR1ASY	M-38
HMIR1CSU	M-38
HMIR2BSW	M-38
HMIR2DSS	M-38
HMNP01IV	M-44
HMNP02IW	M-44
HMNP03IX	M-44
HMNP04IY	M-44
HMP1AAAP	M-31
HMP1ABAO	M-31
HPCILCST	M-50
HPCILSP	M-54
HPCIN02	M-48
HPCIN03	M-48
HPCIN04	M-48
HPRC1	M-60
HS4401JI	M-41
HS4402JJ	M-41
HS4403JK	M-41
HS4404JL	M-41
HSACCAAE	M-31

~~PROPRIETARY~~

~~PROPRIETARY~~

TABLE M-0.0. (continued)

<u>ASEP Event</u>	<u>Page No.</u>
HSADC3BA	M-30
HSADGCAF	M-33
HSADRAAD	M-31
HSADRBAZ	M-31
HSADS1DH	M-33
HSADS2DI	M-33
HSADS3OJ	M-34
HSADS4OK	M-34
HSADS5OL	M-34
HSCI1ARI	M-35
HSCI1ARJ	M-35
HSCI1ARK	M-38
HSCI1ARP	M-37
HSCI1ARQ	M-37
HSCI1ARR	M-37
HSCI1ASZ	M-38
HSCI1CRW	M-35
HSCI1CSV	M-38
HSCI1TRV	M-36
HSCI2BRF	M-35
HSCI2BRG	M-35
HSCI2BRH	M-38
HSCI2BRL	M-37

~~PROPRIETARY~~

~~PROPRIETARY~~

TABLE M-0.0. (continued)

<u>ASEP Event</u>	<u>Page No.</u>
HSCI2BRM	M-37
HSCI2BRN	M-37
HSCI2BSX	M-38
HSCI2DRU	M-35
HSCI2DSI	M-38
HSCI2TRT	M-36
HSCIHASC	M-38
HSCIHB8	M-38
HSCIPARA	M-35
HSCIPASF	M-39
HSCIPBRS	M-35
HSCIPBSI	M-39
HSCIPCRC	M-35
HSCIPCSL	M-39
HSCIPORD	M-36
HSCIPOSO	M-40
HSCS1AQN	M-54
HSCS1CQM	M-54
HSCS1XQY	M-52
HSCS1XQZ	M-51
HSCS2BQJ	M-55
HSCS2DQI	M-55
HSCS2XQW	M-52

~~PROPRIETARY~~

~~PROPRIETARY~~

TABLE M-0.0. (continued)

<u>ASEP Event</u>	<u>Page No.</u>
HSCS2XQX	M-51
HSCSPAQP	M-51
HSCSPAQQ	M-51
HSCSPAQR	M-54
HSCSPBQB	M-51
HSCSPBQC	M-51
HSCSPBQQ	M-55
HSCSPCQT	M-51
HSCSPCQU	M-51
HSCSPCQV	M-54
HSCSPDQF	M-51
HSCSPDQG	M-51
HSCSPDQH	M-55
HSCST1Q0	M-54
HSCST1Q0	M-54
HSCST2QA	M-55
HSCSTBQA	M-55
HSCSTBQQ	M-54
HSCSTCQS	M-54
HSCSTDQE	M-55
HSCWAAEQ	M-60
HSCWABER	M-60

~~PROPRIETARY~~

~~PROPRIETARY~~

TABLE M-0.0. (continued)

<u>ASEP</u> <u>Event</u>	<u>Page</u> <u>No.</u>
HSCWBADV	M-60
HSCWBBDW	M-60
HSCWCADX	M-60
HSCWCBDY	M-60
HS013EAY	M-33
HS013HAA	M-33
HS013KAX	M-34
HS013MAB	M-34
HS013SAC	M-34
HS01AWHY	M-43
HS01NWHZ	M-42
HS01SGJB	M-41
HS01SGJF	M-41
HS01SWHX	M-42, -43
HS01VAGO	M-50
HS01VAGR	M-41
HS01VAGT	M-49
HS01VBGN	M-50
HS01VBGO	M-42
HS01VBGU	M-49
HS01VBHC	M-49
HS01VXGS	M-40

~~PROPRIETARY~~

~~PROPRIETARY~~

TABLE M-0.0. (continued)

<u>ASEP Event</u>	<u>Page No.</u>
HSD2AWIC	M-43
HSD2NWID	M-42
HSD2SGJD	M-41
HSD2SWIB	M-42, -43
HSD2VAGZ	M-50
HSD2VAHA	M-42
HSD2VAHT	M-49
HSD2VBGW	M-50
HSD2VSGX	M-42
HSD2VXHB	M-41
HSD3AWIG	M-43
HSD3NWIH	M-42
HSD3SGJF	M-41
HSD3SWIF	M-42, -43
HSD3VAHH	M-50
HSD3VAHI	M-42
HSD3VAHU	M-49
HSD3VBHE	M-50
HSD3VBHF	M-42
HSD3VBHK	M-49
HSD3VXHJ	M-41

~~PROPRIETARY~~

~~PROPRIETARY~~

TABLE M-0.0. (continued)

<u>ASEP Event</u>	<u>Page No.</u>
HSD4NWIL	M-43
HSD4SWIJ	M-43
HSD4VAHP	M-50
HSD4VAHQ	M-42
HSD4VAHV	M-49
HSD4VBHM	M-50
HSD4VBHN	M-42
HSD4VBHS	M-49
HSD4VXHR	M-41
HS08GABM	M-30
HS08G8BN	M-30
HS08V2CL	M-34
HS08V3CM	M-34
HS08V4CN	M-34
HS08V5CO	M-34
HS08VICK	M-33
HS0C11JN	M-44
HS0C12JP	M-44
HS0C13JQ	M-44
HS0C14JR	M-44
HS0C1AAV	M-31
HS0C1BAW	M-31

~~PROPRIETARY~~

~~PROPRIETARY~~

TABLE M-0.0. (continued)

<u>ASEP Event</u>	<u>Page No.</u>
HSOC1EBH	M-30
HSOC1HBI	M-30
HSOC1KBJ	M-30
HSOC1M8K	M-30
HSOC1SBL	M-30
HSOC21JM	M-44
HSOC22J0	M-44
HSOC4EBC	M-30
HSOC4H80	M-30
HSOC4KBE	M-30
HSOC4MBF	M-30
HSOC4S8G	M-30
HSOC9AAT	M-30
HSOC9BAU	M-31
HSOC01GK	M-45
HSOC01JU	M-41
HSOC02GL	M-45
HSOC02JV	M-41
HSOC03GI	M-45
HSOC03JS	M-41
HSOC04GJ	M-45
HSOC04JT	M-41
HSOG11IN	M-43

~~PROPRIETARY~~

~~PROPRIETARY~~

TABLE M-0.0. (continued)

<u>ASEP Event</u>	<u>Page No.</u>
HSDG11JA	M- 0
HSDG12IP	M-44
HSDG12JC	M-40
HSDG13IR	M-44
HSDG13JE	M-40
HSDG14IT	M-44
HSDG14JG	M-41
HSDGCABY	M-33
HSDGCBBB	M-33
HSDGCBBZ	M-33
HSDH31CF	M-33
HSDH32CG	M-33
HSDH33CH	M-33
HSDH34CI	M-33
HSDH35CJ	M-33
HSOP11CA	M-33
HSOP12CB	M-33
HSOP13CC	M-33
HSOP14CD	M-33
HSOS1ADA	M-32
HSOS1BCP	M-32
HSOS2ADC	M-32
HSOS2BCS	M-32

~~PROPRIETARY~~

~~PROPRIETARY~~

TABLE M-0.0. (continued)

<u>ASEP</u> <u>Event</u>	<u>Page</u> <u>No.</u>
HS0S3ADD	M-32
HS0S3BCU	M-32
HS0S4ADE	M-32
HS0S4BCU	M-32
HS0S5ADE	M-32
HS0S5BCY	M-32
HSOWAWIK	M-43
HSESAAFH	M-60
HSESABFI	M-60
HSESACFF	M-61
HSESBAFJ	M-60
HSESBBFK	M-60
HSESBCOZ	M-61
HSESBOFG	M-61
HSESCAFL	M-60
HSESCBFM	M-60
HSESCTFZ	M-62
HSESCTGA	M-63
HSESPAFV	M-62
HSESPBFW	M-62
HSESPCFX	M-63
HSESWAES	M-61

~~PROPRIETARY~~

~~PROPRIETARY~~

TABLE M-0.0. (continued)

<u>ASEP Event</u>	<u>Page No.</u>
HSESWAET	M-61
HSESWAFN	M-60
HSESWAFQ	M-63
HSESWAFU	M-62
HSESWAGB	M-60
HSESWBEV	M-61
HSESWBFO	M-60
HSESWBFR	M-63
HSESWBFT	M-62
HSESWBGC	M-60
HSESWCEU	M-61
HSESWCFP	M-60
HSESWCFS	M-62
HSESWCGD	M-60
HSESWDEW	M-61
HSHCCPOQ	M-46
HSHCCSMX	M-47
HSHCCTQZ	M-46
HSHCCTNF	M-47
HSHCCTNG	M-47
HSHCFWND	M-45
HSHCSPOV	M-45

~~PROPRIETARY~~

~~PROPRIETARY~~

TABLE M-0.0. (continued)

<u>ASEP Event</u>	<u>Page No.</u>
HSHCSPOW	M-45
HSHPCIMX	M-47
HSHPCINO	M-45
HSHPCINE	M-45
HSHPCINH	M-47
HSHPCIOX	M-46
HSHPCLMY	M-47
HSHPCLMZ	M-48
HSHPCPNC	M-47
HSHPCPNM	M-47
HSHPCTNA	M-47
HSHPCTNI	M-45
HSHPCTNJ	M-47
HSHPCTNK	M-47
HSHPCTNL	M-47
HSHPLPNE	M-45, -51
HSII1A1RV	M-36
HSII1A1RZ	M-36
HSII1A2RV	M-36, -37
HSII1A2RZ	M-36, -37
HSII1B2RX	M-37
HSII1CTRZ	M-36
HSI2B1RT	M-36

~~PROPRIETARY~~

~~PROPRIETARY~~

TABLE M-0.0. (continued)

<u>ASEP Event</u>	<u>Page No.</u>
HSI2B1RX	M-36
HSI2B2RI	M-36
HSI2B2RT	M-37
HSI2B2RX	M-36
HSI2DTRX	M-36
HSIAABAQ	M-31
HSIACAAH	M-30
HSIACBAG	M-30
HSICSAAS	M-31
HSIGCAAS	M-30
HSIGCBAR	M-30, -31
HSIGSAAJ	M-30
HSIGSBAI	M-30
HSIHXASA	M-37
HSIHXBRY	M-37
HSIL1ASY	M-38
HSIL1CSU	M-38
HSIL2BSW	M-38
HSIL2DSS	M-38
HSINCABS	M-30
HSINCBBT	M-30
HSINVABQ	M-33
HSINVBBR	M-33

~~PROPRIETARY~~

~~PROPRIETARY~~

TABLE M-0.0. (continued)

<u>ASEP Event</u>	<u>Page No.</u>
HSIP1ASE	M-37
HSIP1BSH	M-37
HSIP1CSK	M-37
HSIP1DSN	M-37
HSIP2ASD	M-37
HSIP2BSG	M-37
HSIP2CSJ	M-37
HSIP2DSM	M-37
HSIT6ASR	M-39
HSIT6BSQ	M-39, -40
HSIT7ASP	M-39, -40
HSIT7BSP	M-39, -40
HSITGASR	M-39, -40
HSNGRABU	M-31
HSNGRBV	M-31
HSNGSABW	M-31
HSNGSBX	M-31
HSPIAAAN	M-31
HSPIABAM	M-31
HSPP15CE	M-33
HSRCCSLY	M-57
HSRCIPKR	M-59

~~PROPRIETARY~~

~~PROPRIETARY~~

TABLE M-0.0. (continued)

<u>ASEP</u> <u>Event</u>	<u>Page</u> <u>No.</u>
HSRCIPKS	M-59
HSRCIPMC	M-59
HSRCIPMF	M-56
HSRCITKP	M-59
HSRCITMA	M-59
HSRCITMB	M-59
HSRCITMO	M-56
HSRCITMP	M-56
HSRCITMQ	M-56
HSRCITMR	M-56
HSRCITMS	M-60
HSRCITMT	M-57
HSRCLSMV	M-58
HSRCLWMU	M-51
HSRCSPLV	M-56
HSRCSPLW	M-56
HSRCSPLEX	M-57
HSRESTEM	M-36
HSRESTEN	M-36
HSRESTEO	M-37
HSRESTEP	M-37
HSRESWEA	M-37
HSRESWEB	M-37

~~PROPRIETARY~~

~~PROPRIETARY~~

TABLE M-0.0. (continued)

<u>ASEP Event</u>	<u>Page No.</u>
HSRESWEC	M-37
HSRESWED	M-37
HSRESWEF	M-37
HSRESWEI	M-37
HSRESWEJ	M-37
HSRESWEK	M-38
HSRESWEL	M-37
HSRESXEG	M-35
HSRESXEH	M-34
HSRHCI MD	M-47
HSRHCI ME	M-58
HSRHCT LY	M-46, -54, -55, -57
HSRRC AKI	M-50
HSRRC AKK	M-49
HSRRC BKD	M-50
HSRRC BKL	M-49
HSRRC XKM	M-50
HSRSPXPE	M-54
HSSW1ADT	M-63
HSSW1BDR	M-63
HSSW2ADU	M-63
HSSW2BDS	M-63

~~PROPRIETARY~~

~~PROPRIETARY~~

TABLE M-0.0. (continued)

<u>ASEP Event</u>	<u>Page No.</u>
LOSPCMAK	M-30, -62, -63
PHHPCINV	M-48
PHHPCTNB	M-49
PHHPCTNI	M-45
PHHPCTNL	M-47
PHRSPXPD	M-54
RCDG11IO	M-43
RCDG12IQ	M-43
RCDG13IS	M-43
RCDG14IU	M-43
RCOGA103	M-56
RCDGA207	M-56
RCDGA297	M-56
RCDGA309	M-56
RCOGA399	M-56
RCICJ01	M-53
RCLOSPIZ	M-44
RCOSP102	M-58
RCOSP206	M-58
RCOSP308	M-59
TMAOS10M	M-33
TMAOS20N	M-33
TMADS300	M-33

~~PROPRIETARY~~

~~PROPRIETARY~~

TABLE M-0.0. (continued)

<u>ASEP Event</u>	<u>Page No.</u>
TMA0S4DP	M-33
TMA0S5DQ	M-33
TMCI1ATD	M-34
TMCI1CTB	M-35
TMCI2BTC	M-34
TMCI2DTOA	M-36
TMCS1XQL	M-55
TMCS2XQK	M-55
TMDGSDIM	M-41
TMEP11G4	M-44
TMEP12GG	M-45
TMEP13GF	M-45
TMEP14GE	M-45
TMESPCFY	M-62
TMHPCIMW	M-49
TMRCICMG	M-58
UNDGABO	M-30
UNDGBBP	M-30
UNDG1BCQ	M-32
UNDG2BCT	M-32
UNDG3BCV	M-32
UNDG4BCV	M-32
UNDG4BCX	M-32

~~PROPRIETARY~~

~~PROPRIETARY~~

TABLE M-0.0. (continued)

<u>ASEP Event</u>	<u>Page No.</u>
UNDG5BCZ	M-32
UNHC2SPB	M-48
UNHC3SPC	M-48
UNHPIX05	M-60
UNLPCX11	M-60
UNLPCX12	M-60
UNLPCX13	M-60
UNRCTTKQ	M-59
UNRCITMT	M-57
UNRESWEE	M-38

~~PROPRIETARY~~

TABLE LIMERICK GENERATION STATION ASEP EVENT DEFINITIONS

ASCE Event
Unavailability
Time

A REA Event	A SCE Event	Component/Idealization	Unavailability
ABGS1		Failure of ADS backup gas supply, Train A (Excluding ABGS1 and gate)	
	ABY52ADP1	Failure of pressure regulator	
	AVV28ADW1	globe/check valve fail closed	
	ABY52ADP1	Failure of solenoid valve 152A, NO-FC	
JACBGA0C	AB211ADW1	ADS backup gas supply unavailable to Train A	
ABGS2		Failure of ADS backup gas supply, Train B (Excluding ABGS2 and gate)	
	ABY52ADP1	Failure of pressure regulator	
	ABY52ADP1	Failure of solenoid valve 152B, NO-FC	
	AVV28ADW1	globe/check valves fail closed	
	UNOBGEP	AB211ADW1, ADS backup gas supply unavailable	
ACM1		Failure of instrument gas system A (for ADS gas supply)	
	HSIGSAAS	APP[GAOF], instrument gas system A line rupture	
	HSIGSAAI	ACM110W1, failure of instrument gas system A compressor	
	LOSPOPAK	EDSP, loss of offsite power	
ACM2		Failure of instrument gas system B (for ADS gas supply)	
	HSIGSBAR	APP[GAOF], instrument gas system B line rupture, fail plant instrument gas Train B also	
	HSIGSBAI	ACM110W1, failure of instrument gas system B compressor	
	LOSPOPAK	EDSP, loss of offsite power	
ACM1ADM1	HSIACAAH	ACM110W1, failure of plant instrument air compressor A (for ADS gas supply)	
ACM1BDW1	HSIACBAG	ACM110W1, failure of plant instrument air compressor B (for ADS gas supply)	
ACY122DRI	HSINC8BT	ACY122DRI, failure of ADS gas supply check valve 1122	
ACY141DRI	HSINC8BS	ACY141DRI, failure of ADS gas supply check valve 1141	
ACY24EDR1	HSDC4EBC	ACY24EDR1, ADS gas supply check valve 1024E fails to close	
ACY24HDR1	HSDC4AHB	ACY24HDR1, ADS gas supply check valve 1024H fails to close	
ACY24EDR1	HSDC4KEBE	ACY24EDR1, ADS gas supply check valve 1024K fails to close	
ACY24HDR1	HSDC4KMBF	ACY24HDR1, ADS gas supply check valve 1024M fails to close	
ACY24SDR1	HSDC4SBB	ACY24SDR1, ADS gas supply check valve 1024S fails to close	
ACY31EDR1	HSDC1EBH	ACY31EDR1, ADS gas supply check valve 1131E fails to close	
ACY31HDR1	HSDC1HBI	ACY31HDR1, ADS gas supply check valve 1131H fails to close	
ACY31EDR1	HSDC1KBL	ACY31EDR1, ADS gas supply check valve 1131K fails to close	
ACY31HDR1	HSDC1MBB	ACY31HDR1, ADS gas supply check valve 1131M fails to close	
ACY31SDR1	HSDC1SLB	ACY31SDR1, ADS gas supply check valve 1131S fails to close	
AMHOA11		Failure of PS line B check valves (ADS gas supply)	
	HSADC3BA	ACY23EDR1, check valve 1023E fails to close	
	ACY23ADW1	check valve 1023X fails to close	
AMOA2		Containment isolation valve (29A) fails to close (fails gas supply, header A, to ADS valve)	
	ACDC9AT	APAL29A, false isolation signal closes valve	
	HSOC9AT	ACY25AMC1, isolation valve fails closed, NO-FC	

PROPRIETARY

TABLE N-1. (Continued)

~~PROBLEMS~~

PRA Event	ASER Event	Component/Explanation	Unavailability	ASER Event Unavailability Total
AM0811		Failure of PG line A check valves (ADS gas supply)		
	HSADCAAE	ACV23H01I, check valve 1023H fails to close		
		ACV23M01I, check valve 1023M fails to close		
		ACV23S01I, check valve 1023S fails to close		
AM082		Containment isolation valve (298) fails closed (fails gas supply header A, to ADS valve)		
	ACDC9BAU	AFAL298, false isolation signal closes		
	HSOC9BAU	ASL29BH01, isolation valve fails closed, NO-FC		
APGSA		Failure of ADS normal gas supply, Train A (Portion which is common with other events)		
	HSNGRABU	APPH3A0FI, ADS normal gas supply, header A rupture		
APGSA		Failure of ADS normal gas supply, Train A (Excluding events ACMA and common event APPH3A0FI)		
	HSNGSABW	ASV50A00I, failure of solenoid valve 150-A, NO-FC		
		AVVP1A0WI, globe/check valve fails closed		
APGSB		Failure of ADS normal gas supply, Train B (Portion which is common with other events)		
	HSNGRABBY	APPH3B0FI, ADS normal gas supply, header B ruptures		
APGSB		Failure of ADS normal gas supply, Train B (Excluding events ACMB and common event APPH3B0FI)		
	HSNGSBBI	ASV50B00I, failure of solenoid valve 150-B, NO-FC		
		AVVP1B0WI, globe/check valves fail closed		
APIA1		Failure of plant instrument air system, Train A (for ADS gas supply) (Portion excluding the APIA2 AND gate)		
	ESIAIAAL	AHY0010II, operator fails to open valve (common between both trains)		
	HMP1AAAP	AVV12BDWI, globe valves 1094A and 1095A		
	HSIAABAO	AVV1C0DWI, globe/check valve failure (common between both trains)		
	HSICCSAAS	APP1GA0FI, instrument gas system line A rupture, fails plant instrument air Train A also		
	HSPIAAAM	ASV2BA0FI, solenoid valve fails to open, NC-FC		
APIB1		Plant instrument air unavailable, Train B (for ADS gas supply) (Portion excluding the APIA2 AND gate)		
	ESIAIAAL	Defined under PRA event APIA1		
	HMP1ABAQ	AVV12BDWI, globe valves 1094B and 1095B fail closed		
	HSIAABAO	Defined under PRA event APIA1		
	HSIGCBAR	APP1GB0FI, instrument gas system B, line rupture, fails plant instrument air, Train B, also		
	HSPIABAM	ASV2BB0FI, solenoid valve fails to open, NC-FC		
APP1GA0FI	HSADRAAD	APP1GA0FI, point gas A header rupture (for ADS)		
APP1GB0FI	HSADRBAL	APP1GB0FI, point gas B header rupture (for ADS)		
APTA2		Containment isolation valve fails closed (fails point gas A, ADS gas supply)		
	ACDC1AAV	AFAL31A, false isolation signal closes valve		
	HSOC1AAV	ASVETAH01, isolation valve fails closed		
APTB2		Containment isolation valve fails closed (fails point gas B, ADS gas supply)		
	ACDC1BAW	AFAL31B, false isolation signal closes valve		
	HSOC1BAW	ASVETAH01, isolation valve fails closed		

TABLE X-1. (CONTINUED)

~~PROTECTED~~

PRA Event	ASER Event	Component/Explanation	Unavailability	ASER Event Unavailability Total
ARC	ESRME104	ARC, failure of normal MPC/RCIC room cooling equipment and the operator fails to establish a natural ventilation path for these rooms in the two to four hour range		
ASY1AB1		ADS valve #1 solenoid A fails		
	HSDS1ADA	ASY1AADY1, solenoid A fails		
		AC10ADW1, local signal failure (wire failure)		
	UNDG1BCD	AAS1110W1, ADS gas supply contaminated		
ASY1AB2		ADS valve #1 solenoid B unavailable		
	HSDS1BCP	ACA10B0W1, local signal failure (wire failure)		
		ASV1BCDY1, solenoid B fails		
	UNDG1BCD	Defined under PRA event ASY1AB1		
ASY2AB1		ADS valve #2 solenoid A fails		
	HSDS2ADE	ASY2AADY1, solenoid A fails		
		AC13ADW1, local signal failure (wire failure)		
	UNDG2BCD	AAS2110W1, ADS gas supply contaminated		
ASY2AB2		ADS valve #2 solenoid B unavailable		
	HSDS2BCS	ACA20B0W1, local signal failure (wire failure)		
		ASV2BCDY1, solenoid B fails		
	UNDG2BCT	Defined under PRA event ASY2AB1		
ASY3AB1		ADS valve #3 solenoid A fails		
	HSDS3ADA	ASY3AADY1, solenoid A fails		
		AC13ADW1, local signal failure (wire failure)		
	UNDG3BCY	AAS3110W1, ADS gas supply contaminated		
ASY3AB2		ADS valve #3 solenoid B unavailable		
	HSDS3BCU	ACA30B0W1, local signal failure (wire failure)		
		ASV3BCDY1, solenoid B fails		
	UNDG3BCY	Defined under PRA event ASY3AB1		
ASY4AB1		ADS valve #4 solenoid A fails		
	HSDS4ADE	ASY4AADY1, solenoid A fails		
		AC14ADW1, local signal failure (wire failure)		
	UNDG4BCJ	AAS4110W1, ADS gas supply contaminated		
ASY4AB2		ADS valve #4 solenoid B unavailable		
	HSDS4BCU	ACA40B0W1, local signal failure (wire failure)		
		ASV4BCDY1, solenoid B fails		
	UNDG4BCY	Defined under PRA event ASY4AB1		
ASY5AB1		ADS valve #5 solenoid A fails		
	HSDS5ADE	ASY5AADY1, solenoid A fails		
		AC15ADW1, local signal failure (wire failure)		
	UNDG5BCI	AAS5110W1, gas supply contaminated		
ASY5AB2		ADS valve #5 solenoid B unavailable		
	HSDS5BCY	ACA50B0W1, local signal failure (wire failure)		
		ASV5BCDY1, solenoid B fails		
	UNDG5BCI	Defined under PRA event ASY5AB1		

~~PROTECTED~~

TABLE MA1 - Continued

~~PROTECTED~~

PRA Event	ASER Event	Component/Explanation	Unavailability	ASER Event Unavailability Total
ASVSCAD1	HSINVABD	ASVSCAD1I, failure of solenoid valve 150A, NO-FD (ADS system)		
ASVSDOBM1	HSINVBBR	ASVSDOBM1I, failure of solenoid valve 150B, NO-FD (ADS system)		
ATMC1	TMADS10H	ADS valve #1 unavailable due to T&M given that HPCI is not down for maintenance		
ATMC2	TMADS20H	ADS valve #2 unavailable due to T&M given that HPCI and ADS valve #1 are not unavailable due to T&M		
ASTMC3	TMADS30H	ADS valve #3 unavailable due to T&M given that HPCI and ADS valves #1 and #2 are not unavailable due to T&M		
ATMC4	TMADS40P	ADS valve #4 unavailable due to T&M given that HPCI and ADS valves #1, #2 and #3 are not unavailable due to T&M		
ATMC5	TMADS50H	ADS valve #5 unavailable due to T&M given that HPCI and ADS valves #1, #2, #3 and #4 are not unavailable due to T&M		
AVVG11DWI	HSOP11CA	AVVG11DWI, check valve fails (fails ADS point gas supply)		
AVVG12DWI	HSOP12CB	AVVG12DWI, check valve fails (fails ADS point gas supply)		
AVVG13DWI	HSOP13CC	AVVG13DWI, check valve fails (fails ADS point gas supply)		
AVVG14DWI	HSOP14CD	AVVG14DWI, check valve fails (fails ADS point gas supply)		
AVVG15DWI	HSOP15CE	AVVG15DWI, check valve fails (fails ADS point gas supply)		
AVVH31DWI	HSOH31CF	AVVH31DWI, globe/check valves fail (fails header gas supply to ADS 1)		
AVVH32DWI	HSOH32CG	AVVH32DWI, globe/check valves fail (fails header gas supply to ADS 2)		
AVVH33DWI	HSOH33CH	AVVH33DWI, globe/check valves fail (fails header gas supply to ADS 3)		
AVVH34DWI	HSOH34CI	AVVH34DWI, globe/check valves fail (fails header gas supply to ADS 4)		
AVVH35DWI	HSOH35CJ	AVVH35DWI, globe/check valves fail (fails header gas supply to ADS 5)		
AVVH44DWI	HSOGC888	AVVH44DWI, globe/check valves fail closed (for ADS gas supply)		
AVVH48DWI	HSOGCAF	AVVH48DWI, globe/check valve fail closed (for ADS gas supply)		
AVVPZADW1	HSOGC88T	AVVPZADW1, globe/check valves fail closed, fails ADS point gas supply, Train A		
AVVPZ3DW1	HSOGC382	AVVPZ3DW1, globe/check valves fails closed, fails ADS point gas supply, Train B		
AV1		ADS valve 1 fails to open if available (Portion excluding the ASV1AB AND gate and event AV1B)		
	ENADCM0G	AMU1110XI, operator error during maintenance, disables valve		
	HSADS10H	AAV1PY0P1, pilot valve fails actuator		
		AAV1000P1, mechanical valve failure		
AY1AL		ADS valve 1SE line or accumulator rupture		
	HSO1DEAT	AAL1030FT, accumulator rupture		
		APPAS10FT, valve 1SE line rupture		
AY1B1		Gas supply to ADS valve #1 solenoids, blocked		
	HSOBVICK	AYV1B1ED01, manual globe valve fails closed		
		ACY36EDP1, check valve fails closed, NC-FC		
AY2		ADS valve #2 fails to open if available (Portion excluding the ASV2AB AND gate and event AV2B)		
	ENADCM0G	Defined under PRA event AV1		
	HSADS20H	AAV2PY0P1, pilot valve fails (actuator)		
		AAV2000P1, mechanical valve failure		
AY2AL		ADS valve 1SH line or accumulator rupture		
	HSO1SHA	AAL1030FT, accumulator rupture		
		APPAS10FT, valve 1SH line rupture		

~~PROTECTED~~

TABLE 4-1. Continued

~~PROBLEMS~~

PRA Event	ASER Event	Component/Explanation	Unavailability	ASER Event Unavailability Total
ASVSCADM	HSINVABD	ASV50ADM1, failure of solenoid valve 150A, NO-FO (ADS system)		
ASVSOBDM	HSINVBBR	ASV50ADM1, failure of solenoid valve 150B, NO-FO (ADS system)		
ATMC1	TMADSTDR	ADS valve #1 unavailable due to T&M given that HPCI is not down for maintenance		
ATMC2	TMADSDCR	ADS valve #2 unavailable due to T&M given that HPCI and ADS valve #1 are not unavailable due to T&M		
ATMC3	TMADSDC0	ADS valve #3 unavailable due to T&M given that HPCI and ADS valves #1 and #2 are not unavailable due to T&M		
ATMC4	TMADSDP	ADS valve #4 unavailable due to T&M given that HPCI and ADS valves #1, #2 and #3 are not unavailable due to T&M		
ATMC5	TMADSDC0	ADS valve #5 unavailable due to T&M given that HPCI and ADS valves #1, #2, #3 and #4 are not unavailable due to T&M		
AVVGT10WI	HSOP11CA	AVVGT10WI, check valve fails (fails ADS point gas supply)		
AVVGT20WI	HSOP12CB	AVVGT20WI, check valve fails (fails ADS point gas supply)		
AVVGT30WI	HSOP13CC	AVVGT30WI, check valve fails (fails ADS point gas supply)		
AVVGT40WI	HSOP14CD	AVVGT40WI, check valve fails (fails ADS point gas supply)		
AVVGT50WI	HSOP15CE	AVVGT50WI, check valve fails (fails ADS point gas supply)		
AVVH310WI	HSOH31CF	AVVH310WI, globe/check valves fail (fails header gas supply to ADS 1)		
AVVH320WI	HSOH32CG	AVVH320WI, globe/check valves fail (fails header gas supply to ADS 2)		
AVVH330WI	HSOH33CH	AVVH330WI, globe/check valves fail (fails header gas supply to ADS 3)		
AVVH340WI	HSOH34CI	AVVH340WI, globe/check valves fail (fails header gas supply to ADS 4)		
AVVH350WI	HSOH35CJ	AVVH350WI, globe/check valves fail (fails header gas supply to ADS 5)		
AVVH460WI	HSOGC888	AVVH460WI, globe/check valves fail closed (for ADS gas supply)		
AVVH480WI	HSOGCAF	AVVH480WI, globe/check valve fail closed (for ADS gas supply)		
AVVPAZ0WI	HSOGCAET	AVVPAZ0WI, globe/check valves fail closed, fails ADS point gas supply, Train A		
AVVPAZ0WI	HSOGC38Z	AVVPAZ0WI, globe/check valves fails closed, fails ADS point gas supply, Train B		
AV1		ADS valve 1 fails to open if available (Portion excluding the ASV1AB AND gate and event AV1B)		
	ENADCM06	AHU1110XI, operator error during maintenance, disables valve		
	HSADSDH	AAV1PY0PI, pilot valve fails actuator		
		AAV1000PI, mechanical valve failure		
AV1A1		ADS valve 1SE line or accumulator rupture		
	HSO13EAT	AAL1030FI, accumulator rupture		
		APPAB310FI, valve 1SE line rupture		
AV1B1		Gas supply to ADS valve #1 solenoids, blocked		
	HSOBVICK	ACY18BED01, manual globe valve fails closed		
		ACY36EDPI, check valve fails closed, NC-FC		
AV2		ADS valve #2 fails to open if available (Portion excluding the ASV2AB AND gate and event AV2B)		
	ENADCM06	Defined under PRA event AV1		
	HSADSDZ01	AAV2PY0PI, pilot valve fails (actuator)		
		AAV2000PI, mechanical valve failure		
AV2A1		ADS valve 1SH line or accumulator rupture		
	HSO13HAF	AAL1020FI, accumulator rupture		
		APPAB30FI, valve 1SH line rupture		

~~PROBLEMS~~

TABLE MATL - Continued

PRA Event	ASEP Event	Component/Explanation	Unavailability	ASEP Event Unavailability Total
AV281		Gas supply to ADS valve #2 solenoids, blocked		
	+SD8V2CL	AIV18H001, manual globe valve fails closed		
		ACV36H001, check valve fails closed, NC-FC		
AV3		ADS valve #3 fails to open if available (Portion excluding the ASVSAB AND gate and event AV38)		
	+SA0S3D01	AAV3PV001, pilot valve fails (actuator)		
		AAV300001, mechanical valve failure		
	ENADCM06	Defined under PRA event AV1		
AV4A1		ADS valve 13K line or accumulator rupture		
	+SD12KA1	AAL30300FL, accumulator rupture		
		APP43300FI, valve 13K line rupture		
AV281		Gas supply to ADS valve #3 solenoids, blocked		
	+SD8V3CH	AIV18K001, manual globe valve fails closed		
		ACV36K001, check valve fails closed, NC-FC		
AV4		ADS valve #4 fails to available (Portion excluding the ASVAAB AND gate and event AV48)		
	ENADCM06	Defined under PRA event AV1		
	+SA0S4D01	AAV4PV001, pilot valve fails (actuator)		
		AAV400001, mechanical valve failure		
AV4A1		ADS valve 13M line or accumulator rupture		
	+SD12PA8	AAL40300FI, accumulator rupture		
		APP43400FI, valve 13M line rupture		
AV481		Gas supply to ADS valve #4 solenoids, blocked		
	+SD8V4CH	AIV18M001, manual globe valve fails closed		
		ACV18C001, check valve fails closed, NC-FC		
AV5		ADS valve #5 fails to available (Portion excluding the ASVSAB AND gate and event AV58)		
	ENADCM06	Defined under PRA event AV1		
	+SA0S5D01	AAV5PV001, pilot valve fails (actuator)		
		AAV500001, mechanical failure		
AV5A1		ADS valve 13S line or accumulator rupture		
	+SD12SA1	AAL50300FI, accumulator rupture		
		APP43500FI, valve 13S line rupture		
AV581		Gas supply blocked to ADS valve #5 solenoids		
	+SD8V5CO	AIV18S001, manual globe valve fails closed		
		ACV36SD01, check valve fails closed, NC-FC		
CMDF	CMDHAL01	CMDF, common mode diesel failure		
DAT	TMC11ATO	DAT, LPCI pump Train A unavailable due to maintenance given that LPCS loads 1 and 2, and all diesels are not in maintenance		
DBT	TMC12BTO	DBT, LPCI pump Train B unavailable due to maintenance given that LPCI pump Trains A and C, LPCS loads 1 and 2, and all diesels are not in maintenance		
DCROSSAB1		Failure of cooling tower crossover valves (ESW)		
	DMV17SD01	DMV17SD01, motor operated butterfly valve, NC-FC		
	DMV17AD01	DMV17AD01, motor operated butterfly valve, NC-FC		

TABLE X-1 Continued

PRA Event	ASER Event	Component/Explanation	UNAVAILABILITY	ASER Event Unavailability Total
DCROSSAB2		Failure of 10mV bond crossover valves (ESM)		
	HSCRESIES	DMW34BDPI, motor operated butterfly valve, MC-FC		
		DMW34ADPI, motor operated butterfly valve, MC-FC		
DCT	TMCIICB3	DCT, LPCI pump Train C unavailable due to maintenance given that LPCS Loops 1 and 2, and all diesels are not in maintenance		
DOA2		Discharge valves to LPCI injection loop 1, pump Train A, fail closed (Excluding event EAC440A)		
	HSC11ARI	DCY65AD001, discharge valve fails closed, MLO-FC		
		DCY41AD001, discharge check valve stuck closed		
		DMW17AD001, discharge MOV fails closed, MC-FC		
	HSC11ARJ	OPPO2AHFI, pipe rupture occurs in discharge line of loop 1, pump Train A		
DOB2		Discharge valves to LPCI injection loop 2, pump Train B, fail closed (Excluding event EAC440B)		
	HSC12BRF	DCY64AD001, discharge valve fails closed, MLO-FC		
		DCY41BD001, discharge check valve stuck closed		
		DMW17BD001, discharge MOV fails closed, MC-FC		
	HSC12BRG	OPPO2BHFI, pipe rupture occurs in discharge line of loop 2, pump Train B		
DOC2		Discharge valves to LPCI injection, loop 1, pump Train C, fail closed (Excluding event EAC440C)		
	HSC11CRW	OPPO2CHFI, pipe rupture in discharge line of pump Train C		
		DCY65CD001, discharge valve fails closed, MLO-FC		
		DMW17CD001, discharge MOV fails closed, MC-FC		
		DCY41CD001, discharge check valve stuck closed		
DOC2		Discharge valves to LPCI injection, loop 2, pump Train D, fail closed (Excluding event EAC440D)		
	HSC12DRU	OPPO2DHFI, pipe rupture in discharge line of pump Train D		
		DCY65D0001, discharge valve fails closed, MLO-FC		
		DMW17DD001, discharge MOV fails closed, MC-FC		
		DCY41DD001, discharge check valve stuck closed		
DOIFFA		Failure of differential pressure permissive, fails LPCI pump Train A, loop 1		
	ENCLCHRA	DMW9190XII, miscalibration of pressure channels (channel 58)		
	HSC1PARA	OPR5BAHFI, failure of pressure sensor S8A		
		DRE5BAHFI, failure of pressure relay logic		
DOIFFB		Failure of differential pressure permissive, fails LPCI pump Train B, loop 2		
	ENCLCHRA	Defined under PRA event DOIFFA		
	HSC1PBRB	OPR5BBHFI, failure of pressure sensor S8B		
		DRE5BBHFI, failure of pressure relay logic		
DOIFFC		Failure of differential pressure permissive, fails pump Train C, loop 1		
	ENCLCHRA	Defined under PRA event DOIFFA		
	HSC1PCRC	OPR5BCHFI, failure of pressure sensor S8C		
		DRE5BCHFI, failure of pressure relay logic		

TABLE IV-1. (CONTINUED)

PRA Event	ASEP Event	Component Explanation	Availability	ASME Event Availability Data
DOLFFO		Failure of differential pressure permissive, fails open Train D, Loop 2		
	ENSCMRA	Defined under PRA event DOLFFA		
	HSCIPD0	OPPS80HWI, failure of pressure sensor 880		
		OPRE80HWI, failure of pressure relay logic		
DOT	THC120TQA	DOT, LPCI pump Train D unavailable due to maintenance given that LPCI pump Trains A and C, LPCL loops 1 and 2, and all diesels are not in maintenance		
DFAPA		Failure of LPCI alternate path (through pump Train A) for pump Train C (Excluding events DR1ZA, DPPMA0, EAC440A)		
	ESCI1TRY	OHU0300II, failure of operator to realign valves		
	HSCI1TRY	OCV3180II, pump discharge check valve fails to prevent flow		
	HSI1ATRY	OMV62AD0I, MOV crossover valve fails closed (F182A), NO-FC		
	HSI1AZRY	OMV03AD0I, MOV fails closed (F003A) NO-FC		
DFAPB		Failure of LPCI alternate path (through pump Train B) for pump Train D (Excluding events DR1ZB, DPPMB0, EAC440B)		
	ESCI2TRY	OHU0300II, failure of operator to realign valves		
	HSCI2TRY	OCV3180II, pump discharge check valve fails to prevent flow		
	HSI2B1RT	OMV62AD0I, MOV crossover valve fails closed (F182B), NO-FC		
	HSI2B2RI	OMV03AD0I, MOV fails closed (F003B) NO-FC		
DFAPC		Failure of LPCI alternate path (through pump Train C) for pump Train A (Excluding events DFMP0 and EAC440C)		
	ESCI1ARZ	OHU02AD0II, failure of operator to manually realign valves		
	HSI1ATRY	Defined under PRA event DFAPA		
	HSI1ATRZ	OMV1010AII, MOV F010A fails open, NO-FO		
	HSI1AZRZ	OMV47AD0I, MOV F047A fails closed, NO-FC		
	HSI1CTRZ	OCV31C0II, pump discharge check valve fails to prevent flow		
DFAPD		Failure of LPCI alternate path (through pump Train D) for pump Train B (Excluding events DFMP0 and EAC440D)		
	ESCI2BRI	OHU02YD0II, failure of operator to manually realign valves		
	HSI2B1RT	Defined under PRA event DFAPB		
	HSI2B1RI	OMV1010BII, MOV F010B fails open, NO-FO		
	HSI2B2RI	OMV47BD0I, MOV F047 fails closed, NO-FC		
	HSI2CTRZ	OCV31C0II, pump discharge check valve fails to prevent flow		
DFCTA1		Valves to cooling tower unit 1 fails (ESW) (Portions excluding DCROSSAB events)		
DFCTA1	HSRESTEM	OMV114600, cooling tower lower MOV butterfly valve, NO-FC		
		OMV1110PI, motor operated butterfly valve, NO-FO		
		OMV1110PI, motor operated butterfly valve, NO-FO		
DFCTA2		Valves to cooling tower unit 2 fails (ESW) (Portions excluding DCROSSAB)		
DFCTA2	HSRESTEM	OMV114600, cooling tower lower MOV butterfly valve, NO-FC		
		OMV1110PI, motor operated butterfly valve, NO-FO		
		OMV1110PI, motor operated butterfly valve, NO-FO		

TABLE N-1. (CONTINUED)

PRA Event	ASID Event	Component/Explanation	Initial Probability	ASER Event Initial Probability Total
DEFH1A		Failure of flow through LPCI heat exchanger A		
	HSIM1A8A	DM101AHE1, Heat exchanger A plugged		
	HS11A2RY	Defined under PRA event DEFAP		
	HS11A2RZ	Defined under PRA event DEFAPC		
DEFH1B		Failure of flow through LPCI heat exchanger B		
	HSIM1BRY	DM101BHE1, heat exchanger plugged		
	HS12B2RT	Defined under PRA event DEFAPB		
	HS12B2RZ	Defined under PRA event DEFAPC		
DFLO1AHE1	HSIP1A8E	DFLO1AHE1, single strainer 1A blockage/failure (LPCI suction from SP)		
DFLO2AHE1	HSIP2A8D	DFLO2AHE1, single strainer 2A blockage/failure (LPCI suction from SP)		
DFLO1BHE1	HSIP1B8H	DFLO1BHE1, single strainer 1B blockage/failure (LPCI suction from SP)		
DFLO2BHE1	HSIP2B8G	DFLO2BHE1, single strainer 2B blockage/failure (LPCI suction from SP)		
DFLO1CHE1	HSIP1C8K	DFLO1CHE1, single strainer 1C blockage/failure (LPCI suction from SP)		
DFLO2CHE1	HSIP2C8J	DFLO2CHE1, single strainer 2C blockage/failure (LPCI suction from SP)		
DFLO1DHE1	HSIP1D8K	DFLO1DHE1, single strainer 1D blockage/failure (LPCI suction from SP)		
DFLO2DHE1	HSIP2D8M	DFLO2DHE1, single strainer 2D blockage/failure (LPCI suction from SP)		
DFPH1A		Flow diverted from LPCI pump Train A to suppression pool (SP)		
	HSC11ARR	DMW24A001, NOV, NC-FO		
		DMW27A001, valve to SP spray header, NC-FO		
DFPH1B		Flow diverted from LPCI pump Train B to suppression pool (SP)		
	HSC12BRA	DMW24B001, NOV, NC-FO		
		DMW27B001, valve to SP spray header, NC-FO		
DMU102011	ESCI1XRE	DMU102011, failure to manually open discharge valves (loop 2, pump Train 3 and 4) or operator fails to realign pump Train A and/or B for injection via the recirculation loop (LPCI)		
DICT1		Failure of discharge valves from cooling tower #1 (ESW)		
	HSRE1ST0G	DMW1120P1, motor operated butterfly valve, NO-FO		
		DMW1140P1, motor operated butterfly valve, NO-FO		
DICT2		Failure of discharge valves from cooling tower #2 (ESW)		
	HSRE1STP	DMW2120P1, motor operated butterfly valve, NO-FO		
		DMW2140P1, motor operated butterfly valve, NO-FO		
DMW005001	HSRE1SWF	DMW005001, failure of motor operated connecting sluice gate, NO-FO		
DMW03A001	HSRE1SWB	DMW03A001, ESW sluice gate 1A to vit pit fails, NO-FO		
DMW03B001	HSRE1SWD	DMW03B001, ESW sluice gate 3B to vit pit fails, NO-FO		
DMW03C001	HSRE1SEA	DMW03C001, ESW sluice gate 3C to vit pit fails, NO-FO		
DMW03D001	HSRE1SWE	DMW03D001, ESW sluice gate 3D to vit pit fails, NO-FO		
DMW16A001	HS111A8D	DMW16A001, LPCI NOV in loop #1, NC-FO		
DMW16B001	HSC12BRH	DMW16B001, LPCI NOV in loop #2, NC-FO		
DMW21A001	HSC11ARR	DMW21A001, LPCI NOV in loop #1, NC-FO		
DMW21B001	HSC12BRU	DMW21B001, LPCI NOV in loop #2, NC-FO		
DMW22A001	HSRE1SWC	DMW22A001, ESW motor operated butterfly valve, NO-FO		
DMW22B001	HSRE1SWE	DMW22B001, ESW motor operated butterfly valve, NO-FO		
DMW22C001	HSRE1SWG	DMW22C001, ESW motor operated butterfly valve, NO-FO		

TABLE N-1... Continued

~~PROPRIETARY~~

PRA Event	ASCP Event	Component Explanation	Unavailability	ASCP Event Unavailability Total
DMV22001	ASAE2WEX	DMV220011, ESW motor operated butterfly valve, NO-FC		
DMV48A001	HSCLINASE	DMV48A0011, ESW motor operated butterfly valve fails closed, NO-FC		
DMV48B001	HSCLINBSB	DMV48B0011, ESW motor operated butterfly valve fails closed, NO-FC		
OPMAU1A		Loss of LPCI pump A auxiliaries (Excluding events EAC440A and KSHA)		
	AMR12AST	ARMELL1A, failure of pump A room cooling equipment		
	HSIL12AST	OLUBED1A, loss of lubrication for pump A		
OPMAU1B		Loss of LPCI pump B auxiliaries (Excluding events EAC440B and KSB)		
	AMR12BSA	KRMELL1B, failure of pump __ room cooling equipment		
	HSIL12BSA	OLUBED1B, loss of lubrication for pump B		
OPMC1		Failure of LPCI pump Train C to provide adequate head (Excluding events OPMC10)		
	HSC11CSV	DCV31COP1, pump C check valve fails, stuck closed		
	OPM02C0W1	pump C fails to start or run		
OPMC10		Loss of LPCI pump C auxiliaries (Excluding events EAC440C and KSH)		
	AMR12CSU	KRMELL1C, failure of pump C room cooling equipment		
	HSIL12CSU	OLUBED1C, loss of lubrication for pump C		
OPMC11		Failure of LPCI pump Train D to provide adequate head (Excluding events OPMC10)		
	HSC12DSI	DCV31DOP1, pump D check valve fails, stuck closed		
	OPM02D0W1	pump D fails to start or run		
OPMC10		Loss of LPCI pump D auxiliaries (Excluding events EAC440D and KSD)		
	AMR12DSU	KRMELL1D, failure of pump D room cooling equipment		
	HSIL12DSU	OLUBED1D, loss of lubrication for pump D		
OPMC12		Failure of LPCI pump Train A to provide adequate head (Excluding events OPMAU1A)		
	HSC11ASZ	DCV31AOP1, pump A check valve fails, stuck closed		
	OPM02A0W1	pump A fails to start or run		
OPMC12		Failure of LPCI pump Train B to provide adequate head (Excluding events OPMAU1B)		
	HSC12BSA	DCV31BOP1, pump B check valve fails, stuck closed		
	OPM02B0W1	pump B fails to start or run		
OPSL0W	JARSHWE	OPSL0W, spray pond water level insufficient (ESW)		
DR11A		Failure of flow to enter Rx vessel via recirculation loop (loop 1, pump Train A, LPCI)		
	ESCL1IRE	Defined under PRA event DMU10203I		
	HSC11ARK	DCV50A0011, manual valve, NO-FC		
		DCV50AOP1, air operated check valve fails, stuck closed		
		DMV15AOP1, NOV, NO-FC		
DR11B		Failure of flow to enter Rx vessel via recirculation loop (loop 2, pump Train B, LPCI)		
	ESCL1IRE	Defined under PRA event DMU10203I		
	HSC11BRW	DCV50B0011, manual valve, NO-FC		
		DCV50BOP1, air operated check valve fails, stuck closed		
		DMV15BOP1, NOV, NO-FC		

~~PROPRIETARY~~
PRA-10203I-08
Planned by

TABLE N-11 (CONTINUED)

~~PROPRIETARY~~

PRA Event	ASER Event	Component Explanation	Unavailability	ASER Event Unavailability Total
DSTA		Insufficient flow from SP strainer to LPCI pump A (Excluding event LSP and the DSTA2 AND gate)		
	HSC1PASR	OPPO1BHFI, pipe rupture in suction line LW04AC001, suction MOV, NO-FC		
DSTAB		LPCI alternate path A: failure to provide flow to pump 3 (Excluding event DSTA)		
	ESCICTSP	OPM01AD01, failure to manually initiate the opening of the crossover valves		
	HSITGASR	OPM06AD01, crossover MOV, NC-FC		
	HSIT6BS0	OPM06BD01, crossover MOV, NC-FC		
DSTAC		LPCI alternate path A: failure to provide flow to pump C (Excluding event)		
	ESCICTSP	Defined under PRA event DSTAB		
	HSIT6ASR	Defined under PRA event DSTAB		
	HSIT7ASP	QIV67AD01, crossover manual valve (067A), NLC-FC		
DSTAD		LPCI alternate path A: failure to provide flow to pump D		
	ESCICTSP	Defined under PRA event DSTAB		
	HSIT7BSP	QIV67BD01, crossover manual valve (067B), NLC-FC		
	HSIT8ASR	Defined under PRA event DSTAB		
DSTB		Insufficient flow from SP strainer to LPCI pump B (Excluding event LSP and the DSTB2 AND gate)		
	HSC1PBSI	OPPO1BHFI, pipe rupture in suction line LW04AB001, suction MOV, NO-FC		
DSTBA		LPCI alternate path B: failure to provide flow to pump A (Excluding event DSTB)		
	ESCICTSP	Defined under PRA event DSTAB		
	HSIT6ASR	Defined under PRA event DSTAB		
	HSIT6BS0	Defined under PRA event DSTAB		
DSTBC		LPCI alternate path B: failure to provide flow to pump C		
	ESCICTSP	Defined under PRA event DSTAB		
	HSIT6BS0	Defined under PRA event DSTAB		
	HSIT7ASP	Defined under PRA event DSTAC		
DSTBD		LPCI alternate path B: failure to provide flow to pump D (Excluding event DSTB)		
	ESCICTSP	Defined under PRA event DSTAB		
	HSIT6BS0	Defined under PRA event DSTAB		
	HSIT7BSP	Defined under PRA event DSTAB		
DSTC		Insufficient flow from SP strainer to LPCI pump C (Excluding events LSP and the DSTC2 AND gate)		
	HSC1PCSL	OPPO1CHFI, pipe rupture in suction line LW04AC001, suction MOV, NO-FC		
DSTCA		LPCI alternate path C: failure to provide flow to pump A (Excluding event DSTC)		
	ESCICTSP	Defined under PRA event DSTAB		
	HSIT6ASR	Defined under PRA event DSTAB		
	HSIT7ASP	Defined under PRA event DSTAC		

~~PROPRIETARY~~

TABLE N-1. Continued

PRA Event	ASER Event	Component/Explanation	Unavailability	ASER Event Unavailability Total
DSTC3		LPCI alternate path C: failure to provide flow to pump 3 (Excluding event DSTC)		
	ESCICTSP	Defined under PRA event DSTAB		
	HSIT68SQ	Defined under PRA event DSTAB		
	HSIT7ASP	Defined under PRA event DSTAC		
DSTC0		LPCI alternate path C: failure to provide flow to pump 0 (Excluding event DSTC)		
	ESCICTSP	Defined under PRA event DSTAB		
	HSIT7ASP	Defined under PRA event DSTAC		
	HSIT7BSP	Defined under PRA event DSTAD		
DSTD0		Insufficient flow from SP strainer to LPCI pump 0 (Excluding event LSP and the DSTD2 AND gate)		
	HSCIP0SO	OPPOSITIONFI, pipe rupture in suction line LW04000I, suction MNV, NO-FO		
DSTDA		LPCI alternate path D: failure to provide flow to pump A (Excluding event DSTD)		
	ESCICTSP	Defined under PRA event DSTAB		
	HSITGASR	Defined under PRA event DSTAB		
	HSIT7BSP	Defined under PRA event DSTAD		
DSTDB		LPCI alternate path D: failure to provide flow to pump B (Excluding event DSTD)		
	ESCICTSP	Defined under PRA event DSTAB		
	HSIT58SQ	Defined under PRA event DSTAB		
	HSIT7BSP	Defined under PRA event DSTAD		
DSTDC		LPCI alternate path D: failure to provide flow to pump C (Excluding event DSTD)		
	ESCICTSP	Defined under PRA event DSTAB		
	HSIT7ASP	Defined under PRA event DSTAC		
	HSIT7BSP	Defined under PRA event DSTAD		
EABUS	HS01VIGS	EABUS, local electrical failure of ventilation system (fails ventilation system A and B for room cooling for DG 11)		
EACAZ		Power from DG 11 unavailability (Excluding event EDGA)		
	AC0G11JA	ES40110WI, failure to make automatic transfer for DG 11 start		
	HS0611JA	EC45070WI, short in power cable from generator EC26070WI, circuit breaker fails, NO-FO		
EACZ2		Power from DG 12 unavailability (Excluding event EDGZ)		
	AC0612JC	ES40120WI, failure to make automatic transfer for DG 12 start		
	HS0612JC	EC46070WI, short in power cable from generator EC26070WI, circuit breaker fails, NO-FO		
EACZ2		Power from DG 13 unavailability (Excluding event EDGZ)		
	AC0G12JE	ES40120WI, failure to make automatic transfer for DG 12 start		
	HS0612JE	EC47070WI, short in power cable from generator EC27070WI, circuit breaker fails, NO-FO		

TABLE X-1. (Continued)

~~PROBZAR~~

PRA Event	ASER Event	Component/Explanation	Unavailability	ASER Event Unavailability Total
EAC02		Power from DG 14 unavailable (Excluding event EDG0)		
	ACDG14UG	ESW0140WI, failure to make automatic transfer for DG 14 start		
	HSOG14UG	ECAB07DWI, short in power from generator EC3B07DWI, circuit breaker fails, NC-FO		
EAC14A		Loss of 440 Vac bus, EPS Division I (Excluding event EAC1)		
	HS4401JI	EXT102DWI, voltage transformer failure EBS1140WI, 440 Vac bus or switchgear unavailable EC9545DWI, bus transformer breaker failure, NC-FO		
EAC14B		Loss of 440 Vac bus, EPS Division II (Excluding event EAC1)		
	HS4402JJ	EXT202DWI, voltage transformer failure EC8605DWI, bus transformer breaker failure, NC-FO EBS1240WI, 440 Vac bus or switchgear unavailable		
EAC14C		Loss of 440 Vac bus, EPS Division III (Excluding event EAC1)		
	HS4403JK	EXT303DWI, voltage transformer failure EC9705DWI, bus transformer breaker failure, NC-FO EBS1340WI, 440 Vac bus or switchgear unavailable		
EAC14D		Loss of 440 Vac bus, EPS Division IV		
	HS4404JL	EXT402DWI, voltage transformer failure EC8805DWI, bus transformer breaker failure, NC-FO EBS1440WI, 440 Vac bus or switchgear unavailable		
EALL	TM0050IM	EALL, all diesels fail to start during test, plant being shutdown		
EABUS	HS02YXH	EABUS, local electrical failure of ventilation system (fails ventilation system A and B for room cooling for DG 12)		
EBS0110WI	HS01SGJB	EBS0110WI, 4 KVac bus or switchgear for EPS Divisions I (DG 11) unavailable		
EBS0120WI	HS02SGJD	EBS0120WI, 4 KVac bus or switchgear for EPS Divisions II (DG 12) unavailable		
EBS0130WI	HS01SGJF	EBS0130WI, 4 KVac bus or switchgear for EPS Divisions III (DG 13) unavailable		
EBS0140WI	HS02SGJF	EBS0140WI, 4 KVac bus or switchgear for EPS Divisions IV (DG 14) unavailable		
EBS25ADWI	HS02C01JU	EBS25ADWI, failure of 250/125 Vac bus (EPS Division I)		
EBS25BDWI	HS02C02JY	EBS25BDWI, failure of 250/125 Vac bus (EPS Division II)		
EBS25CDWI	HS02C03JS	EBS25CDWI, failure of 125 Vac bus (EPS Division III)		
EBS25DDWI	HS02C04JT	EBS25DDWI, failure of 125 Vac bus (EPS Division IV)		
EBCBUS	HS03VXHJ	EBCBUS, local electrical failure of ventilation system (fails ventilation system A and B for room cooling for DG 13)		
EBCBUS	HS04VXHR	EBCBUS, local electrical failure of ventilation system (fails ventilation system A and B for room cooling for DG 14)		
EDGA21		Failure of exhaust ventilation damper system A (applies to room cooling for DG 11)		
	HS01VAGR	KDP1000PI, exhaust damper stuck closed KDP1000WI, exhaust damper for room ventilation fails to function		

~~PROBZAR~~

TABLE 4A - Continued

~~PROTECTED~~

PRA Event	ASEP Event	Component Explanation	Availability	ASEP Event Unavailability Total
E00AZ1		Failure of exhaust ventilation damper 5 (applies to room cooling for SG 11)		
	HSD1V8G0	KOP200DPI, exhaust damper closed		
		KOP200HWI, exhaust damper for room ventilation fails to function		
E00BZ1		Failure of exhaust ventilation damper system A (applies to room cooling for SG 12)		
	HSD2V8A0	KOP101DPI, exhaust damper stuck closed		
		KOP101HWI, exhaust damper for room ventilation fails to function		
E00BZ2		Failure of exhaust ventilation damper 8 (applies to room cooling for SG 12)		
	HSD2V8G1	KOP201DPI, exhaust damper closed		
		KOP201HWI, exhaust damper for room ventilation fails to function		
E00CZ1		Failure of exhaust ventilation damper 5 stem A (applies to room cooling for SG 13)		
	HSD3V8A1	KOP102DPI, exhaust damper stuck closed		
		KOP102HWI, exhaust damper for room ventilation fails to function		
E00CZ2		Failure of exhaust ventilation damper 8 (applies to room cooling for SG 13)		
	HSD3V8B0	KOP202DPI, exhaust damper closed		
		KOP202HWI, exhaust damper for room ventilation fails to function		
E00CZ1		Failure of exhaust ventilation damper, system A (applies to room cooling for SG 14)		
	HSD4V8A0	KOP103DPI, exhaust damper stuck closed		
		KOP103HWI, exhaust damper for room ventilation fails to function		
E00CZ2		Failure of exhaust ventilation damper 8 (applies to room cooling for SG 14)		
	HSD4V8B0	KOP203DPI, exhaust damper closed		
		KOP203HWI, exhaust damper for room ventilation fails to function		
E00GZ1		Failure of the normal ESW loop for SG 11 (Excluding the transfer from the ESW fault tree)		
	HSD1NHWI	Failure of the SW inlet or outlet valve for the ESW loop to SG 11		
	HWY32A001	Failure of the SW discharge valve, NO-FC		
	HWY31A001	Failure of the SW inlet valve, NO-FC		
	HSD1S001	WEY05A001, failure of manual valve 1005A		
E00GZ1		Failure of the normal ESW loop for SG 12 (Excluding the transfer from the ESW fault tree)		
	HSD2NHWI	Failure of the SW inlet or outlet valve for the ESW loop to SG 12		
	HWY34B001	Failure of the SW discharge valve, NO-FC		
	HWY33B001	Failure of the SW inlet valve, NO-FC		
	HSD2SW18	WEY05B001, failure of manual valve 1005B		
E00GZ1		Failure of the normal ESW loop for SG 13 (Excluding the transfer from the ESW fault tree)		
	HSD3NHWI	Failure of the SW inlet or outlet valve for the ESW loop to SG 13		
	HWY32C001	Failure of the SW discharge valve, NO-FC		
	HWY31C001	Failure of the SW inlet valve, NO-FC		
	HSD3SW18	WEY05C001, failure of manual valve 1005C		

TABLE N-1. Continued

~~PROTECTED~~

PRA Event	ASCP Event	Component Explanation	Availability	ASCP Event Unavailability Total
EDGCT0		Failure of the normal ESW loop for DG 14 (Excluding the transfer from the ESW fault tree)		
	HSDAWH1	Failure of the SW inlet or outlet valve for the ESW loop to DG 14 MW340001, failure of the SW discharge valve, NC-FC		
		MW330001, failure of the SW inlet valve, NC-FC		
	HSDASW12	MEY050001, Failure of manual valve 10050		
EDGC2A		Failure of the alternate ESW loop for DG 11 (Excluding the transfer from the ESW fault tree)		
	ESDIAWH	MHU1, operator fails to make transfer		
	HSDIAWHY	Failure of the SW inlet or outlet valve for the ESW to DG 11 MW34ADP1, failure of SW discharge valve, NC-FC		
		MW33ADP1, failure of SW inlet valve, NC-FC		
	HSDISW12	Defined under PRA event EDGC1A		
EDGC2B		Failure of the alternate ESW loop for DG 12 (Excluding the transfer from the ESW fault tree)		
	ESDZAW1A	MHU2, operator fails to make transfer		
	HSDZAWIC	Failure of the SW inlet or outlet valve for the ESW to DG 12 MW32SDP1, failure of SW discharge valve, NC-FC		
		MW31SDP1, failure of SW inlet valve, NC-FC		
	HSDZSW13	Defined under PRA event EDGC1B		
EDGC2C		Failure of the alternate ESW loop for DG 13 (Excluding the transfer from the ESW fault tree)		
	ESDZAW1E	MHU3, operator fails to make transfer		
	HSDZAW1G	Failure of the SW inlet or outlet valve for the ESW to DG 13 MW34CDP1, failure of SW discharge valve, NC-FC		
		MW33CDP1, failure of SW inlet valve, NC-FC		
	HSDZSW1F	Defined under PRA event EDGC1C		
EDGC2D		Failure of the alternate ESW loop for DG 14 (Excluding the transfer from the ESW fault tree)		
	ESDZAW1H	MHU4, operator fails to make transfer		
	HSDZAW1X	Failure of the SW inlet or outlet valve for the ESW to DG 14 MW3200P1, failure of SW discharge valve, NC-FC		
		MW3100P1, failure of SW inlet valve, NC-FC		
	HSDASW12	Defined under PRA event EDGC1D		
EDGREPA	RC061110	Failure to repair DG 11 given failure or maintenance		
EDGREPB	RC061210	Failure to repair DG 12 given failure or maintenance		
EDGREPC	RC061315	Failure to repair DG 13 given failure or maintenance		
EDGREPD	RC061410	Failure to repair DG 14 given failure or maintenance		
ED611		DG 11 hardware failures		
	HSD611IN	EGE0110W1, generator failure		
		EDU0110X1, DG 11 in improper mode		
		ED11CNO, failure of DG 11 to start and run (from Appendix A of PRA text)		

TABLE IV. (Continued)

~~PROBABILITY~~

PRA Event	ASER Event	Component/Explanation	Unavailability	ASER Event Unavailability/Total
ED612		DE 12 hardware failures		
	HSD612IR	EGED120W1, generator failure EHUD120H1, DE 12 in improper mode ED12CNO, failure of DE 12 to start and run (from Appendix A of PRA text)		
ED613		DE 13 hardware failures		
	HSD613IR	EGED130W1, generator failure EHUD130H1, DE 13 in improper mode ED13CNO, failure of DE 13 to start and run (from Appendix A of PRA text)		
ED614		DE 14 hardware failures		
	HSD614IR	EGED140W1, generator failure EHUD140H1, DE 14 in improper mode ED14CNO, failure of DE 14 to start and run (from Appendix A of PRA text)		
ELCC01		Loss of charge circuit, EPS Division I, Loop 1 (Excluding event EAC440A)		
	HSDC01IR	ECAZAZ0W1, power cable from 440 Vac MCC to charger broken EBCCA0W1, charger unavailable		
ELCC02		Loss of charge circuit, EPS Division I, Loop 2 (Excluding event EAC440A)		
	HSDC02IR	ECAZAZ0W1, power cable from 440 Vac MCC to charger broken EBCCA0W1, charger unavailable		
ELCC03		Loss of charge circuit, EPS Division II, Loop 1 (Excluding event EAC440B)		
	HSDC03IR	ECAZBT0W1, power cable from 440 Vac MCC to charger broken EBCCBT0W1, charger unavailable		
ELCC04		Loss of charge circuit, EPS Division II, Loop 2 (Excluding event EAC440B)		
	HSDC04IR	ECAZBT0W1, power cable from 440 Vac MCC to charger broken EBCCBT0W1, charger unavailable		
ELCC05		Loss of charge circuit, EPS Division III, Loop 1 (Excluding event EAC440C)		
	HSDC05IR	ECAZBT0W1, power cable from 440 Vac MCC to charger broken EBCCBT0W1, charger unavailable		
ELCC06		Loss of charge circuit, EPS Division IV, Loop 1 (Excluding event EAC440D)		
	HSDC06IR	ECAZBT0W1, power cable from 440 Vac MCC to charger broken EBCCBT0W1, charger unavailable		
EOSPA	HMPD01W	EOSPA, loss of offsite power sources, EPS Division I		
EOSPB	HMPD02W	EOSPB, loss of offsite power sources, EPS Division II		
EOSPC	HMPD03W	EOSPC, loss of offsite power sources, EPS Division III		
EOSPD	HMPD04W	EOSPD, loss of offsite power sources, EPS Division IV		
EOSREC	RCLOSPTC	EOSREC, failure to recover offsite power given its loss		
ETX	THEP1104	ETX, DE 11 in maintenance		

TABLE N-1. (Continued)

PRA Event	ASEP Event	Component/Explanation	Unavailability	ASEP Event Unavailability Total
E125A		Insufficient power from EPS Division I batteries (fails DE 11)		
	HSD0016A	EB01A, battery charge level insufficient		
		EBY1A1HMI, battery set unavailable		
E125B		Insufficient power from EPS Division II batteries (fails DE 12)		
	HSD0026L	EB01B, battery charge level insufficient		
		EBY1B1HMI, battery set unavailable		
E125C		Insufficient power from EPS Division III batteries (fails DE 13)		
	HSD0036I	EB01C, battery charge level insufficient		
		EBY1C1HMI, battery set unavailable		
E125D		Insufficient power from EPS Division IV batteries (fails DE 14)		
	HSD0046J	EB01D, battery charge level insufficient		
		EBY1D1HMI, battery set unavailable		
E2M	TREP126G	E2M, DE 12 in maintenance, given that DE 11 is not in maintenance		
E2M	TREP136F	E3M, DE 13 in maintenance, given that DE 11 and 12 are not in maintenance		
E4M	TREP146E	E4M, DE 14 in maintenance, given that DE 11, 12 and 13 are not in maintenance		
H BOTH	CNHRSD00A	HBOTH, both HPCI and RCIC out, Rx being shutdown		
HCS		Insufficient flow to Rx vessel through core spray (HPCI and LPCS)		
	HSAPCINE	HMVO0060PI, HPCI discharge isolation MOV, AC-FC		
	HSAPLPNE	LPO04BHFI, failure due to pipe rupture		
		LIV07B00I, Core spray manual shutoff valve, RLO-FC		
		LCY10B00I, AO core spray line discharge valve fails, stuck closed		
		LCY06AD0I, AO core spray line discharge valve fails, stuck closed		
HEIT		Failure in HPCI turbine steam exhaust to suppression pool		
	HSAPCTRI	HRD001HFI, failure of rupture disk		
		HRV02100I, steam discharge manual valve, locked open-fails closed		
		HPP002HEI, pipe blockage inhibits steam flow		
		HPP000HEI, exhaust header failure blocks flow		
		HRW07Z00I, steam discharge MOV, NO-FC		
	PHAPCTRI	HTRI, instability in HPCI steam exhaust line causes high exhaust pressure		
HFL100HEI	HSNCSP0W	HFL100HEI, HPCI SP strainer #1 clogged		
HFL200HEI	HSNCSP0Y	HFL200HEI, HPCI SP strainer #2 clogged		
HFW		Insufficient flow to Rx vessel through feedwater loop (HPCI)		
	HSNCFW0D	FPP10AHFI, failure due to pipe rupture		
		FWW11A00I, FW isolation MOV NO-FC		
		FCY10AD0I, check valve fails, stuck closed		
		FCY74AD0I, AO testable check valve fails, stuck closed		
	HSAPCIND	HMV10SD0PI, HPCI discharge isolation MOV, AC-FC		
HMU0690X1	ESHOOT0Y	HMU0690X1, failure of operator to initiate transfer given CST line valve failure (HPCI)		
HMU5000X0	ESHPCIRX	HMU5000X0, manual actuation fails (first restart of HPCI)		
HMU6000X1	ESHPCIRY	HMU6000X1, manual actuation fails (initial start of HPCI)		

~~PROPRIETARY~~

TABLE N-1. (Continued)

~~PROBLEMS~~

PRA Event	ASEP Event	Component/Explanation	Unavailability	ASEP Event Unavailability Total
HNU7000I	ESHP001Z	HNU7000I, MPC1 not reset for operation (initial start of MPC1)		
HINTA		Failure of CST low level indication and logic prevents transfer from CST to SP, MPC1 (Excluding event HINTA1)		
	ACRCCSLT	HRE661HWI, failure of relay logic for CST level indication (common link with RCIC)		
	ENRCCSLT	HLE6610XI, miscalibration of low level sensors in CST (common link with RCIC)		
HINT2		Failure to provide manual transfer from CST to SP (MPC1) (Excluding event HINTA)		
	ESRCTUR	HNU0790XI, human error, failure to transfer in sufficient time (common link with RCIC)		
	HSMCCPOO	HSW0010WI, manual transfer switch fails		
HINT		Failure of CST lines and valves (MPC1)		
	HSACCTOZ	HPP001HFI, pipe rupture		
		HIV0100I, manual isolation valve on suction line from CST, NO-FC		
		HIV0040WI, CST shutoff valve, NO-FC		
		HCV0190PI, check valve fails, stuck closed		
	HSRNCOTL	Failure of CST MOV's (RCIC/MPC1/LPCS)		
		TNN12400I, CST discharge MOV, NO-FC		
		TNN12500I, CST discharge MOV, NO-FC		
HIM2		Failure of suppression pool to provide flow (MPC1) (Excluding events LSP and HIM3)		
	HSHPCIOX	HPP0410PI, SP isolation MOV, NO-FC		
		HPP04200I, SP isolation MOV, NO-FC		
		HCV0450PI, check valve fails, stuck closed		
		HPP003HFI, pipe rupture in suction line to pump		
HLEV23		Failure of level channel B (MPC1)		
	ACHP2BMO	HRE92BHMI, failure of level B relay logic		
		HLE92BHMI, failure of level B sensor		
HLEV2C		Failure of level channel C (MPC1)		
	ACHP2CMO	HRE92CHMI, failure of level C relay logic		
		HLE92CHMI, failure of level C sensor		
HLEV2F		Failure of level channel F (MPC1)		
	ACHP2FBS	HRE92FHWI, failure of level F relay logic		
		HLE92FHWI, failure of level F sensor		
HLEV2G		Failure of level channel G (MPC1)		
	ACHP2GMU	HRE92GHMI, failure of level G relay logic		
		HLE92GHMI, failure of level G sensor		
HLEY9200XI	ENHPCLOW	HLEY9200XI, miscalibration of level channels (MPC1 initiation)		
HLE61BHMI	ACRCCSLQ	HLE61BHMI, failure of CST low level indication, #661B (MPC1 and RCIC)		
HLE61FHWI	ACRCCSLP	HLE61FHWI, failure of CST low level indication, #661F (MPC1 and RCIC)		
HLE9200XI	ESRCTUMH	HLE9200XI, miscalibration of level channels (MPC1 and RCIC)		
HLE93BHMI	ACHCLSON	HLE93BHMI, false signal indicates high Rx vessel water level (trios MPC1), #693B		
HLE93FHWI	ACHCLSOI	HLE93FHWI, false signal indicates high Rx vessel water level (trios MPC1), #693F		

TABLE N-11 (Continued)

~~PROPRIETARY~~

PRA Event	ASEP Event	Component/Explanation	Unavailability	ASEP Event Unavailability Total
HUEBE		Failure of HPCI tube system after start		
	HSHPCUH	HAV035001, isolation valve (MOV) fails, NC-FO		
		HAV059001, isolation valve (MOV) fails, NC-FO		
		HCY048001, check valve fails closed		
		HCY057001, check valve fails closed		
		HME100MFI, tube oil cooler heat exchanger leaks		
HADVO11001	HSRACIMD	HADVO11001, HPCI MOV test line valve fails, NC-FO		
HAW008001	HSCHCTNG	HAW008001, CST bypass isolation valve, NC-FO (HPCI)		
HAW011001	HSCHCTNE	HAW011001, CST bypass isolation valve, NC-FO (HPCI)		
HOT		Insufficient coolant to Rx vessel (HPCI) (Excluding MOT1 AND gate)		
	HSHPCINH	HCY005001, HPCI discharge valve fails, stuck closed		
		HAW007001, HPCI discharge isolation MOV, NC-FO		
		HPP100MFI, pipe rupture in coolant discharge line		
HOTD		Insufficient coolant to reactor vessel from HPCI		
	HSCHCSPR	LCY10800D, core spray (CS) line discharge check valve fails/stuck closed (fails HPCI)		
		LCY06400D, core spray (CS) line discharge check valve fails/stuck closed (fails HPCI)		
	HSHPCIMD	FCY10400D, check valve fails, stuck closed		
		FCY74A00D, AO testable check valve fails, stuck closed		
		HCY00500D, HPCI discharge check valve fails, stuck closed		
		HAW10500D, HPCI discharge isolation valve (MOV), NC-FO		
		HAW00600D, HPCI discharge isolation valve (MOV), NC-FO		
HPP		Failure of HPCI pump to produce adequate head (Excluding event HPM1)		
	HSHPCPNH	HPP00100M, failure to provide adequate flow through pump (HPCI) during subsequent starts		
HPM01A		HPCI turbine, loss of function (Excluding event HUEBE)		
	HSHPCPTNA	HAW11200D, turbine stop valve normally closed, fails closed		
		HAW11100D, turbine control valve fails		
		HTU00200D, turbine fails to start		
HPM010NC	HSHPCPNC	HPP00100M, failure to provide adequate flow through pump (HPCI)		
HPM1		Failure of HPCI pump negative force during subsequent starts (Excluding events HPM1B, HPM1A and HEXT)		
	HSHPCPTL	HPP00200F, pipe rupture in steam piping for turbine		
	HSHPCPTL	HTR, transient steam flow during startup leads to isolation signal		
HPM1A		Insufficient steam supply to HPCI turbine		
	HSHPCPTN	HAW00200I, steam supply line isolation MOV, NC-FO		
		HAW00300I, steam supply line isolation MOV, NC-FO		
		HAW00100I, steam supply line isolation MOV, NC-FO		
HPM1B		HPCI turbine loss of function (Excluding event HUEBE)		
	HSHPCPTN	HAW11200I, turbine stop valve normally closed, fails closed		
		HSH00200I, turbine shaft, coupling failure		
		HAW11100I, turbine control valve fails		
		HTU00200I, turbine fails to start and run		

~~PROPRIETARY~~~~PROPRIETARY~~

PRA Event	ASEP Event	Component/Explanation	ASER Event PLAYBACK ACTIVITY
HPR0000W1	HSPCLW2	HPR0000W1, dc powered pump fails to provide starting tube for HPCI	
HPR0000W2		Failure of high dry well pressure indication, HPCI initiation (Excluding event HFTG1 and HFTG2)	
	HMPDCWY	HPR1000X1, miscalibration of pressure channels	
	HMPCINW	HPR, event does not cause high dry well pressure. For some events this event has a value of 1.0 and for others it has a value of 0.0. This event was assumed to have a value of 1.0 for the sequences analyzed by ASEP	
HPR1B		Failure of containment pressure channel B (HPCI/LPCS/LPC1)	
	ACHP1BHWI	HRE94BHWI, failure of pressure B relay logic	
		HRS94BHWI, failure of pressure B sensor	
HPR1D		Failure of containment pressure channel D (HPCI/LPCS/LPC1)	
	ACHP1DHWI	HRE94DHWI, failure of pressure D relay logic	
		HRS94DHWI, failure of pressure D sensor	
HPR1F		Failure of containment pressure channel F (HPCI/LPCS/LPC1)	
	ACHP1FHWI	HRE94FHWI, failure of pressure D relay logic	
		HRS94FHWI, failure of pressure D sensor	
HPR1H		Failure of containment pressure channel H (HPCI/LPCS/LPC1)	
	ACHP1HHWI	HRE94HHWI, failure of pressure H relay logic	
		HRS94HHWI, failure of pressure H sensor	
HPR55BHWI	ACHP50D	HPR55BHWI, false signal indicates high exhaust pressure (HPCI) 4655B	
HPR55DHWI	ACHP50B	HPR55DHWI, false signal indicates high exhaust pressure (HPCI) 4655D	
HPR55FHWI	ACHP50C	HPR55FHWI, false signal indicates high exhaust pressure (HPCI) 4655E	
HPR55HHWI	ACHP50A	HPR55HHWI, false signal indicates high exhaust pressure (HPCI) 4655H	
HPR58BHWI	ACHP50J	HPR58BHWI, false signal, low pressure, 4658B (Division 1, HPCI)	
HPR58DHWI	ACHP50H	HPR58DHWI, false signal, low pressure, 4658D (Division 2, HPCI)	
HPR58FHWI	ACHP50I	HPR58FHWI, false signal, low pressure, 4658F (Division 1, HPCI)	
HPR58HHWI	ACHP50G	HPR58HHWI, false signal, low pressure, 4658H (Division 2, HPCI)	
HPR653HHWI	ACHP50P	HPR653HHWI, false signal indicates low pressure on pump suction, 4653, (HPCI)	
HRE660HWI	ACHC60S	HRE660HWI, failure of control logic to automatically activate transfer of HPCI from CST to SP	
HR51	HPC1N02	HR51, failure of HPCI during first restart given that the initial start was successful	
HR52	HPC1M03	HR52, failure of HPCI during second restart given that the first restart was successful	
HR52A	UMHC2SP8	HR52A, failure of HPCI during second restart (probability is estimated based on PRA event HRE51A)	
HR53	HPC1N04	HR53, failure of HPCI during third restart given that the second restart was successful	
HR53A	UMHC2SPC	HR53A, failure of HPCI during second restart (probability is estimated based on PRA event HRE51A)	
HSP4		False signal indicating high steam line space temperature (HPCI)	
	ACHT030R	HTE030HHWI, false signal indicates high temperature, sensor 603D	
		HTE030MMWI, false signal indicates high temperature, sensor 603M	
		HTE033MWI, false signal indicates high temperature, sensor 603R	
		HTE033HWI, false signal indicates high temperature, sensor 603S	
		HTE033HWI, false signal indicates high temperature, sensor 603P	
		HTE033HWI, false signal indicates high temperature, sensor 603A	
		HTE033HWI, false signal indicates high temperature, sensor 603F	
		HTE033HWI, false signal indicates high temperature, sensor 603B	

PROTECTED BY
PROPRIETARY
NOTICE

TABLE NH-1. (Continued)

100% LCOV

PRA Event	ASCP Event	Component/Explanation	Unavailability	ASCP Event Unavailability Total
HSPC		False HPCI steam supply line high AP or line break signal		
	ACHOPDDE	HPR600HMI, false signal indicates high AP, N6600		
		HPR603HMI, false signal indicates high AP, N6600		
		HPR570HMI, false signal indicates high AP, N6600		
		HPR573HMI, false signal indicates high AP, N6600		
HSPE		False signal indicates high turbine exhaust pressure (HPCI)		
	ACHOPSOX	HPR56FHMI, false signal indicates high pressure, N656F		
		HPR56BHMI, false signal indicates high pressure, N656B		
HSPE		Emergency area cooler (HPCI) high temperature, false signal		
	ACHCTSOX	HTED02DHMI, false signal indicates high temperature N602D		
		HTED02BHMI, false signal indicates high temperature N602B		
HSM102HMI	ACHOSOO	HSM102HMI, false signal indicates HPCI turbine overspeed		
HTMBOTH		HPCI unavailable due to maintenance or HPCI and RCIC out (reactor being shutdown)		
	CYHRSOHH	Defined under PRA event HBOTH		
	TMPC1MH	HPCI in maintenance		
HTRID	PHHPCTRB	HTRID, instability in turbine exhaust causes HPCI to trip		
KELA		Failure of RCIC pump room cooling Unit A (Excluding events ULA, FTIA, and KLU00A)		
	HSR0CAKX	KSD16AHMI, failure of solenoid valve A, NO-FC		
		KHY20AD001, failure of manual outlet valve 1020A, NO-FC		
		HEXAPC, heat exchanger A plugs or clogs		
		KFA00BDWI, failure of fan A		
		KAV16AHMI, failure of fan interlock valve HV106A, NC-FC		
KCUB		Failure of RCIC pump room cooling Unit B (Excluding events ULB, FTIB, and KLU00B)		
	HSR0CBKL	KSD16AHMI, failure of solenoid valve B, NO-FC		
		KHY20AD001, failure of manual outlet valve 1020B, NO-FC		
		HEXAPC, heat exchanger B plugs or clogs		
		KFA00BDWI, failure of fan B		
		KAV16AHMI, failure of fan interlock valve HV106B, NC-FC		
KFN111HMI	HS01YAKT	KFN111HMI, loss of function of ventilation system A (applies to room cooling for DE 11)		
- KFN112HMI	HS02YAKT	KFN112HMI, loss of function of ventilation system A (applies to room cooling for DE 12)		
KFN113HMI	HS03YAKU	KFN113HMI, loss of function of ventilation system A (applies to room cooling for DE 13)		
KFN114HMI	HS04YAKY	KFN114HMI, loss of function of ventilation system A (applies to room cooling for DE 14)		
KFN200HMI	HS01YBSU	KFN200HMI, loss of function of ventilation system B (applies to room cooling for DE 11)		
KFN201HMI	HS01YBNC	KFN201HMI, loss of function of ventilation system B (applies to room cooling for DE 12)		
KFN202HMI	HS03YBHK	KFN202HMI, loss of function of ventilation system B (applies to room cooling for DE 13)		
KFN203HMI	HS04YBHS	KFN203HMI, loss of function of ventilation system B (applies to room cooling for DE 14)		
KHS00AD00E	ACRREAKE	KHS00AD00E, manual/auto switch A fails (RCIC room cooling)		

PROOF

TABLE K-1. (Continued)

PRA Event	ASER Event	Component/Explanation	ASER Facility	ASER Event Unavailability "start"
KHSCOBONG	ACRREBQI	KHSCOBONG, manual/auto switch & fails (RCIC room cooling)		
KHVENTIA	ESD1YAGP	KHVENTIA, operator fails to start ventilation system A (applies to room cooling for DG 11)		
KHVENTIB	ESD1YBGM	KHVENTIB, operator fails to start ventilation system B (applies to room cooling for DG 11)		
KHVENTZA	ESD2YAGY	KHVENTZA, operator fails to start ventilation system A (applies to room cooling for DG 12)		
KHVENTZB	ESD2YBGY	KHVENTZB, operator fails to start ventilation system B (applies to room cooling for DG 12)		
KHVENTZA	ESD2YANG	KHVENTZA, operator fails to start ventilation system A (applies to room cooling for DG 13)		
KHVENTZB	ESD2YBHD	KHVENTZB, operator fails to start ventilation system B (applies to room cooling for DG 13)		
KHVENTAA	ESD4VANQ	KHVENTAA, operator fails to start ventilation system A (applies to room cooling for DG 14)		
KHVENTAB	ESD4VBHL	KHVENTAB, operator fails to start ventilation system B (applies to room cooling for DG 14)		
KHUSADIDR	ESRRCAKH	KHUSADIDR, operator fails to isolate RCIC pump room cooling unit A		
KHUSBDIDR	ESRRCBEC	KHUSBDIDR, operator fails to isolate RCIC pump room cooling unit B		
KLUOAR		RCIC pump room cooling unit A fails due to leakage		
	HSRCAKJ	KHY56AH01, failure of drain valve 1056A, unit A, NC-FO		
		KHY56AHF1, failure due to heat exchanger (unit A) leakage		
		KHY57AH01, failure of vent valve 1057A, unit A, NC-FO		
KLUOBF		RCIC pump room cooling unit B fails due to leakage		
	HSRBCBKD	KHY56BH01, failure of drain valve 1056B, unit B, NC-FO		
		KHY56BHFI, failure due to heat exchanger (unit B) leakage		
		KHY57BH01, failure of vent valve 1057B, unit B, NC-FO		
KRMELHPC1	HMCRCPA	KRMELHPC1, failure of pump room cooling equipment (the subtree for HPC1 room cooling was not quantified by the PRA, the value evaluated for RCIC room cooling was used as a component input to the HPC1 fault tree)		
KRMELRCIC		Failure of RCIC pump room cooling equipment (valve failures which fail both unit A and B) (Excluding the CUF AND gate)		
	HSRCEIKM	RHY1119001, failure of manual inlet valve 1019, NO-FC		
		RHY121001, failure of manual outlet valve 1021, NO-FC		
KVENTIA	HS01YAGG	KVENTIA, failure of ventilation system A auto start (applies to room cooling for DG 11)		
KVENTIB	HS01YBGM	KVENTIB, failure of ventilation system B auto start (applies to room cooling for DG 11)		
KVENTZA	HS02YAGZ	KVENTZA, failure of ventilation system A auto start (applies to room cooling for DG 12)		
KVENTZB	HS02YBGM	KVENTZB, failure of ventilation system B auto start (applies to room cooling for DG 12)		
KVENTZA	HS03VANH	KVENTZA, failure of ventilation system A auto start (applies to room cooling for DG 13)		
KVENTZB	HS03VBHE	KVENTZB, failure of ventilation system B auto start (applies to room cooling for DG 13)		
KVENTAA	HS04VAMP	KVENTAA, failure of ventilation system A auto start (applies to room cooling for DG 14)		
KVENTAB	HS04VBHF	KVENTAB, failure of ventilation system B auto start (applies to room cooling for DG 14)		
LOST	HP101LOST	LOST loss of water from condensate storage tank (HPC1/RCIC/LPCC)		

PROPRIETARY

TABLE N-1. (Continued)

PRA Event	ASER Event	Component/Explanation	Unavailability	ASER Event Unavailability Total
L01		Failure to discharge water from LPCS loop 1 (pump Trains A and C) to reactor (Excluding events EAC440A and LD201S)		
	HSCS1XQZ	LXV07AD01, discharge line manual isolation valve locked open, FC L2P04AAIFI, discharge line rupture in loop 1 LXV06AD01, discharge line check valve fails, stuck closed LWV04AD01, discharge line isolation MVN, NO-FC LWV15AD01, flow diverted to SR via test line MVN, NC-FO		
L02		Failure to discharge water from LPCS loop 2 (pump Trains B and D) to reactor (Excluding events EAC440B and LD201S)		
	HSCS1PNE	Defined under PRA event HCS		
	HSCS2XQZ	LWV04BD01, discharge line isolation valve (MVN), NO-FC LWV15BD01, flow diverted to SR via test line MVN, NC-FO		
LFL1A1HEI	HSCSPA00	LFL1A1HEI, failure of strainer #1 for LPCS pump A, strainer blocks flow		
LFL1A2HEI	HSCSPA0P	LFL1A2HEI, failure of strainer #2 for LPCS pump A, strainer blocks flow		
LFL1C1HEI	HSCSPC0U	LFL1C1HEI, failure of strainer #1 for LPCS pump C, strainer blocks flow		
LFL1C2HEI	HSCSPC0T	LFL1C2HEI, failure of strainer #2 for LPCS pump C, strainer blocks flow		
LFL2B1HEI	HSCSPB0C	LFL2B1HEI, failure of strainer #1 for LPCS pump B, strainer blocks flow		
LFL2B2HEI	HSCSPB0B	LFL2B2HEI, failure of strainer #2 for LPCS pump B, strainer blocks flow		
LFL2D1HEI	HSCSPD0G	LFL2D1HEI, failure of strainer #1 for LPCS pump D, strainer blocks flow		
LFL2D2HEI	HSCSPD0F	LFL2D2HEI, failure of strainer #2 for LPCS pump D, strainer blocks flow		
LHUT110ZI	HSOSACPZ	LHUT110ZI, failure to manually initiate LPCS		
LLCW		Loss of ACIC tube cooling water		
	HSRCLWMU	RSY018D01, PCV IF018 fails open, NO-FC PON015D01, PCV IF015 fails closed, NO-FC RPP001DF1, 2" water line pluggs RPP001DF1, 2" water line leaks/rupture		
LLEYA		Failure of Level channel 691A, loop 1, LPCS pump A (Excluding event EDC125A)		
	ACCS1APRH	LLE91AHWI, failure of level sensor LRE91AHWI, failure of level relay logic		
	ENCSOMPH	LHUS110ZI, miscalibration of level channels		
LLEYB		Failure of Level channel 691B, loop 2, LPCS pump B (Excluding event EDC125D)		
	ACCS2BPK	LLE91BHWI, failure of level sensor LRE91BHWI, failure of level relay logic		
	ENCSOMPH	Defined under PRA event LLEYA		
LLEYC		Failure of Level channel 691C, loop 1, LPCS pump C (Excluding event EDC125C)		
	ACCS1CPK	LLE91CHWI, failure of level sensor LRE91CHWI, failure of level relay logic		
	ENCSOMPH	Defined under PRA event LLEYA		

~~PROPRIETARY~~

TABLE A-1. (Continued)

PRA Event	ASCP Event	Component/Explanation	Availability	ASCP Event Unavailability Total
LLEYD		Failure of level channel 691D, loop 2, LPCS pump D (Excluding event EDC125D)		
	ACCS2DPO	LLE81DMW1, failure of level sensor		
		LRE81DMW1, failure of level relay logic		
	ENSC2MPH	Defined under PRA event LLEYA		
LLEYE		Failure of level channel 691E, loop 1, LPCS pump A (Excluding event EDC125A)		
	ACCS1APS	LLE81EMW1, failure of level sensor		
		LRE81EMW1, failure of level relay logic		
	ENSC2MPH	Defined under PRA event LLEYA		
LLEYF		Failure of level channel 691F, loop 2, LPCS pump B (Excluding event EDC125A)		
	ACCS2BPU	LLE81FMW1, failure of level sensor		
		LRE81FMW1, failure of level relay logic		
	ENSC2MPH	Defined under PRA event LLEYA		
LLEYG		Failure of level channel 691G, loop 1, LPCS pump C (Excluding event EDC125C)		
	ACCS1CPW	LLE81GMW1, failure of level sensor		
		LRE81GMW1, failure of level relay logic		
	ENSC2MPH	Defined under PRA event LLEYA		
LLEYH		Failure of level channel 691H, loop 2, LPCS pump D (Excluding event EDC125D)		
	ACCS2DPO	LLE81HMW1, failure of level sensor		
		LRE81HMW1, failure of level relay logic		
	ENSC2MPH	Defined under PRA event LLEYA		
LW005DPI	HSCS1DQY	LW005DPI, failure of LPCS loop 1 discharge line isolation valve 005		
LW037D01	HSCS2DQW	LW037D01, failure LPCS loop 2 of discharge line isolation valve 037		
LPREA		Failure of Rx low pressure permissive channel 690A, loop 1, LPCS pump A (Excluding event EDC125A)		
	ACCS1APS	LPR90AMW1, failure of pressure sensor		
		LRE90AMW1, failure of pressure relay logic		
	ENSC2MPG	LHS5120X1, miscalibration of pressure sensors		
LPREB		Failure of Rx low pressure permissive channel 690B, loop 2, LPCS pump B (Excluding event EDC125D)		
	ACCS2BPU	LPR90BMW1, failure of pressure sensor		
		LRE90BMW1, failure of pressure relay logic		
	ENSC2MPG	Defined under PRA event LPREA		
LPREC		Failure of Rx low pressure permissive channel 690C, loop 1, LPCS pump C (Excluding event EDC125C)		
	ACCS1CPW	LPR90CMW1, failure of pressure sensor		
		LRE90CMW1, failure of pressure relay logic		
	ENSC2MPG	Defined under PRA event LPREA		

PROPRIETARY

TABLE N-1. (Continued)

PRA Event	ASER Event	Component/Explanation	Unavailability	ASER Event Unavailability Total
UPREF		Failure of Rx low pressure permissive channel 6900, Loop 2, LPCS PUMP 0 (Excluding event EDC1250)		
	ACCS2DPP	LPR900HWI, failure of pressure sensor LRE900HWI, failure of pressure relay logic		
	ENSCOMP	Defined under PRA event UPREA		
UPREZ		Failure of Rx low pressure permissive channel 690E, Loop 1, LPCS PUMP A (Excluding event EDC125A)		
	ACCS1APP	LPR90EHWI, failure of pressure sensor LRE90EHWI, failure of pressure relay logic		
	ENSCOMP	Defined under PRA event UPREA		
UPREF		Failure of Rx low pressure permissive channel 690F, Loop 2, LPCS PUMP 3 (Excluding event EDC1258)		
	ACCS2BPT	LPR90FHWI, failure of pressure sensor LRE90FHWI, failure of pressure relay logic		
	ENSCOMP	Defined under PRA event UPREA		
UPRES		Failure of Rx low pressure permissive channel 690G, Loop 1, LPCS PUMP C (Excluding event EDC125C)		
	ACCS1CPY	LPR90GHWI, failure of pressure sensor LRE90GHWI, failure of pressure relay logic		
	ENSCOMP	Defined under PRA event UPREA		
UPREH		Failure of Rx low pressure permissive channel 690H, Loop 2, LPCS PUMP 0 (Excluding event EDC1250)		
	ACCS2DPI	LPR90HHWI, failure of pressure sensor LRE90HHWI, failure of pressure relay logic		
	ENSCOMP	Defined under PRA event UPREA		
UPRIA		Failure of drywell high pressure channel 694A, Loop 1, LPCS PUMP A (Excluding event EDC125A)		
	ACCS1APP	LPR94AHWI, failure of pressure sensor LRE94AHWI, failure of pressure relay logic		
	ENHPCDNY	Defined under PRA event HPRES2		
UPRIG		Failure of drywell high pressure channel 694G, Loop 1, LPCS PUMP C (Excluding event EDC125C)		
	ACCS1CPY	LPR94CHWI, failure of pressure sensor LRE94CHWI, failure of pressure relay logic		
	ENHPCDNY	Defined under PRA event HPRES2		
UPRIC		Failure of drywell high pressure channel 694C, Loop 1, LPCS PUMP C (Excluding event EDC125C)		
	ACCS1CHI	LPR94CHWI, failure of pressure sensor LRE94CHWI, failure of pressure relay logic		
	ENHPCDNY	Defined under PRA event HPRES2		

TABLE P-1. (Continued)

PRA Event	ASEP Event	Component/Explanation	Unavailability	ASEP Event Unavailability Total
LPRIE		Failure of drywell high pressure channel 594E, Loop 1, LPCS pump A (Excluding event EDC12SA)		
ACCSAFL	LPR94EHW1, failure of pressure sensor LRE94EHW1, failure of pressure relay logic			
ENRPCDNY	Defined under PRA event MRES2			
LSP	HPC1LSP	Loss of water supply from suppression pool (SP) (for HPC1 and RIC systems, from the PRA HPC1 fault tree, sheet 8)		
LSP		Loss of water from suppression pool (for LPCS and LPCI systems)		
	HSRSPIPE	ETK100DF1, suppression pool water unavailable due to rupture		
	PHRSPIPO	ETK200DW1, suppression pool water unavailable due to high temperature (LPCI and CS pumps not warm started)		
LIPA		Inadequate head from LPCS pump A, Loop 1 (Excluding events EACCAAOA and EACA)		
	HMESRQH	KRMELCSD, failure of pump room cooling equipment for pump B		
	HSCS1AQH	LPP01AHF1, pump piping ruptures LZY20ADQ1, pump discharge manual valve locked open, FC LCV03ADP1, pump discharge check valve stuck closed		
		LPM01CDW1, pump A fails to start and run		
LIPC		Inadequate head from LPCS pump C, Loop 1 (excluding events EACCAAOC and EACC)		
	HMESRQH	KRMELCSD, failure of pump room cooling equipment for pump C		
	HSCS1QH	LPP01AHF1, pump piping ruptures LZY20CDQ1, pump discharge manual valve locked open, FC LCV03CDP1, pump discharge check valve stuck closed		
		LPM01CDW1, pump C fails to start and run		
LISAT		Insufficient flow from SP to LPCS pump A suction (Excluding events LSP and LISAT1)		
	HSCSPAOR	LMM01ADQ1, suction NOV, NO-FC LPP21AHF1, suction line pipe rupture		
LISAZ		Insufficient flow from CST to LPCS pump A suction		
	ESCSCTOA	LHUS902DII, failure to manually open CST valves in time		
	ESCSRFOA	LHUS522DII, failure to replenish CST in time to support LPCS operation		
	HSESTB00	LIV02ADP1, CST discharge valve 002A fails, NO-FC (fails CST source to pump A)		
	HSCSTT00	LIV09ADP1, CST discharge valve 009A fails, NO-FC (valve is common to pump A and pump C CST suction)		
	HSRNCFTY	Defined under PRA event HINI		
LISC1		Insufficient flow from SP to LPCS pump C suction		
	HSCSPCOV	LMM01CDQ1, suction NOV, NO-FC LPP21CHF1, suction line pipe rupture		
LISC2		Insufficient flow from CST to LPCS pump C suction		
	ESCSCTOA	Defined under PRA event LISAZ		
	ESCSRFOA	Defined under PRA event LISAZ		
	HSCSTC05	LIV02CDP1, CST discharge valve 005A fails, NO-FC (valve is common to pump C)		
	HSCSTT00	Defined under PRA event LISAZ		
	HSRNCFTY	Defined under PRA event HINI		

~~PROPRIETARY~~

TABLE N-1. (Continued)

PRA Event	ASER Event	Component/Explanation	Unavailability	ASER Event Unavailability Total
L1T	TMES10L	L1T, LPCS Loop 1 (pumps A and C) unavailable due to maintenance given that MPC1 and all diesels are not in maintenance.		
L2P8		Inadequate head from LPCS pump B, Loop 2 (Excluding events EACCA40B and EAC3)		
	HMECLSB	KRMELCSB, failure of pump room cooling equipment for pump B		
	HSCS2BQJ	LPP01BHFI, pump piping ruptures		
	LIV20B001	LIV20B001, pump discharge manual valve locked open, FC		
	LCY03D0P1	LCY03D0P1, pump discharge check valve stuck closed		
	LPM01B0W1	LPM01B0W1, pump B fails to start and run		
L2P0		Inadequate head from LPCS pump D, Loop 2 (Excluding events EACCA40D and EACD)		
	HMECLSD	KRMELCSD, failure of pump room cooling equipment for pump D		
	HSCS2D0J	LPP01DHFI, pump piping ruptures		
	LIV200001	LIV200001, pump discharge manual valve locked open, FC		
	LCY03D0P1	LCY03D0P1, pump discharge check valve stuck closed		
	LPM01D0W1	LPM01D0W1, pump D fails to start and run		
L2S81		Insufficient flow from SP to LPCS pump B suction (Excluding events LSP and L1S811)		
	HSCSPB00	LPM01B0Q1, suction MDV, NO-FC		
	LPP21DHFI	LPP21DHFI, suction line pipe rupture		
L2S82		Insufficient flow from CST to LPCS pump B suction		
	ESCSC70A	Defined under PRA event L1SAZ		
	ESCSRFD0A	Defined under PRA event L1SAZ		
	HSCSTB0A	LIV20B0P1, CST discharge valve 0028 fails, RLC-FC (fails CST source to pump B)		
	HSCST20A	LIV09B0P1, CST discharge valve 0098 fails, RLC-FC (valve is common to pump B and pump D CST suction)		
	HSRHCTLY	Defined under PRA event H[RI]		
L2S01		Insufficient flow from SP to LPCS pump D suction (Excluding events LSP and L2S011)		
	HSCSPD0H	LPM01D0Q1, suction MDV, NO-FC		
	LPP21DHFI	LPP21DHFI, suction line pipe rupture		
L2S2		Insufficient flow from CST to LPCS pump D suction		
	ESCSC70A	Defined under PRA event L1SAZ		
	ESCSRFD0A	Defined under PRA event L1SAZ		
	HSCSTD0E	LIV02D0P1, CST discharge valve 0020 fails, RLC-FC (fails CST source to pump D)		
	HSCST20A	Defined under PRA event L2S82		
	HSRHCTLY	Defined under PRA event H[RI]		
L2T	TMES210R	L2T, LPCS Loop 2 (pumps B and D) unavailable due to maintenance given that LPCS Loop 1, MPC1, and all diesels are not in maintenance		
RALAA		Failure of automatic initiation action of unit A, RCIC pump room cooling		
	ACRRCAXA	KTE21AHWD, failure of sensor A		
	KTE21AHWD	KTE21AHWD, failure of transmitter A		
	KRL21AHWD	KRL21AHWD, failure of logic A		

~~PROPRIETARY~~

TABLE N-1. (Continued)

PRA Event	AZD Event	Component/Explanation	Availability	ASER Event UNAVAILABILITY TOTAL
NAC1E		Failure of automatic initiation action of unit B, RCIC pump room cooling		
ACRRCBAF	KTE21BHWI, failure of sensor B			
	KTA21BHWI, failure of transmitter B			
	KRL21BHWI, failure of logic B			
NHIAA		Failure of manual initiation of RCIC pump room cooling unit A		
ACRRCAAK	KAMDOADNO, failure of annunciator A			
ESRRCAAK	KHUSTADNO, operator fails to manually initiate pump room cooling unit A or B			
NHIBB		Failure of manual initiation of RCIC pump room cooling unit B		
ACRRCBKG	KAMDOADNO, failure of annunciator B			
ESRRCBKG	KHUSTADNO, operator fails to manually initiate pump room cooling unit B or A			
RAL001HWI	ACRC01LU	RAL001HWI, failure of auto transfer logic RCIC		
RCV017001	HSRC1TMQ	RCV017001, check valve 1017 stuck closed or plugged (RCIC)		
RCV018001	HSRC1TMQ	RCV018001, check valve 1018 stuck closed or plugged (RCIC)		
RCV068001	HSRC1TMQ	RCV068001, check valve 1F068 stuck closed or plugged (RCIC)		
RCV081001	HSRC1TMQ	RCV081001, check valve 1F081 stuck closed or plugged (RCIC)		
RDG1	RDGA103	RDG1, non-recovery of diesel generators within 1/2 hour		
RDG2	RDGA207	RDG2, the failure of Division I and III DG and their non-recovery within two hours for HPCI or RCIC room cooling power supplies (given the failure of normal and alternate room cooling)		
RDG2A	RDGA297	RDG2A, failure to repair DG within two hours, given diesel failure at the 1/2 hour time point and the failure of normal and alternate room cooling		
RDG3	RDGA309	RDG3, Failure of Division I and III DG and their non-recovery, within four hours, given successful implementation of alternate room cooling		
RDG3A	RDGA399	RDG3A, failure to recover the DG within four hours, given diesel failure at the 1/2 hour time point and the successful implementation of alternate room cooling		
RFL100HEI	HSRCSPW	RFL100HEI, suppression pool strainer No. 1 clogged (RCIC)		
RFL200HEI	HSRCSPY	RFL200HEI, suppression pool strainer No. 2 clogged (RCIC)		
RFTDP		Loss of flow from RCIC pump to reactor vessel (Excluding the RFTDP1 AND gate)		
	HSAC1PMF	FCV74BDPI, containment isolation check valve stuck closed		
		FCV108DPI, containment isolation check valve stuck closed		
		RCV014DPI, check valve in discharge line of RCIC stuck closed		
		FHW118DPI, inboard containment isolation valve, MD-FC		
		RHW013DPI, isolation valve in discharge line of RCIC, MD-FC		
		RHW012DPI, MDV in discharge line of RCIC, MD-FC		
		RPP001HFI, pipe rupture in discharge line of RCIC		
RFTT		RCIC fails due to false turbine trip (Excluding the RFTT1 OR gate and the RFTT2 AND gate)		
	ACRC1PLC	APR006HWI, sensor for low pump suction pressure of RCIC gives false signal		
	ACRC1TLU	RCIC turbine trip due to overspeed		
		ASW002HWI, overspeed tachometer gives false signal		
		ASW100HWI, trip due to failed mechanical overspeed		
	SHRC1TLU	RHU004AI, miscalibration of turbine trip sensors: air level, oil pressure		

~~PROPRIETARY~~

PRA
EventASCP
Event

RPTT		RPTT HIGH turbine exhaust pressure channels gives false signal
AFCRTR		RPM58HMI, high turbine exhaust pressure channel gives false signal
		RPM59HMI, high turbine exhaust pressure channel gives false signal
RHUC002II	ESRCADM	RHUC002II, failure to manually initiate RCIC start
RHUC690II	ESRCCTR	RHUC690II, operator fails to transfer RCIC from CST to SR
RHUC700II	ESRCPLI	RHUC700II, failure to manually transfer RCIC from CST to SP
RHUC1200D	ESRC10X	RHUC1200D, operator fails to reset RCIC turbine stop valve for restart
RHUC600II	ESRC10U	RHUC600II, operator fails to reset RCIC turbine stop valve
RHUC700II	ENRCPLU	RHUC700II, miscalibration of RCIC reactor low pressure channels
RHUC701II	ENRCPSL	RHUC701II, miscalibration of RCIC turbine exhaust pressure channels
RIEFT		Failure due to excessive exhaust restriction (Excluding the YFB OR gate)
	HSRCTHT	RCY00100I, globe valve check in turbine exhaust line, LO-FC TELB, blockage in turbine exhaust line RMW06000I, NOV in turbine exhaust line, NO-FC
	UNRCTHT	ATRI, instability in steam exhaust line causes high exhaust pressure
RINTA		Failure of CST level indication (Excluding RINTB AND gate)
	ARCSCLT	RRE561HMI, failure of CST indication level relay logic (MPC and RCIC)
	ENRCCLT	RLE6610II, miscalibration low level CST sensors (MPC and RCIC)
RINT		Failure of CST times and valves (RCIC)
	HSRCCLY	RMW01000I, NO gate valve in CST discharge line, NO RIV00900I, manual gate in pump suction line, LO-FC RCY0110PI, check valve CST discharge line stuck closed RPP009HFI, pipe rupture in CST discharge line
	HSRNHTLY	Defined under PRA event RINT
RINA		Failure of suppression pool supply source for RCIC (Excluding event LSP and the RINA AND gate)
	HSRCSPLY	RMW02900I, NO gate valve in suppression pool discharge line, NO-FC RCY0300PI, check valve suppression pool discharge stuck closed RPP031HFI, pipe rupture in suppression pool discharge line RMW0310PI, NO gate valve in suppression pool discharge line, NO-FC
RIVC		False steam pipe area high temperature signal causes isolation valve closure (RCIC steam supply)
	AFCRCTION	RTE63AHMI, steam pipe area high temperature sensor #603A gives false signal RTE63JHMI, steam pipe area high temperature sensor #603J gives false signal RTE63CHMI, steam pipe area high temperature sensor #603C gives false signal RTE63JHMI, steam pipe area high temperature sensor #603J gives false signal RTE63EHMI, steam pipe area high temperature sensor #603E gives false signal RTE63THMI, steam pipe area high temperature sensor #603T gives false signal RTE63GHMI, steam pipe area high temperature sensor #603G gives false signal RTE63LHMI, steam pipe area high temperature sensor #603L gives false signal RTE63RHMI, steam pipe area high temperature sensor #603R gives false signal RTE63YHMI, steam pipe area high temperature sensor #603Y gives false signal

PROD/PZ

TABLE R-1. (Continued)

RRA Event	ASER Event	Component/Explanation	Unavailability	ASER Event Unavailability Total
RIVC1 (continued)	ENRC01EX	RHUB000II, miscalibration of one of ten channels		
RIVC2		False equipment room ventilation air inlet and outlet high AT signal causes isolation valve closure (RCIC)		
	ACRC01KX	RTE61AHM1, equipment room ventilation air inlet and outlet high AT gives false signal		
		RTE61BHMI, equipment room ventilation air inlet and outlet high AT gives false signal		
	ENRC01KX	RHUB010II, miscalibration of one of two channels		
RIVC3		False emergency area cooler high temperature signal causes isolation valve closure (RCIC)		
	ACRC01KX	RTE62AHM1, emergency area cooler high temperature sensor N602A gives false signal		
		RTE62CHM1,C emergency area cooler high temperature sensor N602C gives false signal		
	ENRC01KX	RHUB020II, miscalibration of one of two channels		
RIVC4		False steam line high AP or instrument line break signal causes isolation valve closure (RCIC)		
	ACRC01KX	RPR57AHM1, steam line high AP sensor N057A gives false signal or instrument line break		
		RPR57CHM1, steam line high AP sensor N057C gives false signal or instrument line break		
	ENRC01KX	RHUB030II, miscalibration of one of two channels		
RLEY2A		Failure of Level 2 channel 697A		
	ACRC01KX	RLE97AHM1, failure of sensor		
		RRE97AHM1, failure of relay logic		
RLEY2A1		Failure of Level 2, channel 692A (RCIC)		
	ACRC01KX	RLE92AHM1, failure of sensor		
		RRE92AHM1, failure of relay logic		
RLEY2E		Failure of Level 2 channel 697E (RCIC)		
	ACRC01KX	RLE97EHM1, failure of sensor		
		RRE97EHM1, failure of relay logic		
RLEY2E1		Failure of Level 2 channel 692E (RCIC)		
	ACRC01KX	RLE92EHM1, failure of sensor		
		RRE92EHM1, failure of relay logic		
RLE24AHM1	ACRC01AH	RLE24AHM1, reactor high water level sensor gives false signal (RCIC)		
RLE24OHM1	ACRC01AH	RLE24OHM1, reactor high water level sensor gives false signal (RCIC)		
RLE61BMH1	ACRC01SL	RLE61BMH1, failure of CST level indicator N661B (RCIC)		
RLE61FHMH1	ACRC01SP	RLE61FHMH1, failure of CST level indicator N661F (RCIC)		
RLUBE		RCIC tube system fails		
	HSRCLSHW	RHW046001, HWTF046, HC-FC		
		RH00010FI, tube cooling heat exchanger leaks		
		RLFO010FI, shaft drive tube pump fails		
		RLFO010EI, tube filter plugs/leaks		
RHW022001	HSRHCHE	RHW022001, RCIC MOV globe valve to CST		
RHAY1	THEC01CHG	RHAY1, RCIC unavailable due to maintenance given that HPCI is not in maintenance		
ROPI1	ACOS01PO	ROPI1, non-recovery of offsite power within 1/2 hr		
ROPI2	ACOS01PH	ROPI2, recovery of offsite power within 2 hr	M-58	

TABLE N-1. (Continued)

PRA Event	ASEP Event	Component/Explanation	Unavailability	ASEP Event Unavailability Total
R0P3	ACDSP008	R0P3, non-recovery of offsite power within 6 hr		
ROTD		Insufficient coolant from RCIC discharge during restart		
	HSRCITPKS	FCV7480PD, containment isolation check valve stuck closed		
		FCV1080PD, containment isolation check valve stuck closed		
		FCV0110PD, check valve fails, stuck closed		
		RMW0130PD, isolation valve in discharge line of RCIC, NO-FC		
RPHOTA		RCIC turbine loss of function (Excluding TSVNBR AND gate)		
	HSRCITTPR	RTU00020MD, turbine fails to start		
		RPY0450PD, steam line valve, NO-FC		
RPH0010MD	HSRCIP008	RPH0010MD, failure of RCIC pump to start		
RPRSSAHM1	ACRCP50D	RPRSSAHM1, RCIC turbine exhaust pressure sensor NOSSA gives false signal (high)		
RPRSSCHM1	ACRCP50C	RPRSSCHM1, RCIC turbine exhaust pressure sensor NOSSC gives false signal (high)		
RPRSEHMI	ACRCP50B	RPRSEHMI, RCIC turbine exhaust pressure sensor NO55E gives false signal (high)		
RPRSGHMI	ACRCP50A	RPRSGHMI, RCIC turbine exhaust pressure sensor NO55G gives false signal (high)		
RPRSBAM1	ACRCP50X	RPRSBAM1, reactor low pressure sensor NO58A gives false signal (RCIC)		
RPRSBCHM1	ACRCP50G	RPRSBCHM1, reactor low pressure sensor NO58C gives false signal (RCIC)		
RPRSBEM1	ACRCP50F	RPRSBEM1, reactor low pressure sensor NO58E gives false signal (RCIC)		
RPRSBGM1	ACRCP50E	RPRSBGM1, reactor low pressure sensor NO58G gives false signal (RCIC)		
RSID	ACRCL00T	RSID, failure of manual actuation to initiate RCIC		
RSMD01HMI	ACRCP50L	RSMD01HMI, manual transfer switch failure (RCIC)		
RSMD45HMI	ACRCP50X	RSMD45HMI, permissive when steam supply valve FD45 is fully open (RCIC)		
RTDP		Loss of flow through RCIC turbine-driven pump (Excluding the RTDP1 OR gate)		
	HSRCIPMC	RPH0010MI, failure of pump		
		RPP001HFI, piping rupture in pump discharge or suction		
RTDP1		Failure of the RCIC turbine (Excluding events RIEFT, RLTIA, and the RTDPA1 OR gate)		
	HSRCITMB	RR000100I, failure of turbine exhaust reheat disc		
		RTU0020MI, failure of the turbine to start and run		
RTDPA		Loss of steam supply to RCIC turbine		
	HSRCITMA	RMW11300I, turbine governing valve, NO-FC		
		RMW11200I, turbine trip throttle valve, NO-FC		
		RPM0450PI, M.O. globe valve in steam line to turbine, NO-FC		
		RPM002HFI, piping in steam line to turbine ruptures		
		RPM00020I, M.O. gate valve in steam line to turbine, NO-FC		
		RPM00700I, M.O. gate valve in steam line to turbine, NO-FC		
RTRID	UNRCITKD	Instability in RCIC turbine exhaust causes trip		
RTT1	RCI0101	RHUS0001I, operator fails to take manual control of MPC1 and P1. MPC1 is successful on its initial demand, results in RCIC trip		

PPK

TABLE 10.1 (Continued)

MUR

REL Event	ASCE Event	Component/Explanation	CHARACTER	ASCE Event Unavailability Time
TSVT	AFC01000	TSVT, RCO turbine stop valve tripped	-	-
U		High pressure injection systems	-	-
U	AFC01	U, failure of HPCI and RCO system (used to calculate U for the TGU sequence only)	-	-
U		High pressure injection systems	-	-
U	UNHPI005	U, failure of HPCI and RCO systems (for TGU sequence only)	-	-
V		LP ECCS, failure of	-	-
V	URLPCI11	V, failure of ADS due to hardware faults or the failure of LPCS and LPSC due to various reasons given that onsite or offsite power is recovered within 1/2 hr.	-	-
V		LP ECCS, failure of	-	-
V	URLPCI12	V, failure of ADS due to hardware faults or the failure of LPCS and LPSC due to various reasons given that HPCI and RCO was initially successful and that offsite power or the diesels are not recovered within 4 hr.	-	-
V		LP ECCS, failure of	-	-
V	URLPCI13	V, failure of ADS due to hardware faults or the failure of LPCS and LPSC due to various reasons given the HPCI and RCO failed initially and offsite power is not recovered within 1/2 hr.	-	-
VFB		Vacuum breaker failed, RCO exhaust high pressure on start (Excluding the CY851 and the CY852 AND gates)	-	-
	HSRCETRS	RHY030001, MOY 030, NO-FC	-	-
		RHY084001, MOY 084, NO-FC	-	-
WAV0410P1	HS041A00	WAV0410P1, OH (ESW) discharge valve 041 fails, NO-FC	-	-
WAV0420P1	HS042C00	WAV0420P1, OH (ESW) discharge valve 042 fails, NO-FC	-	-
WAV0430P1	HS23C00	WAV0430P1, ESW return block valve 043, NO-FO	-	-
WAV0440P1	HS044B00	WAV0440P1, OH (ESW) discharge valve 044 fails, NO-FC	-	-
WAV0710P1	HS071A00	WAV0710P1, ESW discharge valve 071 fails, NO-FC	-	-
WAV0720P1	HS072D00	WAV0720P1, ESW discharge valve 072 fails, NO-FC	-	-
WAV0730P1	HS073A00	WAV0730P1, ESW return block valve 073, NO-FO	-	-
WAV0740P1	HS074B00	WAV0740P1, ESW discharge valve 074 fails, NO-FC	-	-
WAV1210M1	HS1210M1	WAV1210M1, ESW return block valve 121, NO-FO	-	-
WAV1230M1	HS1230M1	WAV1230M1, ESW return block valve 123, NO-FO	-	-
WAV1250M1	HS1250M1	WAV1250M1, ESW return block valve 125, NO-FO	-	-
WAV1260M1	HS1260M1	WAV1260M1, ESW return block valve 126, NO-FO	-	-
WCY0070M1	HS070A00	WCY0070M1, check valve 1007 failure, ESW flow diverted to spray boro	-	-
WCY0090M1	HS090B00	WCY0090M1, check valve 1009 failure, ESW flow diverted to spray boro	-	-
WCY0110M1	HS110A00	WCY0110M1, failure of check valve 1011 (ESW)	-	-
WCY0120M1	HS120B00	WCY0120M1, failure of check valve 1012 (ESW)	-	-
WCY0620M1	HS0620M1	WCY0620M1, failure of check valve 1062 (ESW)	-	-
WESMPASA	ACESWAFB	WESMPASA, failure of auto start control and logic, ESW pump A	-	-
WESMPASB	ACESWAFC	WESMPASB, failure of auto start control and logic, ESW pump B	-	-
WESMPASC	ACESWAFD	WESMPASC, failure of auto start control and logic, ESW pump C	-	-
WESMPASD	ACESWAFE	WESMPASD, failure of auto start control and logic, ESW pump D	-	-

P70

TABLE N-1. (Continued)

PRA Event	ASER Event	Component/Explanation	<u>Unavailabilty</u>	ASER Event Unavailability Total
WENDA		ESW loop A fails to provide water through system (Excluding the W4 and W41 AND gates)	-	
	HSESWAES	WPPO1AHFI, pipe rupture WZY10600I, OH isolation valve 1006 fails, NO-FC WZY10700I, OH check valve 1007 fails, stuck closed		
WENDB		ESW loop B fails to provide water through systems (Portion not including the W8 and W81 AND gates)		
	HSESB0D2	WPPO1BHFI, pipe rupture WZY10800I, OH isolation valve 1008 fails, NO-FC WZY10900I, OH isolation check valve 1009 fails, stuck closed		
WENDC		ESW loop C fails to provide water through system (Excluding the W8 and W81 AND gates)		
	HSESB0D2	Defined for PRA event WENDB above		
WENIA		ESW pump A fails to supply water (Excluding events DIWIPI and WPSTA)		
	HSESAOFF	WP1ABAHFI, pump piping ruptures		
	HSESWAET	WCOY1ADPI, pump discharge check valve fails, stuck closed WPMABCDW, pump fails to start and run WZY02A00I, pump discharge valve fails, NO-FC WFLABAEI, pump suction plugged		
WENIC		ESW pump C fails to supply water (Excluding events DIWIPI and WPSTC)		
	HSESAOFF	Defined under PRA event WENIA		
	HSESWACEU	WCOY1CDPI, pump discharge check valve fails, stuck closed WPMABCDW, pump fails to start and run WZY02C00I, pump discharge valve fails, NO-FC WFLABAEI, pump suction plugged		
WENIB		ESW pump B fails to supply water (Excluding events DIWIPI and WPSTB)		
	HSESB0DFG	WP1ABBFHI, pump piping ruptures		
	HSESWABEY	WCOY1BDPI, pump discharge check valve fails, stuck closed WPMABCDW, pump fails to start and run WZY02B00I, pump discharge valve fails, NO-FC WFLABAEI, pump suction plugged		
WENID		ESW pump D fails to supply water (Excluding events DIWIPI and WPSTD)		
	HSESWDCEW	WCOY1DDPI, pump discharge check valve fails, stuck closed WPMABCDW, pump fails to start and run WZY02D00I, pump discharge valve fails, NO-FC WFLABAEI, pump suction plugged		
	HSESB0DFG	Defined under PRA event WENIB		
WHNMPMSA	ESESWAES	WHNMPMSA, operator fails to start ESW pump A given auto start failure		
WHNMPMSB	ESESWABEY	WHNMPMSB, operator fails to start ESW pump B given auto start failure		
WHNMPMSC	ESESWACEU	WHNMPMSC, operator fails to start ESW pump C given auto start failure		
WHNMPMSD	ESESWDCEA	WHNMPMSD, operator fails to start ESW pump D given auto start failure		

PPC

TABLE K-1. (Continued)

PRA Event	ASEP Event	Component/Explanation	Unavailability	ASEP Event Unavailability Total
WACT		Insufficient flow from cooling towers to ESW pumps		
	HSESCFTZ	ACT, cooling tower fails		
		WIVY052D01, cooling tower isolation valve fails, NO-FC		
WAMC		Standby ESW pump C fails or is unavailable (Excluding the #PMC OR gate)		
	ENESPCTY	WHAUSEP, operator fails to start standby pump		
	TMESPCTY	WHTMC, standby pump unavailable due to maintenance		
WHADA		ESW Loop A fails to deliver water, hardware failures		
	HSESWAFU	WIVY010D01, loop isolation valve fails, NO-FC		
		WCY011D01, loop check valve fails, stuck closed		
		WCY029D01, loop discharge check valve fails, stuck closed		
		WAV121D01, loop discharge isolation valve fails, NO-FC		
		WAV123D01, loop discharge isolation valve fails, NO-FC		
		WPP123HFI, pipe rupture		
WADOB		ESW Loop B fails to deliver water, hardware failures		
	HSESWBFT	WIVY013D01, loop isolation valve fails, NO-FC		
		WCY012D01, loop check valve fails, stuck open		
		WAV125D01, loop discharge valve fails, NO-FC		
		WAV125D01, loop discharge valve fails, NO-FC		
		WPP125HFI, pipe rupture		
WHADC		ESW Loop C fails to deliver water, hardware failures		
	HSESWCFS	WIVY010H01, loop isolation valve fails, NO-FC		
		WCY062H01, loop check valve fails, stuck closed		
		WCY035H01, loop discharge check valve fails, stuck closed		
		WAV043H01, loop discharge isolation valve fails, NO-FC		
		WAV073H01, loop discharge isolation valve fails, NO-FC		
		WPP023HFI, pipe rupture		
WPRM		Failure of operating ESW pump A		
	HSESPAFY	WIVY44A0D01, butterfly suction valve fails, NO-FC		
		WPM50ADW1, pump unavailable due to failure		
		WCY45AD01, discharge check valve fails, stuck closed		
		WIVY40A0D01, discharge butterfly valve fails, NO-FC		
		WPP50AHFI, piping rupture		
LOSPOAN	EOSP	Failure to provide electric power due to the loss of offsite power		
WPRB		Failure of operating ESW pump B		
	HSESPBFW	WIVY44B0D01, butterfly suction valve fails, NO-FC		
		WPM50BDW1, pump unavailable due to failure		
		WCY45BD01, discharge check valve fails, stuck closed		
		WIVY40B0D01, discharge butterfly valve fails, NO-FC		
		WPP50BHFI, piping rupture		
LOSPOAN	Defined under PRA event WPRM			

~~PROTECTED BY
GOVERNMENT CONTRACTOR~~

TABLE H-1 (Continued)

~~PROPRIETARY~~

PRA Event	ASEP Event	Component/Explanation	Unavailability	ASEP Event Unavailability Total
		Standby ESW pump leg C fails to provide adequate head		
WPS				
	WSESPCF1	WY44CD01, butterfly suction valve fails, RD-FC		
		WY50CD01, standby pump fails to start and run		
		WCY45CDP1, discharge check valve fails, stuck closed		
		WCY40CD01, discharge butterfly valve fails, RD-FC		
		WP50CHF1, pipe rupture		
	LOSPOWAK	Defined under PRA event WPA		
WSD01A		ESW discharge valves in header 1A fail		
	WSSW1ADT	WCY65ADP1, discharge check valve fails, stuck closed		
		WY15AD01, discharge butterfly valve fails, RD-FC		
WSD01B		ESW discharge valves in header 1B fail		
	WSSW1BDT	WY15BD01, discharge butterfly valve fails, RD-FC		
		WCY65BDP1, discharge check valve fails, stuck closed		
WSD02A		ESW discharge valves in header 2A fail		
	WSSW2ADU	WCY64ADP1, discharge check valve fails, stuck closed		
		WY11AD01, discharge butterfly valve fails, RD-FC		
WSD02B		ESW discharge valves in header 2B fail		
	WSSW2BDS	WY11BD01, discharge butterfly valve fails, RD-FC		
		WCY64BDP1, discharge check valve fails, stuck closed		
WTMA	WSESMADQ	WTMA, ESW loop A down for maintenance		
WTMB	WSESMAFR	WTMB, ESW loop B down for maintenance (fails loop C, also)		
WTM002001	WSESCTEA	WY0002001, failure of ESW to discharge back to cooling tower, butterfly valve fails, RD-FC		
I		Timely ADS actuation		
	ESADSPAR	ADSOPRY, supervisor overrules operator to avoid ADS		
		ADSPROC, operating procedures unclear		
		ADSOPER1, operator distracted during critical phase of accident		
		ADSOPER2, operator busy trying to restore high pressure injection systems to operation		
	ADSTRANS	ADSTRANS, transient results in loss of indication of the need for ADS		
I	ESADSI10	I, failure of the operator to manually actuate ABS (use to calculate % for TCV sequence only)		

a. The ANDed combination of these two events leads to a top event described as the failure to isolate leak in Unit A, fails Unit B.

b. The ANDed combination of these two events leads to a top event described as the failure to isolate leak in Unit B, fails Unit A.

c. The unavailability of this event (RTE62CHM1) given in the PRA fault tree is 7.0E-6. This was assumed to be a typographical error based on the following facts: (a) event RTE62CHM1 has an unavailability of 7.0E-5. This event is the same as RTE62CHM1 except that it is in a different train, (b) the top event unavailability of OR gate RIVC0 is the same as that for RIVC2. RIVC2 has two similar events each with an unavailability of 7.0E-5.

~~PROPRIETARY~~