

APPENDIX B

NOTICE OF DEVIATION

Kansas Gas and Electric Company  
Wolf Creek Generating Station

Docket: 50-482  
Permit: CPPR-147

Based on the results of an NRC inspection conducted during the period of September 10 - December 14, 1984, and in accordance with NRC Enforcement Policy (10 CFR Part 2, Appendix C), 49 FR 8583, dated March 8, 1984, the following deviation was identified.

Failure of Procedure to Comply with Applicable ASME Code Requirements for Magnetic Particle Examination

Paragraph T-734.2 in Article 7 of Section V of the ASME Code (1974 Edition through Summer 1975 Addenda) requires that a pole spacing of 3 to 6 inches be used for the yoke method of magnetic particle examination.

In deviation from the above, GEO Procedure No. 21.A.1, Revision 6, dated October 14, 1983, "Magnetic Particle Examination Dry Method," permitted a maximum pole spacing of 8 inches to be used for the yoke method.  
(482/8423-04)

Kansas Gas and Electric Company is hereby requested to submit to this office, within 30 days of the date of this Notice of Deviation, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further deviation from commitments made to the Commission; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

Dated: FEB 25 1985

8503010258 850225  
PDR ADOCK 05000482  
Q PDR