



Carolina Power & Light Company

SERIAL: NLS-85-016

FEB 14 1985

85 FEB 19 9:38

Dr. J. Nelson Grace, Regional Administrator
United States Nuclear Regulatory Commission
Suite 2900
101 Marietta Street, NW
Atlanta, GA 30303

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 AND 2
DOCKET NOS. 50-325 & 50-324/LICENSE NOS. DPR-71 & DPR-62
SUPPLEMENTAL RESPONSE TO IE BULLETIN 84-02

Dear Dr. Grace:

By letter dated July 13, 1984, Carolina Power & Light Company (CP&L) committed to provide a schedule for HFA relay replacement at the Brunswick Steam Electric Plant. The relay replacement for Brunswick-1 is presently scheduled to begin during the Reload 4 Outage (March 1985), and for Brunswick-2 during the maintenance outage scheduled to begin in December 1985. The replacement program has been incorporated into the Brunswick long-range plan in order to more effectively coordinate the implementation of improvements.

In the July 13, 1984 letter, CP&L also stated that a purchase specification was being written to ensure that Non-Century-Series HFA relays would not be purchased for use in safety-related systems. Based on a review of existing administrative controls and the implementation of new controls, it has been determined that the development of a purchase specification will not be required.

Should you have any questions concerning this submittal, please contact Mr. Sherwood R. Zimmerman at (919) 836-6242.

Yours very truly,

A. B. Cutter - Vice President
Nuclear Engineering & Licensing

HS/ccc (1057NLU)

cc: Dr. J. Nelson Grace (NRC-RII)
Mr. D. O. Myers (NRC-BNP)
Mr. M. Grotenhuis (NRC)

8503010279 850214
PDR ADOCK 05000324
Q PDR