

142 DELARONDE STREET P.O. BOX BOOB NEW ORLEANS LOUISIANA

70174-6008

• (504) 368-2345

November 12, 1984

W3P84-3096 3-A1.01.04 3-A20.18 A4.05

Director of Nuclear Reactor Regulation Attention: Mr. G. W. Knighton, Chief Licensing Branch No. 3 Division of Licensing U.S. Nuclear Regulatory Commission Washington, D.C. 20555

Dear Mr. Knighton:

Subject: Waterford 3 SES Docket No. 50-382

Environmental Qualification

Reference: LP&L Letter W3P84-2876 dated 10/18/84

The referenced letter submitted to you an updated version of the Index of Qualification Status/Punchlist Items dated 10/17/84. The purpose of this letter is to provide the closure for the open items identified in the referenced letter for the Punchlist Items.

ITEM	STATUS	COMMENTS
3.1W3 (Sheet 2137)	Closed	Limit and torque switch change-out is complete. CIWA 83E515 is closed and has been incorporated in EQ file.
8.2W3 (Sheets 222 & 223)	Closed	Foxboro tranmitters change-out is complete. All field work has been completed and CIWA 10441 is in closure.
8.4W3	JIO submitted via Letter W3P84-0624 is in place.	CE Report for Ex-Core Neutron Monitoring System received. Testing was successfully completed. CE Report comment resolution and EQ File
8411140248 841112 PDR ADDCK 05000389		development to be completed by 12/15/84.

Mr. G. W. Knighton Page 2 W3P84-3096

ITEM	STATUS	COMMENTS
35.1W3 (Sheets 1217-1219)	Closed	Solenoid model number has been verified. Proper documentation has been incorporated in EQ file.
4.2.3W3	JIO submitted via Letter W3P84-0416 is in place.	Borg-Warner qualification test report is expected by May 1985.

In summary, all of the qualification Status/Punchlist items are complete or a JIO is in place.

Please feel free to call me or Robert J. Murillo at (504) 363-8937 if you have any questions.

Yours very truly,

K.W. Cook

Nuclear Support & Licensing Manager

KWC: RJM: sms

cc: E.L. Blake, W.M. Stevenson, J.T. Collins, D.M. Crutchfield, J. Wilson, G.L. Constable