

SNUPPS

Standardized Nuclear Unit
Power Plant System

5 Choke Cherry Road
Rockville, Maryland 20850
(301) 869-8010

Nicholas A. Petrick
Executive Director

February 25, 1985

SLNRC 85-10 FILE: 0543.1.1
SUBJ: Wolf Creek Technical
Specifications

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Docket No. STN 50-482

- Refs: 1) KGE (G. L. Koester) letter to NRC (H. R. Denton), dated 12/10/84, Same Subject
2) NRC (D. G. Eisenhut) letter to KGE (G. L. Koester), dated 11/7/84, Same Subject
3) SLNRC 85-2, 1/18/85, Same Subject
4) SLNRC 85-04, 1/25/85, Same Subject
5) SLNRC 85-5, 2/1/85, Same Subject
6) SLNRC 85-8, 2/19/85, Same Subject

Dear Mr. Denton:

Reference 1 forwarded KGE's comments on the Final Draft version of Wolf Creek's Technical Specifications as issued by reference 2. Since reference 1, several other changes have been identified which were forwarded with references 3, 4, 5, 6, and this letter.

Very truly yours,

Nicholas A. Petrick
Nicholas A. Petrick

JHR/bds/6a20
Attachments

cc: G. L. Koester	KGE
J. M. Evans	KCPL
D. F. Schnell	UE
J. Neisler/B. Little	USNRC/CAL
H. Bundy	USNRC/WC
W. L. Forney	USNRC/RIII
D. R. Hunter	USNRC/RIV

Boo!

8503010418 850225
PDR ADOCK 05000482
A PDR

TABLE 3.8-1 (Continued)

CONTAINMENT PENETRATION CONDUCTOR
OVERCURRENT PROTECTIVE DEVICES

<u>PROTECTIVE DEVICE NUMBER AND LOCATION</u>	<u>POWERED EQUIPMENT</u>
<u>480-V Motor Control Center (Continued)</u>	
P-52NG01BEF3 B-15A Fuse	Ctmt Recirc Sump Iso Vlv ENHV1
P-52NG01BGF3 B-60A Fuse	Accumulator Iso Vlv EPHV8808A
P-52NG01BGF2 B-60A Fuse	Accumulator Iso Vlv EPHV8808C
P-52NG01BFF2 B-15A Fuse	Ctmt Air to Aux Bldg ESF Filter Iso Vlv GSHV20
P-52NG01BBR2 B-15A Fuse	React Bldg Discharge Iso Vlv LFFV95
P-52NG02BBF3 B-40A Fuse	RHR Loop Inlet Iso Vlv BBPV8702B
P-52NG02BCF2 B-40A Fuse	RHR Loop Inlet Iso Vlv BBPV8702A
P-52NG02BHF3 B-15A Fuse	ESW to Ctmt Air Coolers Iso Vlv EFHV34
P-52NG01BCF2 B-15A Fuse	ESW to Ctmt Air Coolers Iso Vlv EFHV33
P-52NG01BDF2 B-15A Fuse	ESW from Ctmt Air Coolers Iso Vlv EFHV45
P-52NG01BEF2 B-40A Fuse	RHR Loop Inlet Iso Vlv EJHV8701A
P-52NG03CDF4 B-15A Fuse	RCP Thermal Barrier CCW Iso Valve 88HV13
P-52NG03CHF1 B-15A Fuse	RCP Thermal Barrier CCW Iso Vlv 88HV14
P-52PG19NAF4 B-100A Fuse Iso	Reactor Cavity Cooling Fan DCGN02A
P-52PG19NCF3 B-60A Fuse	Ctmt Atmospheric Control System Fan DCGR01A

TABLE 3.8-1 (Continued)

CONTAINMENT PENETRATION CONDUCTOR
OVERCURRENT PROTECTIVE DEVICES

<u>PROTECTIVE DEVICE NUMBER AND LOCATION</u>	<u>POWERED EQUIPMENT</u>
<u>480-V Motor Control Center (Continued)</u>	
P-52PG19NGF2 B-40 Fuse	RCP A Space Heater
P-52PG19NGF3 B-40 Fuse	RCP B Space Heater
P-52PG19NEF1 B-40A Fuse	RCP A Oil Lift Pump
P-52PG19NGR3 B-40A Fuse	RCP B Oil Lift Pump
P-52PG19NFF1 B-15A Fuse	Ctmt Normal Sump Pump DPLF05A
P-52PG19NFF2 B-15A Fuse	Ctmt Normal Sump Pump DPLF05C
P-52PG19NAF2 B-25A Fuse	Instrument Tunnel Sump Pump DPLF07A
P-52NG03CBF4 B-15A Fuse	RCP Thermal Barrier CCW Iso Vlv BBHV15
P-52NG03CLF2 B-15A Fuse	RCP Thermal Barrier CCW ISO Vlv BBHV16
P-52RG20NBF5 B-100A Fuse <i>ISO</i>	Reactor Cavity Cooling Fan DCGN02B
P-52PG20NFF4 B-60A Fuse	Ctmt Atmospheric Control System Fan DCGR01B
P-52PG20NBF1 B-40A Fuse	RCP C Space Heater
P-52PG20NCF1 B-40A Fuse	RCP D Space Heater
P-52PG20NFF3 B-40A Fuse	RCP C Oil Lift Pump
1EPRO8C P-3A Fuse RP139 B-3A Fuse	Accumulator Tank A Isol Vlv EPHV8808A

*submitted previously via
SWRC 85-8, 2/19/85*

TABLE 3.8-1 (Continued)

CONTAINMENT PENETRATION CONDUCTOR
OVERCURRENT PROTECTIVE DEVICES

<u>PROTECTIVE DEVICE NUMBER AND LOCATION</u>	<u>POWERED EQUIPMENT</u>
<u>Low Voltage Power and Control (Continued)</u>	
15 1BBK40A P-30A Fuse	PZR PORV
NK5108 B-30A Fuse	BBPCV455A
40 15 48BK04B P-30A Fuse	PZR PORV
15 NK4421 B-30A Fuse	BBPCV456A
5BGK04B P-3A Fuse	Alternate Charging Path Isol Valv
RL001 B-3A Fuse	BGHV8147
6BGK04A P-3A Fuse	Normal Charging Path Isol Valv
RL001 B-3A Fuse	BGHV8146
P-5LFY10A 3A Fuse	Containment Cooler Drain Valve
RL023	LFLV97
B-5RLY01H 15A Breaker	
PG19GCR217	
P-5LFY10C 3A Fuse	Containment Cooler Drain Valve
RL023	LFLV99
B-5RLY01H 15A Breaker	
PG19GCR217	
P-6LFY10B 3A Fuse	Containment Cooler Drain Valve
RL023	LFLV98
B-6RLY01G 15A Breaker	
PG20GBR217	
P-6LFY10D 3A Fuse	Containment Cooler Drain Valve
RL023	LFLV100
B-6RLY01G 15A Breaker	
PG20GBR217	
P-6LFY17A 3A Fuse	Refueling Pool Stand Pipe
RL023	Discharge Valve
B-6RLY01G 15A Breaker	LFLV122
PG20GBR217	
P-5LFY20A 15A Breaker	Instrument Tunnel Sump Moisture
PG19NHF224	Sensor
B-5LFY20A 30A Fuse	TLVF01
PG19NHF1	

TABLE 3.8-1 (Continued)

CONTAINMENT PENETRATION CONDUCTOR
OVERCURRENT PROTECTIVE DEVICES

<u>PROTECTIVE DEVICE</u> <u>NUMBER AND LOCATION</u>	<u>POWERED</u> <u>EQUIPMENT</u>
<u>Low Voltage Power and Control (Continued)</u>	
P-5SJY06C 3A Fuse RP211 B-5RPY09D 15A Breaker PG19NHF236	Press Liquid Space Samp Isol Vlv SJHV20
P-48MY01A 3A Fuse RL024 B-4RLY01H 15A Breaker NG02ACR127	S.G. A Out to Nuc Sample Sys Vlv BMHV19
P-48MY01B 3A Fuse RL024 B-4RLY01H 15A Breaker NG2ACR127	S.G. B Out to Nuc Sample Sys Vlv BMHV20
P-48MY01C 3A Fuse RL024 B-4RLY01H 15A Breaker NG02ACR127	S.G. C Out to Nuc Sample Sys Vlv BMHV21
P-5GNY08A 3A Fuse RL020 B-5RLY01L 15A Breaker PG19GCR230	CRDM Cooling Discharge Damper GNHZ71
P-5GNY08C 3A Fuse RL020 B-5RLY01L 15A Breaker PG19GCR230	CRDM Cooling Discharge Damper GNHZ73
P-6QNY08 ^C 3A Fuse RL020 B-6RLY01J 15A Breaker PG20GBR222	CRDM Cooling Discharge Damper GNHZ72
P-6GNY08 ^A 3A Fuse RL020 B-6RLY01J 15A Breaker PG20GBR222	CRDM Cooling Discharge Damper GNHZ74
5BGK10A P-3A Fuse RL001 B-3A Fuse	Normal Letdown Isolation Vlv BGLCV459

*submitted previously
via KLMAC 84-226, 12/10/84*

TABLE 3.8-1 (Continued)

CONTAINMENT PENETRATION CONDUCTOR
OVERCURRENT PROTECTIVE DEVICES

<u>PROTECTIVE DEVICE NUMBER AND LOCATION</u>	<u>POWERED EQUIPMENT</u>
<u>Low Voltage Power and Control (Continued)</u>	
6GNG04B P-6A Fuse PG20NBF5 B-4A Fuse	Cavity Cooling Fan Discharge Damper GNHZ48
1HBK03A P-3A Fuse RL021 B-3A Fuse	RCDT Vapor Space CTMT Isol Vlv HBHV7126
6HBK04A P-3A Fuse HB115 B-3A Fuse	RCDT Vapor Space CTMT Isol Vlv HBHV7127
5EPY07B P-3A Fuse RP043 B-15A CB-1	Accumulator Tank Discharge Valve Position Switch EPHV8808DA EPHV88088A
6EPY07A P-3A Fuse RP044 B-15A CB-1	Accumulator Tank Discharge Valve Position Switch EPHV8808AA EPHV8808CA
6GTY12A P-15A Breaker PG20GBRZ34 B-20A Fuse 2	CTMT Minipurge Exhaust Isolation Damper GTHZ41
6GTY12A P-15A Breaker PG20GBRZ34 B-20A Fuse 2	CTMT Minipurge Exhaust Isolation Damper GTHZ42
P-5SRY09A 5A Fuse SF057 P-5SRY09A 20A Breaker PG19GEF6	In-Core Neutron Monitoring Drive Unit Heater SRO1A, B
P-5SRY09A 5A Fuse SR057 B-5SRY09A 20A Breaker PG19GEF6	In-Core Neutron Monitoring Drive Unit Heater SRO1C, D

TABLE 3.8-1 (Continued)

CONTAINMENT PENETRATION CONDUCTOR
OVERCURRENT PROTECTIVE DEVICES

<u>PROTECTIVE DEVICE NUMBER AND LOCATION</u>	<u>POWERED EQUIPMENT</u>
<u>Low Voltage Power and Control (Continued)</u>	
5BBK14C P-3A Fuse RK021 B-3A Fuse	RCP Standpipe Makeup Vlv BBLCV180
5BBK14D P-3A Fuse RK021 B-3A Fuse	RCP Standpipe Makeup Vlv BBLCV181
6BBK14A P-3A Fuse RL021 B-3A Fuse	RCP Standpipe Makeup Vlv BBLCV178
6BBK14B P-3A Fuse RL021 B-3A Fuse	RCP Standpipe Makeup Vlv BBLCV179
5BBK15B P-3A Fuse RL021 B-3A Fuse	Reactor Coolant Loops Instrumentation
5BBK15C P-3A Fuse RL021 B-3A Fuse	Reactor Coolant Loops Instrumentation
6BBK15D P-3A Fuse RL021 B-3A Fuse	Reactor Coolant Loops Instrumentation
6BBK15E P-3A Fuse RL021 B-3A Fuse	Reactor Coolant Loops Instrumentation
5BBK19A P-3A Fuse RL002 B-3A Fuse	Pressurizer Spray Valve BBPCV455B
5BBK19B P-3A Fuse RL002 B-3A Fuse	Pressurizer Spray Valve BBPCV455C
1BBK30A P-3A Fuse RL021 B-3A Fuse	Reactor Vessel Head Vent Vlv BBHV8001A
6GNG03B P-5A Fuse NG02BJF5 B-3A Fuse	CRDM Cooling Fan B Discharge Isolation Damper GNHZ42
6GNG03D P-5A Fuse PG20GAR2 B-3A Fuse	CRDM Cooling Fan A Discharge Isolation Damper GNHZ41
5GNG04A P-6A Fuse PG19NAF4 B-4A Fuse	Cavity Cooling Fan Discharge Damper GNHZ47

TABLE 3.8-1 (Continued)

CONTAINMENT PENETRATION CONDUCTOR
OVERCURRENT PROTECTIVE DEVICES

PROTECTIVE DEVICE
NUMBER AND LOCATION

POWERED
EQUIPMENT

Low Voltage Power and Control (Continued)

1EJG05B P-2A Fuse NG01BDF3 B-1A Fuse	RHR Shutdown Suction Line Isolation Valve EJHV8701B
1EJG06A P-2A Fuse NG01BFF3 B-1A Fuse	Cont Recirc Sump Isolation Valve EJHV8811A
4EJG06B P-2A Fuse NG02BEF2 B-2A Fuse	Cont Recirc Sump Isolation Valve EJHV8811B
1EJK07A P-3A Fuse RL017 B-3A Fuse	Test Line Isol Vlv Hot Leg Inj Line Solenoid EJHCV8825
1EJK07C P-3A Fuse RL017 B-3A Fuse	RHR Test Line Vlv EJHCV8890A
4EJK07B P-3A Fuse RL017 B-3A Fuse	RHR Test Line Vlv EJHCV8890B
P-1EJY13A 3A Fuse RL011 B-1RLY01G 15A Breaker NG01ACR119	Ctmt Sump Sample Isolation Vlv EJHV21
P-4EJY13B 3A Fuse RL011 B-4RLY01G 15A Breaker NG02ACR140	Ctmt Sump Sample Isolation Vlv EJHV22
P-48MY01D 3A Fuse RL024 B-4RLY01H 15A Breaker NG02ACR127	S.G.C Cnt to Nuc Sample Sys Vlv BMHV22
P-48MY02A 3A Fuse RL024 B-4RLY01H 15A Breaker NG02ACR127	S.G.A Tube Sheet Sample Vlv BMHV25
P-48MY02B 3A Fuse RL024 B-4RLY01H 15A Breaker NG02ACR127	S.G.B Tube Sheet Sample Vlv BMHV36