



Public Service Electric and Gas Company P.O. Box 236 Hancocks Bridge, New Jersey 08038-0236

Nuclear Business Unit

APR 26 1996

LR-N96117

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Dear Sir:

HOPE CREEK GENERATING STATION
DOCKET NO. 50-354
UNIT NO. 1
LICENSEE EVENT REPORT NO. 95-033-05

This Licensee Event Report entitled "Technical Specification Surveillance Requirement Implementation Deficiencies" is being submitted pursuant to the requirements of 10CFR50.73(a)(2)(i)(B).

This supplement documents the discovery of a Technical Specification surveillance implementation deficiency identified by the Technical Specification Surveillance Improvement Program (TSSIP). As stated in LER 95-033-01, additional Technical Specification surveillance implementation deficiencies discovered by TSSIP with minimal safety significance will be documented in supplements to this LER on a periodic basis until completion of the TSSIP project.

Sincerely,

Mark E. Reddemann
General Manager -
Hope Creek Operations

Attachment

JPP
SORC Mtg. 96-047

C Distribution
LER File

9605020145 960426
PDR ADOCK 05000354
S PDR

69

IE22%

Attachment A

The following items represent commitments that Public Service Electric & Gas (PSE&G) made to the Nuclear Regulatory Commission (NRC) relative to this LER (354/95-033-05). The commitments are as follows:

1. Surveillance test procedures for the quarterly and semi-annual APRM Channel Calibrations will be revised to ensure that they are performed in accordance with the Technical Specification definitions. These procedure revisions will be completed by June 30, 1996.
2. Operations procedures will be revised to incorporate guidance on the performance of APRM, SRM and IRM surveillances. These procedure revisions will be completed by June 30, 1996.