U.S. NUCLEAR REGULATORY COMMISSION NRC Form 366 APPROVED OMB NO 3150-0104 EXPIRES 8 31 85 LICENSEE EVENT REPORT (LER) DONALD C. COOK NUCLEAR PLANT UNIT 1 1 OF 0 1 0 15 10 10 10 13 11 15 ACTUATION OF ENGINEERED SAFETY FEATURE LER NUMBER 6 REPORT DATE (7) OTHER FACILITIES INVOLVED IS EVENT DATE (5) FACILITY NAMES DOCKET NUMBER S EQUENTIAL NUMBER REVISION MONTH YEAR YEAR MONTH DAY VEAR 0 | 5 | 0 | 0 | 0 | 219 0 0 0 2 0 11 8 5 8 5 0 0 4 2 5 0 | 5 | 0 | 0 | 0 | THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR & Check one or more of the followings (11) OPERATING 1 20 402(b) 20 406 (e) 73 71(6) 50 73(a)(2)(v) 73.71(c) 20 406(+)(1)(i) 50 36(e)(1) 8, 9,0 OTHER Specify in Adstract below and in Text NAC Form 366A) 50.73(a)(2)(vii) 20 406(4)(13(4) 50 36(c)(2) 20 406(a)(1)(m) 50.73(a)(2)(i) 50 73(a)(2)(viii)(A) 20 406(a)(1)(iv) 50.73(a)(2)(ii) 50 73(a)(2)(viii)(8) 50 73(a)(2)(x) 20 406(a)(1)(v) 50.73(a)(2)(iii) LICENSEE CONTACT FOR THIS LER (12) TELEPHONE NUMBER NAME AREA CODE T. A. KRIESEL -TECHNICAL PHYSICAL SCIENCES SUPERINTENDENT 6 1 6 4 16151-151901 COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13) MANUFAC TURER REPORTABLE TO NPROS TO NPACE MANUFAC CAUSE SYSTEM COMPONENT CAUSE SYSTEM COMPONENT

ABSTRACT (Limit to 1400 spaces i.e. approximately fifteen single space typewritten lines) (16)

YES IT VAL COMPLETE EXPECTED SUBMISSION DATE

SUPPLEMENTAL REPORT EXPECTED (14)

ON JANUARY 29, 1985 AT 1521 HOURS WITH THE REALIOR IN MODE 1 AT 8 PERCENT POWER, A HIGH ALARM WAS RECEIVED ON THE LOWER CONTAINMENT RADIATION MONITOR (ERS-1401) THAT RESULTED IN A CONTAINMENT ISOLATION, AN AUTOMATIC ACTUATION OF AN ENGINEERED SAFETY FEATURE (TECHNICAL SPECIFICATION 3.3.2.1, TABLE 3.3-4, ITEM 3.C.3).

REACTOR POWER WAS BEING INCREASED CAUSING THE CONTAINMENT AIRBORNE ACTIVITY TO TREND UPWARD. THE SETPOINT FOR THE ERS-1401 HIGH ALARM WAS 9.53E-2 MICRO CURIES WHICH IS 1.2 TIMES THE LAST TEN MINUTE AVERAGE. TECHNICAL SPECIFICATION REQUIRES A SETPOINT VALUE LESS THAN OR EQUAL TO 2 TIMES THE BACKGROUND. THE ALARM RESULTED IN THE AUTOMATIC CLOSURE OF THE TRAIN B CONTAINMENT ISOLATION VALVE FOR THE CONTAINMENT PRESSURE RELIEF SYSTEM (VCR-207) WHICH WAS IN SERVICE AT THIS TIME. AT THE TIME OF THIS OCCURRENCE THE CONTAINMENT PRESSURE RELIEF PROCEDURE DID NOT ADDRESS EXPECTED RESULTS OR PREPLANNED SEQUENCES AS IDENTIFIED IN 10 CFR 50.73 (A)(2)(IV).

THERE WERE NO ADVERSE CONSEQUENCES FROM THIS EVENT, ALL SYSTEM COMPONENTS FUNCTIONED AS DESIGNED.

TO PREVENT RECURRENCE A PROCEDURE CHANGE WILL BE MADE BY MARCH 8, 1985 TO IDENTIFY EXPECTED RESULTS OR PREPLANNED SEQUENCES WHICH WILL PREVENT THE NEED TO REPORT ANY SIMILAR EXPECTED INCIDENTS OF THIS NATURE.

PREVIOUS OCCURRENCES OF A SIMILAR NATURE INCLUDE: 50-315/84-012; 50-315/84-003; 50-316/84-010.

8503060590 850225 PDR ADOCK 05000315 TEN

YEAR

MONTH

EXPECTED

24

DONALD C. COOK NUCLEAR PLANT P.O. Box 458, Bridgman, Michigan 49106 (616) 465-5901

February 25, 1985

United States Nuclear Regulatory Commission Document Control Desk Washington, D.C. 20555

Operating License DPR-58 Docket No. 50-315

Document Control Manager:

In accordance with the criteria established by 10CFR50.73 entitled Licensee Event Reporting System, the following report/s are being submitted:

RO 85-004-0

Sincerely,

W.G. Smith, Jr. Plant Manager

/cbm

Attachment

cc: John E. Dolan
J.G. Keppler, RO:III
M.P. Alexich
R.F. Kroeger
H. Brugger
NRC Resident Inspector
R.C. Callen, MPSC
G. Charnoff, Esq.
J.M. Hennigan
INPO
PNSRC
J.F. Stietzel
Dottie Sherman, ANI Library