

DUKE POWER COMPANY

P.O. BOX 33169
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

November 12, 1984

TELEPHONE
(704) 373-4531

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Ms. E. G. Aransam, Chief
Licensing Branch No. 4

Subject: McGuire Nuclear Station
Docket Nos. 50-369 and 50-370
Technical Specifications for the Cold Leg Accumulator
Isolation Valve

Dear Mr. Denton:

Attached are proposed license amendments to Facility Operating Licenses NPF-9 and NPF-17 for McGuire Nuclear Station Units 1 and 2, respectively. The proposed changes seek to delete surveillance requirement 4.5.1.1.1.d for the Cold Leg Accumulator Isolation Valve's automatic actuation. The automatic actuation feature has been made obsolete by the Duke Power Company procedure for operation and it no longer fulfills any safety function. The testing requirement for the automatic actuation feature for the cold leg accumulator isolation valve is thus no longer necessary.

Attachment I contains the proposed Technical Specification changes. Attachment II provides the Justification and Safety Analysis in support of the proposed changes. Attachment III provides an analysis performed in accordance with the standards contained in 10CFR 50.92 as required by 10CFR50.91. These analyses conclude that the proposed changes do not have any adverse safety or environmental impact.

This request involves an application for amendment to the McGuire Technical Specifications. Accordingly, pursuant to 10CFR170.21 a check for \$150.00 is enclosed.

Please feel free to contact us if you require any additional information.

Very truly yours,



Hal B. Tucker

WHM/mjf

Attachment

8411150038 841112
PDR ADOCK 05000369
P PDR

Rec'd w/ check \$150.00
#764562


Acc 1
11

Mr. Harold R. Denton, Director
November 12, 1984
Page 2

cc: Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30323


W. T. Orders
Senior Resident Inspector
McGuire Nuclear Station

HAL B. TUCKER, being duly sworn, states that he is Vice President of Duke Power Company; that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this revision to the McGuire Nuclear Station License Nos. NPF-9 and NPF-17 and that all statements and matters set forth therein are true and correct to the best of his knowledge.



Hal B. Tucker, Vice President

Subscribed and sworn to before me this 12th day of November, 1984



Notary Public

My Commission Expires:

September 20, 1989