

ENCLOSURE 1

NOTICE OF VIOLATION

Georgia Power Company
Hatch 1 and 2

Docket Nos. 50-321 and 50-366
License Nos. DPR-57 and NPF-5

The following violation was identified during an inspection conducted on July 16-20, 1984. The Severity Levels were assigned in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C).

10 CFR 20.203(b) requires that each radiation area be conspicuously posted with a sign or signs bearing the radiation caution symbol and the words: Caution - Radiation Area.

Contrary to the above, the area around containers of demineralizer filters stored in the waste handling building and reading 16 mr/hr at about 18 inches, was not posted as a radiation area on July 18, 1984.

This is a Severity Level IV violation (Supplement IV).

Pursuant to 10 CFR 2.201, you are required to submit to this office within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violations; (2) the reasons for the violations if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved.

Security or safeguards information should be submitted as an enclosure to facilitate withholding it from public disclosure as required by 10 CFR 2.790(d) or 10 CFR 73.21.

Date: AUG 20 1984