

ENCLOSURE 1

NOTICE OF VIOLATION

Georgia Power Company  
Hatch Unit 1

Docket No. 50-321  
License No. DPR-57

The following violation was identified during an inspection conducted on July 21 - August 20, 1984. The Severity Level was assigned in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C).

Technical Specification 6.8.1.a requires that written procedures shall be established, implemented and maintained covering the applicable procedures recommended in Appendix "A" of Regulatory Guide 1.33, Revision 2, February 1978.

Contrary to the above, procedures were not properly implemented in that on August 1, 1984, two snubbers were removed from Unit 1 Residual Heat Removal (RHR) system in violation of work instructions (MR 1-843763 work process sheet) which required the worker to "obtain necessary clearances and notify responsible engineer." No clearances were obtained prior to removal of snubbers E11-RHRH-193 or E11-RHRH-199.

This is a Severity Level IV violation (Supplement I).

Pursuant to 10 CFR 2.201, you are required to submit to this office within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violations; (2) the reasons for the violations if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved.

Security or safeguards information should be submitted as an enclosure to facilitate withholding it from public disclosure as required by 10 CFR 2.790(d) or 10 CFR 73.21.

Date: AUG 30 1984

8411150275 841011  
PDR ADOCK 05000321  
Q PDR