

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) Vermont Yankee Nuclear Power Corporation	DOCKET NUMBER (2) 0 5 0 0 0 2 7 1	PAGE (3) 1 OF 0 2
---	--------------------------------------	----------------------

TITLE (4)
Missed LPCI Surveillance Test

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)		
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES		DOCKET NUMBER(S)
0 1	2 8	8 5	8 5	0 0 2	0 0	0 2	2 6	8 5			0 5 0 0 0
											0 5 0 0 0

OPERATING MODE (9)	THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 5. (Check one or more of the following) (11)										
POWER LEVEL (10) 1 0 0	23.402(b)			20.408(a)			80.736(a)(2)(iv)			73.71(b)	
	20.408(a)(1)(i)			80.38(a)(1)			80.736(a)(2)(v)			73.71(e)	
	26.408(a)(1)(ii)			80.38(a)(2)			80.736(a)(2)(vi)			OTHER (Specify in Abstract below and in Text, NRC Form 305A)	
	20.408(a)(1)(iii)			X 80.736(a)(2)(i)			80.736(a)(2)(viii)(A)				
	20.408(a)(1)(iv)			80.736(a)(2)(ii)			80.736(a)(2)(viii)(B)				
20.408(a)(1)(v)			80.736(a)(2)(iii)			80.736(a)(2)(ix)					

LICENSEE CONTACT FOR THIS LER (12)

NAME James P. Pelletier, Plant Manager	TELEPHONE NUMBER AREA CODE: 8 0 2 2 5 7 - 7 7 1 1
---	---

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS

SUPPLEMENTAL REPORT EXPECTED (14)

<input type="checkbox"/> YES (If yes, complete EXPECTED SUBMISSION DATE) <input type="checkbox"/> NO	EXPECTED SUBMISSION DATE (15) MONTH: DAY: YEAR:
---	--

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

On 1/28/85 the plant was at 100 percent power during normal operation. Upon review of the master surveillance list, it was found that a quarterly calibration of LPCI low reactor pressure #3 channel was not performed during the week of 10/25/84 as required by Tech. Spec. Table 4.2.1. System operability was subsequently verified when the instrumentation was functionally tested and calibrated on 1/23/85. The calibration was missed because the pressure switch was replaced during the last refueling outage with analog instrumentation that normally requires calibration only once per operating cycle. The quarterly calibration was changed to once per operating cycle in the surveillance list based on the anticipated Tech. Spec. amendment.

8503060808 850226
PDR ADOCK 05000271
S PDR


IE22 111

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1) Vermont Yankee Nuclear Power Corporation	DOCKET NUMBER (2) 0 5 0 0 0 2 7 1	LER NUMBER (6)			PAGE (3)	
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		
		8 5	- 0 0 2	- 0 0	0 2	OF 0 2

TEXT (If more space is required, use additional NRC Form 386A's) (17)

On 1/28/85 the plant was at 100 percent power during normal operation. While reviewing the updated master surveillance list against the Tech. Spec. requirements, it was found that a quarterly calibration of LPCI low reactor pressure #3 channel was not performed during the week of 10/25/84 as required by Tech. Spec. Table 4.2.1. System operability was subsequently verified when the instrumentation was functionally tested and calibrated on 1/23/85. The calibration was missed because the pressure switch was replaced during the last refueling outage with a pressure transmitter and analog trip unit and similar instrumentation normally requires calibration only once per operating cycle. The quarterly calibration was changed to once per cycle in the surveillance list based on the anticipated Tech. Spec. amendment. The Tech. Spec. amendment, however, was erroneously processed, resulting in the wrong instrument being changed. This error resulted in not performing the surveillance in accordance with the Tech. Spec. A revised proposed change is currently being prepared to correct the error. In the interim, a quarterly surveillance will be performed. No similar occurrences of this type have been reported to the Commission.



VERMONT YANKEE NUCLEAR POWER CORPORATION

P. O. BOX 157
GOVERNOR HUNT ROAD
VERNON, VERMONT 05354

February 26, 1985

VYV85-02

U.S. Nuclear Regulatory Commission
Document No. 50-271
Washington, D.C. 20555

REFERENCE: Operating License DPR-28
Docket No. 50-271
Reportable Occurrence No. LER 85-02

Dear Sirs:

As defined by 10CFR50.73, we are reporting the attached Reportable Occurrence as LER 85-02.

Very truly yours,

VERMONT YANKEE NUCLEAR POWER CORPORATION

James P. Pelletier
Plant Manager

RDP/jbb

cc: Regional Administrator
USNRC Office of Inspection and Enforcement
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

IE22
1/1