

Appendix

NOTICE OF VIOLATION

Monticello Nuclear Generating Plant

Docket No. 50-263

As a result of the inspection conducted on October 1-3, 1984, and in accordance with the General Policy and Procedures for NRC Enforcement Actions, (10 CFR Part 2, Appendix C), the following violation was identified:

10 CFR 50.54(q) states in part that a licensee authorized to operate a nuclear power reactor shall follow and maintain in effect emergency plans which meet the standards of 10 CFR 50.47(b) to this part and the requirements of Appendix E to this part. Section 8.1 of the Monticello Nuclear Generating Plant Emergency Plan states in part that specialized training of plant and support personnel necessary to achieve and maintain an acceptable level of emergency preparedness is covered in the Corporate Nuclear Emergency Plan. Section 10.3 of the Corporate Nuclear Emergency Plan states in part that training was presented initially when all plans and procedures were finalized, and re-training will be conducted annually in accordance with the Emergency Plan Supplemental Procedures and the Emergency Plan Training Program. This section further states that emergency response personnel will be trained for those who occupy the position of Directors or Coordinators of the Emergency Response Organizations.

Contrary to the above, four Emergency Director designees had not received the annual emergency preparedness training during calendar years 1983 or 1984, through September.

This is a Severity Level IV violation (Supplement VIII).

Pursuant to the provisions of 10 CFR 2.201, you are required to submit to this office within thirty days of the date of this Notice a written statement or explanation in reply, including for the item of noncompliance: (1) corrective action taken and the results achieved; (2) corrective action to be taken to avoid further noncompliance; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

10/23/84  
Dated

L. R. Greger  
L. R. Greger, Chief  
Emergency Preparedness and  
Radiological Protection Branch

8411160036 841023  
PDR ADDCK 05000263  
PDR  
Q