

ENCLOSURE 2  
SEQUOYAH NUCLEAR PLANT  
RADICALOGICAL IMPACT ASSESSMENT REPORT

9605030307 960429  
PDR ADOCK 05000327  
R PDR

## **INTRODUCTION**

Potential doses to maximum individuals and the population around Sequoyah are calculated for each quarter as required in Section 5.2 of the Offsite Dose Calculation Manual (ODCM). Measured plant releases for the reporting period are used to estimate these doses. Dispersion of radioactive effluents in the environment is estimated using meteorological data and riverflow data measured during the period. In this report, the doses resulting from releases are described and compared to limits established for Sequoyah.

## **DOSE LIMITS**

The ODCM specifies limits for the release of radioactive effluents, as well as limits for doses to the general public from the release of radioactive effluents. These limits are set well below the Technical Specification limits which govern the concentrations of radioactivity and doses permissible in unrestricted areas. This ensures that radioactive effluent releases are As Low As Reasonably Achievable.

The limits for doses in unrestricted areas from airborne noble gases releases are:

Less than or equal to 5 mrad per quarter and  
10 mrad per year (per reactor unit) for gamma radiation, and  
Less than or equal to 10 mrad per quarter and  
20 mrad per year (per reactor unit) for beta radiation.

The limit for the dose to a member of the general public in an unrestricted area from iodines and particulates released in airborne effluents is:

Less than or equal to 7.5 mrem per quarter and  
15 mrem per year (per reactor unit) to any organ.

The limit for doses to a member of the general public from radioactive material in liquid effluents released to unrestricted areas, is:

Less than or equal to 1.5 mrem per quarter and  
3 mrem per year (per reactor unit) to the total body, and  
Less than or equal to 5 mrem per quarter and  
10 mrem per year (per reactor unit) to any organ

The EPA limits for total dose to the public in the vicinity of a nuclear power plant, established in the Environmental Dose Standard of 40 CFR 190, are:

Less than or equal to 25 mrem per year to the total body,  
Less than or equal to 75 mrem per year to the thyroid, and  
Less than or equal to 25 mrem per year to any other organ.

## **DOSE CALCULATIONS**

Estimated doses to the public are determined using computer models (the Gaseous Effluent Licensing Code, GELC, and the Quarterly Water Dose Assessment Code, QWATA). These models are based on guidance provided by the NRC (in Regulatory Guides 1.109, 1.111 and 1.113) for determining the potential dose to individuals and populations living in the vicinity of the plant. The area around the plant is analyzed to determine the pathways through which the public may receive a dose. The doses calculated are a representation of the dose to a "maximum exposed individual." Some of the factors used in these calculations (such as ingestion rates) are maximum values. Many of these factors are obtained from NUREG/CR-1004. The values chosen will tend to overestimate the dose to this "maximum" person. The expected dose to actual individuals is lower. The calculated doses are presented in Tables 1 through 9.

## **DOSES FROM AIRBORNE EFFLUENTS**

For airborne effluents, the public can be exposed to radiation from several sources: direct radiation from the radioactivity in the air, direct radiation from radioactivity deposited on the ground, inhalation of airborne radioactivity, ingestion of vegetation which contains radioactivity deposited from the atmosphere, and ingestion of milk and beef which contains radioactivity deposited from the atmosphere onto vegetation and subsequently eaten by milk and beef animals.

### Airborne Discharge Points

All releases from Sequoyah are considered ground-level releases. The ground-level Joint Frequency Distribution (JFD) is derived from windspeeds and directions measured 10 meters above ground and from the vertical temperature difference between 10 and 46 meters, and are presented for each quarter in Attachment 1.0

### Meteorological Data

Meteorological variables at Sequoyah are measured continuously. Measurements collected include wind speed, wind direction, and temperature at heights of 10, 46, and 91 meters above the ground. Quarterly joint frequency distributions (JFDs) are calculated for each release point using the appropriate levels of meteorological data. A joint frequency distribution gives the percentage of the time in a quarter that the wind is blowing out of a particular upwind compass sector in a particular range of wind speeds for a given stability class A through G. The wind speeds are divided into nine wind speed ranges. Calms are distributed by direction in proportion to the distribution of noncalm wind directions less than 0.7 m/s (1.5 mph). Stability classes are determined from the vertical temperature difference between two measurement levels.

## **Radiological Impact Assessment**

Sequoyah Nuclear Plant

January - December 1995

Page 3 of 17

### External Exposure Dose

Dose estimates for maximum external air dose (gamma-air and beta-air doses) are made for points at and beyond the unrestricted area boundary as described in the Sequoyah ODCM. The highest of these doses is then selected.

### Submersion Dose

External doses to the skin and total body, due to submersion in a cloud of noble gases, are estimated for the nearest residence in each sector. The residence with the highest dose is then selected from all sectors.

### Organ Dose

Doses to organs due to releases of airborne effluents are estimated for the inhalation, ground contamination, and ingestion pathways. The ingestion pathway is further divided into four possible contributing pathways: ingestion of cow/goat milk, ingestion of beef, and ingestion of vegetables. Doses from applicable pathways are calculated for each real receptor location identified in the most recent land use survey. To determine the maximum organ dose, the doses from the pathways are summed for each receptor. For the ingestion dose, however, only those pathways that exist for each receptor are considered in the sum, i.e., milk ingestion doses are included only for locations where milk is consumed without commercial preparation and vegetable ingestion is included only for those locations where a garden is identified. To conservatively account for beef ingestion, a beef ingestion dose equal to that for the highest unrestricted area boundary location is added to each identified receptor. For ground contamination, the dose added to the organ dose being calculated is the total body dose calculated for that location, i.e., it is assumed that the dose to an individual organ is equal to the total body dose.

Doses from airborne effluents are presented in Tables 1 through 4.

**DOSES FROM LIQUID EFFLUENTS**

For liquid effluents, the public can be exposed to radiation from three sources: the ingestion of water from the Tennessee River, the ingestion of fish caught in the Tennessee River, and direct exposure from radioactive material deposited on the river shoreline sediment (recreation).

The concentrations of radioactivity in the Tennessee River are estimated by a computer model which uses measured hydraulic data downstream of Sequoyah. Parameters used to determine the doses are based on guidance given by the NRC (in Regulatory Guides 1.109) for maximum ingestion rates, exposure times, etc. Wherever possible, parameters used in the dose calculation are site specific use factors determined by TVA. The models that are used to estimate doses, as well as the parameters input to the models, are described in detail in the Sequoyah Nuclear Plant ODCM.

**Liquid Release Points and River Data**

Radioactivity concentrations in the Tennessee River are calculated assuming that releases in liquid effluents are continuous. All routine liquid releases from Sequoyah, located at Tennessee River Mile 484, are made through diffusers which extend into the Tennessee River. It is assumed that releases to the river through these diffusers will initially be entrained in one-fifth of the water which flows past the plant. The QWATA code makes the assumption that this mixing condition holds true until the water is completely mixed at the first downstream dam, at Tennessee River Mile 471.0.

Doses are calculated for locations within a 50 mile radius downstream of the plant site. The maximum potential recreation dose is calculated for a location immediately downstream from the plant outfall. The maximum individual dose from ingestion of fish is assumed to be that calculated for the consumption of fish caught anywhere between the plant and the first downstream dam (Chickamauga Dam). The maximum individual dose from drinking water is assumed to be that calculated at the nearest downstream public water supply (E. I. DuPont). This could be interpreted as indicating that the maximum individual, as assumed for liquid releases from Sequoyah, is an individual who obtains all of his drinking water at E. I. DuPont, consumes fish caught from the Tennessee River between Sequoyah and Chickamauga Dam, and spends 500 hours per year on the shoreline just below the outfall from Sequoyah. Dose estimates for the maximum individual due to liquid effluents for each quarter in the period are presented in Tables 5 through 8, along with the average river flows past the plant site for the periods.

**POPULATION DOSES**

Population doses for highest exposed organ due to airborne effluents are calculated for an estimated 1,060,000 persons living within a 50-mile radius of the plant site. Doses from external pathways and inhalation are based on the 50-mile human population distribution. Ingestion population doses are calculated assuming that each individual consumes milk, vegetables, and meat produced with the sector annulus in which he resides. Doses from external pathways and inhalation are based on the 50-mile human population distribution.

**Radiological Impact Assessment**

Sequoah Nuclear Plant

January - December 1995

Page 5 of 17

Population doses for total body and the maximum exposed organ due to liquid effluents are calculated for the entire downstream Tennessee River Population. Water ingestion population doses are calculated using actual population figures for downstream public water supplies. Fish ingestion population doses are calculated assuming that all sport fish caught in the Tennessee River are consumed by the Tennessee River population. Recreation population doses are calculated using actual recreational data on the number of shoreline visits at downstream locations.

Population dose estimates for airborne and liquid effluents are presented in Tables 1 through 8.

**DIRECT RADIATION**

External gamma radiation levels were measured by thermoluminescent dosimeters (TLDs) deployed around Sequoyah. The quarterly gamma radiation levels determined from these TLDs during this reporting period averaged approximately 14.8 mR/quarter at onsite stations and approximately 13.4 mR/quarter at offsite stations, or approximately 1.4 mR/quarter higher onsite than at offsite stations. This is consistent with levels reported at TVA's non operating nuclear power plant construction sites where the average radiation levels onsite are generally 2-6 mR/quarter higher than the levels offsite. This may be attributable to natural variations in environmental radiation levels, earth moving activities onsite, the mass of concrete employed in the construction of the plants, or other undetermined influences. Fluctuations in natural background dose rates and in TLD readings tend to mask any small increments which may be due to plant operations. Thus, there was no identifiable increase in dose rate levels attributable to direct radiation from plant equipment and/or gaseous effluents.

**DOSE TO A MEMBER OF THE PUBLIC INSIDE THE UNRESTRICTED AREA BOUNDARY**

As stated in the Sequoyah Offsite Dose Calculation Manual, an evaluation of the dose to a member of the public inside the unrestricted area boundary is performed for a hypothetical TVA employee who works just outside the restricted area fence for an entire workyear (2000 hours). Results from onsite TLD measurements for the calendar year in question indicate that the highest onsite TLD reading was 108 mrem. Using this value, and subtracting an annual background value of 55 mrem/year, and multiplying by the ratio of the occupancy times, the highest external dose to a member of the public inside the unrestricted area boundary is 24.7 mrem. The doses due to radioactive effluents released to the atmosphere calculated in this report would not add a significant amount to this measured dose. This dose is well below the 10 CFR 20 annual limit of 100 mrem.

**TOTAL DOSE**

To determine compliance with 40 CFR 190, annual total dose contributions to the maximum individual from Sequoyah radioactive effluents and all other nearby uranium fuel cycle sources are considered.

The annual dose to any organ other than thyroid for the maximum individual is conservatively estimated by summing the following doses: the total body air submersion dose for each quarter, the critical organ dose (for any organ other than the thyroid) from airborne effluents for each quarter from ground contamination, inhalation and ingestion, the total body dose from liquid effluents for each quarter, the maximum organ dose (for any organ other than the thyroid) from liquid effluents for each quarter, and any identifiable increase in direct radiation dose levels as measured by the environmental monitoring program. This dose is compared to the 40 CFR 190 limit for total body or any organ dose (other than thyroid) to determine compliance.

The annual thyroid dose to the maximum individual is conservatively estimated by summing the following doses: the total body air submersion dose for each quarter, the thyroid dose from

**Radiological Impact Assessment**

Sequoyah Nuclear Plant

January - December 1995

Page 7 of 17

airborne effluents for each quarter, the total body dose from liquid effluents for each quarter, the thyroid dose from liquid effluents for each quarter, and any identifiable increase in direct radiation dose levels as measured by the environmental monitoring program. This dose is compared to the 40 CFR 190 limit for thyroid dose to determine compliance.

Cumulative annual total doses are presented in Table 9.

**Radiological Impact Assessment**

Sequoah Nuclear Plant

January - December 1995

Pgce 8 of 17

**Table 1**  
**Doses from Airborne Effluents**  
**First Quarter**

**Individual Doses**

Pathway	Dose	Quarterly Limit	Percent of Limit	Location Sector/Distance
<b>External</b>				
Gamma Air	1.44E-03 mrad	5 mrad	0.029	N/950
Beta Air	2.80E-03 mrad	10 mrad	0.028	
<b>Submersion</b>				
Total Body	9.79E-04 mrad	10 mrad	0.010	SSW/2134
Skin	2.07E-03 mrad	10 mrad	0.021	
<b>Organ Doses</b>				
Child/Thyroid	9.48E-03 mrem	7.5 mrem	0.13	SSW/2707
Child/Total Body	9.47E-03 mrem	7.5 mrem	0.13	

**Population Doses**

Total Body Dose                    7.25E-02 man-rem

Maximum Organ Dose (organ)    7.27E-02 man-rem (thyroid)

Population doses can be compared to the natural background dose for the entire 50-mile population of about 95,400 man-rem/year (based on 90 mrem/yr for natural background).

**Radiological Impact Assessment**

Sequoah Nuclear Plant

January - December 1995

Page 9 of 17

**Table 2**  
**Doses from Airborne Effluents**  
**Second Quarter**

**Individual Doses**

Pathway	Dose	Quarterly Limit	Percent of Limit	Location Sector/Distance
<b>External</b>				
Gamma Air	1.39E-03 mrad	5 mrad	0.028	N/950
Beta Air	2.83E-03 mrad	10 mrad	0.028	
<b>Submersion</b>				
Total Body	9.00E-04 mrad	10 mrad	0.009	SSW/2134
Skin	1.93E-03 mrad	10 mrad	0.019	
<b>Organ Doses</b>				
Child/Thyroid	9.40E-03 mrem	7.5 mrem	0.125	SSW/2707
Child/Total Body	9.40E-03 mrem	7.5 mrem	0.125	

**Population Doses**

Total Body Dose                    7.24E-02 man-rem

Maximum Organ Dose (organ)    7.24E-02 man-rem (thyroid)

Population doses can be compared to the natural background dose for the entire 50-mile population of about 95,400 man-rem/year (based on 90 mrem/yr for natural background).

**Radiological Impact Assessment**  
 Sequoyah Nuclear Plant  
 January - December 1995  
 Page 10 of 17

**Table 3**  
**Doses from Airborne Effluents**  
**Third Quarter**

**Individual Doses**

Pathway	Dose	Quarterly Limit	Percent of Limit	Location Sector/Distance
<b>External</b>				
Gamma Air	2.56E-03 mrad	5 mrad	0.051	N/950
Beta Air	5.15E-03 mrad	10 mrad	0.052	
<b>Submersion</b>				
Total Body	1.65E-03 mrad	10 mrad	0.017	SSW/2134
Skin	3.52E-03 mrad	10 mrad	0.035	
<b>Organ Doses</b>				
Child/Thyroid	3.77E-03 mrem	7.5 mrem	0.050	SSW/2707
Child/Total Body	3.68E-03 mrem	7.5 mrem	0.049	

**Population Doses**

Total Body Dose                    2.65E-02 man-rem

Maximum Organ Dose (organ)    2.71E-02 man-rem (thyroid)

Population doses can be compared to the natural background dose for the entire 50-mile population of about 95,400 man-rem/year (based on 90 mrem/yr for natural background).

**Radiological Impact Assessment**

Sequoah Nuclear Plant

January - December 1995

Page 11 of 17

**Table 4**  
**Doses from Airborne Effluents**  
**Fourth Quarter**

**Individual Doses**

Pathway	Dose	Quarterly Limit	Percent of Limit	Location Sector/Distance
<b>External</b>				
Gamma Air	5.68E-04 mrad	5 mrad	0.011	N/950
Beta Air	7.56E-04 mrad	10 mrad	0.008	
<b>Submersion</b>				
Total Body	4.27E-04 mrad	10 mrad	0.004	SSW/2134
Skin	8.08E-04 mrad	10 mrad	0.008	
<b>Organ Doses</b>				
Child/Thyroid	9.37E-03 mrem	7.5 mrem	0.125	SSW/2707
Child/Total Body	9.37E-03 mrem	7.5 mrem	0.125	

**Population Doses**

Total Body Dose                    7.19E-02 man-rem

Maximum Organ Dose (organ)    7.21E-02 man-rem (thyroid)

Population doses can be compared to the natural background dose for the entire 50-mile population of about 95,400 man-rem/year (based on 90 mrem/yr for natural background).

**Radiological Impact Assessment**

Sequoah Nuclear Plant

January - December 1995

Page 12 of 17

**Table 5**  
**Doses from Liquid Effluents**  
**First Quarter**

**Individual Doses**

Age Group	Organ	Dose	Quarterly Limit	Percent of Limit
Adult	Total Body	4.8E-03	1.5 mrem	< 1 %
	Liver	5.8E-03	5 mrem	< 1 %
Teen	Total Body	3.4E-03	1.5 mrem	< 1 %
	Liver	5.7E-03	5 mrem	< 1 %
Child	Total Body	3.0E-03	1.5 mrem	< 1 %
	Liver	5.8E-03	5 mrem	< 1 %

Average Riverflow past SQN (cubic feet per second): 50,164

**Population Doses**

Total Body Dose                    1.3E-01 man-rem

Maximum Organ Dose (organ)    1.3E-01 man-rem (liver)

Population doses can be compared to the natural background dose for the entire 50-mile population of about 95,400 man-rem/year (based on 90 mrem/yr for natural background).

**Radiological Impact Assessment**

Sequoyah Nuclear Plant

January - December 1995

Page 13 of 17

**Table 6**  
**Doses from Liquid Effluents**  
**Second Quarter**

**Individual Doses**

Age Group	Organ	Dose	Quarterly Limit	Percent of Limit
Adult	Total Body	2.1E-02	1.5 mrem	< 1 %
	Liver	2.6E-02	5 mrem	< 1 %
Teen	Total Body	1.4E-02	1.5 mrem	< 1 %
	Liver	2.6E-02	5 mrem	< 1 %
Child	Total Body	1.2E-02	1.5 mrem	< 1 %
	Liver	2.6E-02	5 mrem	< 1 %

Average Riverflow past SQN (cubic feet per second): 13,954

**Population Doses**

Total Body Dose                    7.0E-01 man-rem

Maximum Organ Dose (organ)    7.3E-01 man-rem (liver)

Population doses can be compared to the natural background dose for the entire 50-mile population of about 95,400 man-rem/year (based on 90 mrem/yr for natural background).

**Radiological Impact Assessment**

Sequoah Nuclear Plant

January - December 1995

Page 14 of 17

**Table 7**  
**Doses from Liquid Effluents**  
**Third Quarter**

**Individual Doses**

Age Group	Organ	Dose	Quarterly Limit	Percent of Limit
Adult	Total Body	3.8E-02	1.5 mrem	2.5 %
	Liver	5.0E-02	5 mrem	1 %
Teen	Total Body	2.4E-02	1.5 mrem	1.6 %
	Liver	5.1E-02	5 mrem	1 %
Child	Total Body	1.3E-02	1.5 mrem	< 1 %
	Liver	4.6E-02	5 mrem	< 1 %

Average Riverflow past SQN (cubic feet per second): 27,580

**Population Doses**

Total Body Dose                    6.0E-01 man-rem

Maximum Organ Dose (organ)    2.6E-01 man-rem (thyroid)

Population doses can be compared to the natural background dose for the entire 50-mile population of about 95,400 man-rem/year (based on 90 mrem/yr for natural background).

**Radiological Impact Assessment**

Sequoah Nuclear Plant

January - December 1995

Page 15 of 17

**Table 8**  
**Doses from Liquid Effluents**  
**Fourth Quarter**

**Individual Doses**

Age Group	Organ	Dose	Quarterly Limit	Percent of Limit
Adult	Total Body	6.5E-03	1.5 mrem	< 1 %
	GIT	2.0E-02	5 mrem	< 1 %
Teen	Total Body	4.9E-03	1.5 mrem	< 1 %
	GIT	1.5E-02	5 mrem	< 1 %
Child	Total Body	4.1E-03	1.5 mrem	< 1 %
	GIT/Liver	7.4E-03	5 mrem	< 1 %

Average Riverflow past SQN (cubic feet per second): 40,181

**Population Doses**

Total Body Dose                    1.8E-01 man-rem

Maximum Organ Dose (organ)    2.3E-01 man-rem (GIT)

Population doses can be compared to the natural background dose for the entire 50-mile population of about 95,400 man-rem/year (based on 90 mrem/yr for natural background).

**Radiological Impact Assessment**

Sequoyah Nuclear Plant

January - December 1995

Page 16 of 17

**Table 9****Total Dose from Fuel Cycle**

Dose	First Quarter	Second Quarter	Third Quarter	Fourth Quarter	
<b>Total Body or any Organ (except thyroid)</b>					
Total body air submersion	9.79E-04	9.00E-04	1.65E-03	4.27E-04	
Critical organ dose (air)	9.48E-03	9.40E-03	3.77E-03	9.37E-03	
Total body dose (liquid)	4.8E-03	2.1E-02	3.8E-02	6.5E-03	
Maximum organ dose (liquid)	5.8E-03	2.6E-02	5.0E-02	2.0E-02	
Direct Radiation Dose	0.0E-00	0.0E-00	0.0E-00	0.00E-00	
<b>Total</b>	<b>2.1E-02</b>	<b>5.7E-02</b>	<b>9.3E-02</b>	<b>3.6E-02</b>	
<b>Cumulative Total Dose (Total body or any other organ) mrem</b>				<b>2.1E-02</b>	
<b>Annual Dose Limit (mrem)</b>				<b>2.50E+01</b>	
<b>Percent of Limit</b>				<b>&lt; 1 %</b>	

**Thyroid Dose (mrem)**

Total body air submersion	9.79E-04	9.00E-04	1.65E-03	4.27E-04	
Thyroid dose (airborne)	9.48E-03	9.40E-03	3.77E-03	9.37E-03	
Total body dose (liquid)	4.8E-03	2.1E-02	3.8E-02	6.5E-03	
Thyroid dose (liquid)	4.0E-03	8.7E-03	6.2E-03	3.1E-03	
Direct Radiation Dose	0.0E-00	0.0E-00	0.0E-00	0.0E-00	
<b>Total</b>	<b>1.9E-02</b>	<b>4.0E-02</b>	<b>5.0E-02</b>	<b>1.9E-02</b>	
<b>Cumulative Total Dose (Thyroid) mrem</b>				<b>1.3E-01</b>	
<b>Annual Dose Limit (mrem)</b>				<b>7.50E+01</b>	
<b>Percent of Limit</b>				<b>&lt; 1 %</b>	

**Radiological Impact Assessment**  
Sequoyah Nuclear Plant  
January - December 1995  
Page 17 of 17

**Attachment 1.0**

## JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (DELTA T&lt;=-1.9 C/100 M)

## SEQUOYAH NUCLEAR PLANT

JAN 1, 95 - MAR 31, 95

WIND DIRECTION	CALM	WIND SPEED (MPH)						>= 24.5
		0-6-1-4	1-5-3-4	3-5-5-4	5-5-7-4	7-5-12-4	12-5-18-4	
N	0.000	0.000	0.000	0.048	0.000	0.288	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.240	0.529	0.000	0.000
NE	0.000	0.000	0.000	0.096	0.048	0.192	0.000	0.000
ENE	0.000	0.000	0.048	0.000	0.048	0.000	0.000	0.336
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.096
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.048	0.000	0.000	0.000
S	0.000	0.000	0.000	0.000	0.096	0.000	0.000	0.048
SSW	0.000	0.000	0.000	0.000	0.192	0.240	0.048	0.096
SW	0.000	0.000	0.000	0.000	0.096	0.144	0.192	0.432
WSW	0.000	0.000	0.000	0.000	0.048	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.096	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.048	0.240	0.000	0.288
NW	0.000	0.000	0.000	0.000	0.096	0.240	0.000	0.336
NNW	0.000	0.000	0.000	0.048	0.144	0.048	0.000	0.240
SUBTOTAL	0.000	0.000	0.048	0.288	1.153	2.066	0.048	3.604

TOTAL HOURS OF VALID STABILITY OBSERVATIONS  
 TOTAL HOURS OF STABILITY CLASS A  
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS A  
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS  
 TOTAL HOURS CALM

METEOROLOGICAL FACILITY: SEQUOYAH NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 9.25 AND 45.99 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 9.73 METER LEVEL

MEAN WIND SPEED = 8.39

DATE PRINTED: 26-APR-95

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

## JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B (-1.9 &lt; DELTA T (&lt;= -1.7 C/100 M)

## SEQUOYAH NUCLEAR PLANT

JAN 1, 95 - MAR 31, 95

WIND DIRECTION	CALM	WIND SPEED (MPH)						TOTAL >= 24.5
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	
N	0.000	0.000	0.000	0.000	0.192	0.048	0.144	0.000
NNE	0.000	0.000	0.000	0.096	0.384	0.000	0.000	0.000
NE	0.000	0.000	0.048	0.096	0.000	0.096	0.000	0.865
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.240
E	0.000	0.000	0.000	0.048	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.048	0.000	0.048	0.000	0.000	0.048
SE	0.000	0.000	0.000	0.048	0.000	0.000	0.000	0.096
SSE	0.000	0.000	0.048	0.000	0.000	0.000	0.000	0.048
S	0.000	0.000	0.000	0.048	0.000	0.000	0.000	0.048
SSW	0.000	0.000	0.048	0.096	0.000	0.000	0.000	0.096
SW	0.000	0.000	0.000	0.048	0.240	0.096	0.048	0.529
WSW	0.000	0.000	0.000	0.048	0.000	0.000	0.000	0.048
W	0.000	0.000	0.000	0.048	0.048	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.096	0.048	0.192	0.000	0.096
NW	0.000	0.000	0.000	0.048	0.048	0.240	0.000	0.336
NNW	0.000	0.000	0.000	0.048	0.000	0.000	0.000	0.288
SUBTOTAL	0.000	0.000	0.144	0.625	1.105	1.105	0.192	0.000
							3.172	0.000

TOTAL HOURS OF VALID STABILITY OBSERVATIONS  
 TOTAL HOURS OF STABILITY CLASS B  
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS B  
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS  
 TOTAL HOURS CALM

METEOROLOGICAL FACILITY: SEQUOYAH NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 9.25 AND 45.99 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 9.73 METER LEVEL

MEAN WIND SPEED = 7.56

DATE PRINTED: 26-APR-95

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

## JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C (-1.7 &lt; DELTA T &lt;= -1.5 C/100 M)

SEQUOYAH NUCLEAR PLANT

JAN 1, 95 - MAR 31, 95

WIND DIRECTION	CALM	WIND SPEED(MPH)									TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>24.5		
N	0.000	0.000	0.000	0.000	0.144	0.096	0.096	0.000	0.000	0.336	
NNE	0.000	0.000	0.192	0.384	0.384	0.288	0.000	0.000	0.000	1.249	
NE	0.000	0.000	0.192	0.384	0.048	0.048	0.000	0.000	0.000	0.673	
ENE	0.000	0.000	0.096	0.000	0.000	0.000	0.000	0.000	0.000	0.096	
E	0.000	0.000	0.096	0.000	0.000	0.000	0.000	0.000	0.000	0.096	
ESE	0.000	0.000	0.000	0.048	0.000	0.000	0.000	0.000	0.000	0.048	
SE	0.000	0.000	0.000	0.192	0.000	0.000	0.000	0.000	0.000	0.192	
SSE	0.000	0.000	0.000	0.048	0.048	0.000	0.000	0.000	0.000	0.096	
S	0.000	0.000	0.000	0.096	0.048	0.000	0.000	0.000	0.000	0.144	
SSW	0.000	0.000	0.048	0.096	0.481	0.048	0.000	0.000	0.000	0.673	
SW	0.000	0.000	0.000	0.240	0.192	0.144	0.000	0.000	0.000	0.577	
WSW	0.000	0.000	0.000	0.000	0.048	0.048	0.000	0.000	0.000	0.096	
W	0.000	0.000	0.000	0.048	0.048	0.048	0.000	0.000	0.000	0.144	
WNW	0.000	0.000	0.000	0.096	0.000	0.048	0.000	0.000	0.000	0.144	
NW	0.000	0.000	0.000	0.048	0.048	0.048	0.000	0.000	0.000	0.144	
NNW	0.000	0.000	0.000	0.048	0.144	0.048	0.000	0.000	0.000	0.240	
SUBTOTAL	0.000	0.000	0.625	1.730	1.634	0.865	0.096	0.000	0.000	4.950	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2149

TOTAL HOURS OF STABILITY CLASS C

110

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS C

103

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS

2081

TOTAL HOURS CALM

0

METEOROLOGICAL FACILITY: SEQUOYAH NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 9.25 AND 45.99 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 9.73 METER LEVEL

DATE PRINTED: 26-APR-95

MEAN WIND SPEED = 5.98

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

## JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D (-1.5 &lt; DELTA T &lt;= -0.5 C/100 M)

## SEQUOYAH NUCLEAR PLANT

JAN 1, 95 - MAR 31, 95

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED(MPH)							TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.000	1.297	1.970	1.586	1.730	0.192	0.000	0.000	6.776	
NNE	0.000	0.000	1.105	2.643	1.634	1.778	0.096	0.000	0.000	7.255	
NE	0.000	0.048	0.721	0.625	0.384	0.048	0.000	0.000	0.000	1.826	
ENE	0.000	0.048	0.336	0.096	0.000	0.000	0.000	0.000	0.000	0.481	
E	0.000	0.000	0.048	0.048	0.000	0.000	0.000	0.000	0.000	0.096	
ESE	0.000	0.000	0.096	0.048	0.048	0.000	0.000	0.000	0.000	0.192	
SE	0.000	0.000	0.192	0.048	0.000	0.048	0.000	0.000	0.000	0.288	
SSE	0.000	0.144	0.144	0.192	0.240	0.240	0.048	0.000	0.000	1.009	
S	0.000	0.096	0.625	1.105	0.240	0.144	0.000	0.300	0.000	2.210	
SSW	0.000	0.240	1.201	3.412	1.057	0.336	0.048	0.000	0.000	6.295	
SW	0.000	0.000	0.673	1.153	0.625	0.144	0.000	0.000	0.000	2.595	
WSW	0.000	0.000	0.192	0.481	0.529	0.192	0.000	0.000	0.000	1.394	
W	0.000	0.000	0.288	0.336	0.384	0.144	0.000	0.000	0.000	1.153	
WNW	0.000	0.240	0.192	0.529	0.384	0.240	0.000	0.000	0.000	1.586	
NW	0.000	0.048	0.529	0.913	1.105	0.865	0.000	0.000	0.000	3.460	
NNW	0.000	0.096	0.961	1.922	1.105	0.577	0.048	0.000	0.000	4.709	
SUBTOTAL	0.000	0.961	8.602	15.521	9.322	6.487	0.432	0.000	0.000	41.326	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2149

TOTAL HOURS OF STABILITY CLASS D

886

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS D

860

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS

2081

TOTAL HOURS CALM

0

METEOROLOGICAL FACILITY: SEQUOYAH NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 9.25 AND 45.99 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 9.73 METER LEVEL

DATE PRINTED: 26-APR-95

MEAN WIND SPEED = 5.25

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

## JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E (-0.5 &lt; DELTA T &lt;= 1.5 C/100 M)

SEQUOYAH NUCLEAR PLANT

JAN 1, 95 - MAR 31, 95

WIND DIRECTION	CALM	WIND SPEED(MPH)								TOTAL
		0 . 6 - 1 . 4	1 . 5 - 3 . 4	3 . 5 - 5 . 4	5 . 5 - 7 . 4	7 . 5 - 12 . 4	12 . 5 - 18 . 4	18 . 5 - 24 . 4	> = 24 . 5	
N	0.067	0.288	1.970	2.066	0.625	0.192	0.048	0.000	0.000	5.257
NNE	0.090	0.769	2.259	1.346	0.432	0.192	0.000	0.000	0.000	5.088
NE	0.011	0.192	0.192	0.096	0.048	0.000	0.000	0.000	0.000	0.540
ENE	0.004	0.048	0.096	0.000	0.000	0.000	0.000	0.000	0.000	0.148
E	0.004	0.096	0.048	0.000	0.000	0.000	0.000	0.000	0.000	0.148
ESE	0.003	0.096	0.000	0.048	0.000	0.000	0.000	0.000	0.000	0.147
SE	0.007	0.096	0.144	0.000	0.096	0.096	0.000	0.000	0.000	0.440
SSE	0.004	0.048	0.096	0.192	0.000	0.529	0.096	0.000	0.000	0.965
S	0.030	0.240	0.769	0.529	0.384	0.192	0.000	0.000	0.000	2.144
SSW	0.076	0.192	2.355	0.913	0.192	0.144	0.000	0.000	0.000	3.872
SW	0.056	0.288	1.586	1.634	0.144	0.144	0.000	0.000	0.000	3.852
WSW	0.010	0.144	0.192	0.240	0.048	0.000	0.000	0.000	0.000	0.635
W	0.007	0.000	0.240	0.288	0.144	0.096	0.000	0.000	0.000	0.776
WNW	0.011	0.000	0.384	0.432	0.144	0.000	0.000	0.000	0.000	0.973
NW	0.019	0.096	0.529	0.240	0.192	0.240	0.000	0.000	0.000	1.316
NNW	0.032	0.144	0.913	0.432	0.144	0.096	0.000	0.000	0.000	1.761
SUBTOTAL	0.432	2.739	11.773	8.457	2.595	1.922	0.144	0.000	0.000	28.063

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2149

TOTAL HOURS OF STABILITY CLASS E

598

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS E

584

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS

2081

TOTAL HOURS CALM

9

METEOROLOGICAL FACILITY: SEQUOYAH NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 9.25 AND 45.99 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 9.73 METER LEVEL

DATE PRINTED: 26-APR-95

MEAN WIND SPEED = 3.77

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

## JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F ( 1.5 &lt; DELTA T &lt;= 4.0 C/100 M)

## SEQUOYAH NUCLEAR PLANT

JAN 1, 95 - MAR 31, 95

WIND DIRECTION	CALM	WIND SPEED (MPH)						TOTAL >= 24.5
		0-6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	
N	0.004	0.096	0.721	0.192	0.048	0.000	0.000	0.000
NNE	0.014	0.529	2.355	0.432	0.000	0.000	0.000	0.000
NE	0.002	0.288	0.192	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.096	0.000	0.000	0.000	0.000	0.483
E	0.001	0.000	0.096	0.000	0.000	0.000	0.000	0.097
EESE	0.000	0.000	0.048	0.000	0.000	0.000	0.000	0.145
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.097
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.006	0.336	0.817	0.192	0.000	0.000	0.000	0.289
SSW	0.008	0.048	1.490	0.288	0.000	0.000	0.000	1.351
SW	0.007	0.048	1.297	0.625	0.048	0.000	0.000	1.834
WSW	0.001	0.000	0.144	0.048	0.048	0.000	0.000	2.025
W	0.000	0.000	0.000	0.048	0.000	0.000	0.000	0.241
WNW	0.000	0.000	0.096	0.048	0.000	0.000	0.000	0.048
NNW	0.000	0.000	0.048	0.000	0.000	0.000	0.000	0.145
NNW	0.003	0.144	0.384	0.048	0.000	0.000	0.000	0.048
SUBTOTAL	0.048	1.826	7.833	2.018	0.144	0.000	0.000	0.579

TOTAL HOURS OF VALID STABILITY OBSERVATIONS  
 TOTAL HOURS OF STABILITY CLASS F  
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS F  
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS  
 TOTAL HOURS CALM  
 1

METEOROLOGICAL FACILITY: SEQUOYAH NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 9.25 AND 45.99 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 9.73 METER LEVEL

MEAN WIND SPEED = 2.58

DATE PRINTED: 26-APR-95

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

## JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G (DELTAT) 4.0 C/100 W)

## SEQUOYAH NUCLEAR PLANT

JAN 1, 95 - MAR 31, 95

WIND DIRECTION	CALM	WIND SPEED (MPH)					TOTAL
		0-6-1-4	1-5-3-4	3-5-5-4	5-5-7-4	7-5-12-4	
N	0.000	0.096	0.144	0.000	0.000	0.000	0.000
NNE	0.000	0.048	1.634	0.048	0.000	0.000	0.000
NE	0.000	0.432	0.769	0.000	0.000	0.000	0.000
ENE	0.000	0.192	0.048	0.000	0.000	0.000	0.000
E	0.000	0.144	0.048	0.000	0.000	0.000	0.000
EE	0.000	0.096	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.288	0.096	0.000	0.000	0.000	0.000
SSE	0.000	0.144	0.000	0.000	0.000	0.000	0.000
S	0.000	0.096	0.432	0.000	0.000	0.000	0.000
SSW	0.000	0.096	1.249	0.048	0.000	0.000	0.000
SW	0.000	0.048	0.625	0.096	0.000	0.000	0.000
WSW	0.000	0.000	0.096	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL		1.682	5.142	0.192	0.000	0.000	7.016

TOTAL HOURS OF VALID STABILITY OBSERVATIONS  
 TOTAL HOURS OF STABILITY CLASS G  
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS G  
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS  
 TOTAL HOURS CALM

2149  
 149  
 146  
 2081  
 0

METEOROLOGICAL FACILITY: SEQUOYAH NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 9.25 AND 45.99 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 9.73 METER LEVEL

MEAN WIND SPEED = 2.07

DATE PRINTED: 26-APR-95

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

## JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (DELTA T&lt;=-1.9 C/100 M)

SEQUOYAH NUCLEAR PLANT

APR 1, 95 - JUN 30, 95

WIND DIRECTION	CALM	WIND SPEED(MPH)								TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.000	0.000	0.000	0.138	0.322	0.092	0.000	0.000	0.000	0.551
NNE	0.000	0.000	0.092	0.643	0.322	0.230	0.000	0.000	0.000	1.286
NE	0.000	0.000	0.046	0.781	0.322	0.138	0.000	0.000	0.000	1.286
ENE	0.000	0.000	0.000	0.092	0.000	0.000	0.000	0.000	0.000	0.092
E	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.000	0.046
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.000	0.046
S	0.000	0.000	0.000	0.000	0.184	0.230	0.000	0.000	0.000	0.413
SSW	0.000	0.000	0.000	0.046	0.873	0.322	0.000	0.000	0.000	1.240
SW	0.000	0.000	0.000	0.15	0.092	0.046	0.000	0.000	0.000	0.322
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.046
NW	0.000	0.000	0.000	0.000	0.000	0.184	0.000	0.000	0.000	0.184
NNW	0.000	0.000	0.000	0.046	0.138	0.184	0.000	0.000	0.000	0.367
SUBTOTAL	0.000	0.000	0.138	2.021	2.297	1.424	0.000	0.000	0.000	5.880

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2179

TOTAL HOURS OF STABILITY CLASS A

128

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS A

128

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS

2177

TOTAL HOURS CALM

0

METEOROLOGICAL FACILITY: SEQUOYAH NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 9.25 AND 45.99 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 9.73 METER LEVEL

DATE PRINTED: 24-JUL-95

MEAN WIND SPEED = 6.17

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

## JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B (-1.9 &lt; DELTA T &lt;=-1.7 C/100 M)

## SEQUOYAH NUCLEAR PLANT

APR 1, 95 - JUN 30, 95

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED(MPH)						>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4			
N	0.000	0.000	0.000	0.184	0.184	0.046	0.000	0.000	0.000	0.413	
NNE	0.000	0.000	0.046	0.873	0.459	0.092	0.000	0.000	0.000	1.470	
NE	0.000	0.000	0.230	0.505	0.092	0.000	0.000	0.000	0.000	0.827	
ENE	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.000	0.046	
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
SE	0.000	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.046	
SSE	0.000	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.046	
S	0.000	0.000	0.046	0.046	0.230	0.092	0.000	0.000	0.000	0.413	
SSW	0.000	0.000	0.000	0.505	0.643	0.046	0.000	0.000	0.000	1.194	
SW	0.000	0.000	0.000	0.367	0.138	0.092	0.000	0.000	0.000	0.597	
WSW	0.000	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.046	
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
NW	0.000	0.000	0.000	0.046	0.046	0.000	0.000	0.000	0.000	0.092	
NNW	0.000	0.000	0.000	0.046	0.046	0.138	0.000	0.000	0.000	0.230	
SUBTOTAL	0.000	0.000	0.322	2.618	1.975	0.505	0.000	0.000	0.000	5.420	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2179

TOTAL HOURS OF STABILITY CLASS B

118

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS B

118

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS

2177

TOTAL HOURS CALM

0

METEOROLOGICAL FACILITY: SEQUOYAH NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 9.25 AND 45.99 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 9.73 METER LEVEL

DATE PRINTED: 24-JUL-95

MEAN WIND SPEED = 5.51

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

## JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C (-1.7 &lt; DELTA T &lt;= -1.5 C/100 M)

SEQUOYAH NUCLEAR PLANT

APR 1, 95 - JUN 30, 95

WIND DIRECTION	CALM	WIND SPEED (MPH)									TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.000	0.000	0.046	0.138	0.000	0.000	0.000	0.000	0.184	
NNE	0.000	0.000	0.138	0.735	0.184	0.046	0.000	0.000	0.000	1.102	
NE	0.000	0.000	0.276	0.367	0.046	0.000	0.000	0.000	0.000	0.689	
ENE	0.000	0.000	0.138	0.092	0.000	0.000	0.000	0.000	0.000	0.230	
E	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.000	0.046	
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
SE	0.000	0.000	0.046	0.092	0.000	0.000	0.000	0.000	0.000	0.138	
SSE	0.000	0.000	0.092	0.092	0.046	0.046	0.000	0.000	0.000	0.276	
S	0.000	0.000	0.046	0.276	0.092	0.092	0.000	0.000	0.000	0.505	
SSW	0.000	0.000	0.046	0.551	0.459	0.092	0.000	0.000	0.000	1.148	
SW	0.000	0.000	0.046	0.643	0.276	0.046	0.000	0.000	0.000	1.011	
WSW	0.000	0.000	0.000	0.046	0.000	0.046	0.000	0.000	0.000	0.092	
W	0.000	0.000	0.046	0.000	0.046	0.000	0.000	0.000	0.000	0.092	
WNW	0.000	0.000	0.000	0.046	0.046	0.000	0.000	0.000	0.000	0.184	
NW	0.000	0.000	0.000	0.000	0.092	0.092	0.000	0.000	0.000	0.276	
NNW	0.000	0.000	0.000	0.046	0.046	0.184	0.000	0.000	0.000	0.000	
SUBTOTAL	0.000	0.000	0.873	3.078	1.470	0.643	0.000	0.000	0.000	6.063	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2179
TOTAL HOURS OF STABILITY CLASS C	132
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS C	132
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2177
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: SEQUOYAH NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 9.25 AND 45.99 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 9.73 METER LEVEL

DATE PRINTED: 24-JUL-95

MEAN WIND SPEED = 5.13

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

## JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D (-1.5 &lt; DELTA T &lt;= -0.5 C/100 M)

SEQUOYAH NUCLEAR PLANT

APR 1, 95 - JUN 30, 95

WIND DIRECTION	CALM	WIND SPEED(MPH)								TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>24.5	
N	0.000	0.092	0.689	1.332	0.689	0.322	0.000	0.000	0.000	3.124
NNE	0.000	0.046	1.148	1.516	0.367	0.092	0.000	0.000	0.000	3.169
NE	0.000	0.000	0.873	0.322	0.046	0.046	0.000	0.000	0.000	1.286
ENE	0.000	0.046	0.367	0.046	0.000	0.000	0.000	0.000	0.000	0.459
E	0.000	0.046	0.230	0.138	0.000	0.000	0.000	0.000	0.000	0.413
ESE	0.000	0.000	0.367	0.046	0.000	0.000	0.000	0.000	0.000	0.919
SE	0.000	0.000	0.597	0.322	0.000	0.000	0.000	0.000	0.000	2.159
SSE	0.000	0.046	0.827	0.413	0.230	0.459	0.184	0.000	0.000	5.558
S	0.000	0.000	1.194	2.756	0.731	0.827	0.000	0.000	0.000	7.855
SSW	0.000	0.000	2.389	3.537	1.608	0.322	0.000	0.000	0.000	2.343
SW	0.000	0.000	0.965	0.919	0.413	0.046	0.000	0.000	0.000	1.011
WSW	0.000	0.046	0.276	0.459	0.230	0.000	0.000	0.000	0.000	0.735
W	0.000	0.092	0.092	0.367	0.184	0.000	0.000	0.000	0.000	0.781
WNW	0.000	0.000	0.046	0.367	0.276	0.092	0.000	0.000	0.000	0.689
NW	0.000	0.000	0.000	0.505	0.138	0.046	0.000	0.000	0.000	1.011
NNW	0.000	0.000	0.184	0.322	0.322	0.184	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.413	10.243	13.367	5.282	2.435	0.184	0.000	0.000	31.925

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2179

TOTAL HOURS OF STABILITY CLASS D

697

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS D

695

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS

2177

TOTAL HOURS CALM

0

METEOROLOGICAL FACILITY: SEQUOYAH NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 9.25 AND 45.99 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 9.73 METER LEVEL

DATE PRINTED: 24-JUL-95

MEAN WIND SPEED = 4.49

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

## JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E (-0.5 &lt; DELTA T &lt;= 1.5 C/100 M)

## SEQUOYAH NUCLEAR PLANT

APR 1, 95 - JUN 30, 95

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)							TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.046	4.685	1.883	0.322	0.000	0.000	0.000	0.000	0.000	6.936
NNE	0.000	0.230	1.837	0.827	0.000	0.000	0.000	0.000	0.000	0.000	2.894
NE	0.000	0.046	0.413	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.459
ENE	0.000	0.184	0.092	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.276
E	0.000	0.230	0.046	0.046	0.000	0.000	0.000	0.000	0.000	0.000	0.322
ESE	0.000	0.138	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.138
SE	0.000	0.367	0.230	0.046	0.000	0.000	0.000	0.000	0.000	0.000	0.643
SSE	0.000	0.138	0.689	0.276	0.230	0.046	0.000	0.000	0.000	0.000	1.378
S	0.000	0.413	2.618	0.735	0.597	0.276	0.000	0.000	0.000	0.000	4.639
SSW	0.000	0.184	3.261	1.424	0.597	0.000	0.000	0.000	0.000	0.000	5.466
SW	0.000	0.138	1.837	1.102	0.230	0.046	0.000	0.000	0.000	0.000	3.353
WSW	0.000	0.138	0.965	0.505	0.230	0.138	0.000	0.000	0.000	0.000	1.975
W	0.000	0.092	0.276	0.138	0.138	0.000	0.046	0.000	0.000	0.000	0.689
WNW	0.000	0.138	0.230	0.138	0.092	0.046	0.000	0.000	0.000	0.000	0.643
NW	0.000	0.230	0.413	0.276	0.092	0.000	0.000	0.000	0.000	0.000	1.011
NNW	0.000	0.184	1.516	0.413	0.092	0.000	0.000	0.000	0.000	0.000	2.205
SUBTOTAL	0.000	2.894	19.109	7.809	2.618	0.551	0.046	0.000	0.000	33.027	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2179

TOTAL HOURS OF STABILITY CLASS E

719

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS E

719

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS

2177

TOTAL HOURS CALM

0

METEOROLOGICAL FACILITY: SEQUOYAH NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 9.25 AND 45.99 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 9.73 METER LEVEL

DATE PRINTED: 24-JUL-95

MEAN WIND SPEED = 3.16

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

## JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F ( 1.5 &lt; DELTA T (&lt;= 4.0 C/100 M) )

## SEQUOYAH NUCLEAR PLANT

APR 1, 95 - JUN 30, 95

WIND DIRECTION	CALM	WIND SPEED (MPH)						$\Sigma = 24.4$
		0-6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	
N	0.000	0.184	4.042	0.184	0.000	0.000	0.000	0.000
NNE	0.000	0.367	3.215	0.138	0.000	0.000	0.000	0.000
NE	0.000	0.412	0.322	0.000	0.000	0.000	0.000	0.735
ENE	0.000	0.276	0.092	0.000	0.000	0.000	0.000	0.367
E	0.000	0.184	0.046	0.000	0.000	0.000	0.000	0.230
ESE	0.000	0.184	0.000	0.000	0.000	0.000	0.000	0.184
SE	0.000	0.184	0.138	0.000	0.000	0.000	0.000	0.322
SSE	0.000	0.092	0.092	0.000	0.000	0.000	0.000	0.184
S	0.000	0.138	0.597	0.046	0.000	0.000	0.000	0.781
SSW	0.000	0.000	1.148	0.000	0.000	0.000	0.000	1.148
SW	0.000	0.138	0.643	0.184	0.000	0.000	0.000	0.965
WSW	0.000	0.046	0.367	0.092	0.000	0.000	0.000	0.505
W	0.000	0.000	0.138	0.092	0.000	0.000	0.000	0.230
WNW	0.000	0.046	0.184	0.046	0.000	0.000	0.000	0.276
NNW	0.000	0.138	0.184	0.092	0.000	0.000	0.000	0.413
NEW	0.000	0.092	1.011	0.230	0.000	0.000	0.000	1.332
SUBTOTAL	0.000	2.480	12.219	1.102	0.000	0.000	0.000	15.802

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2179  
 TOTAL HOURS OF STABILITY CLASS F 344  
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS F 344  
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2177  
 TOTAL HOURS CALM 0

METEOROLOGICAL FACILITY: SEQUOYAH NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 9.25 AND 45.99 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 9.73 METER LEVEL

MEAN WIND SPEED = 2.18

DATE PRINTED: 24-JUL-95

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

## JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G (DELTAT) 4.0 C/100 M)

## SEQUOYAH NUCLEAR PLANT

APR 1, 95 - JUN 30, 95

WIND DIRECTION	CALM	WIND SPEED (MPH)						TOTAL = 24.5
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.046	0.138	0.000	0.000	0.000	0.000	0.184
NE	0.000	0.138	0.184	0.000	0.000	0.000	0.000	0.322
ENE	0.000	0.092	0.000	0.000	0.000	0.000	0.000	0.092
E	0.000	0.046	0.046	0.000	0.000	0.000	0.000	0.092
ESE	0.000	0.046	0.046	0.000	0.000	0.000	0.000	0.092
SE	0.000	0.184	0.046	0.000	0.000	0.000	0.000	0.230
SSE	0.000	0.046	0.092	0.000	0.000	0.000	0.000	0.138
S	0.000	0.046	0.138	0.000	0.000	0.000	0.000	0.184
SSW	0.000	0.000	0.367	0.000	0.000	0.000	0.000	0.367
SW	0.000	0.000	0.092	0.046	0.000	0.000	0.000	0.138
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WW	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.046
WW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.643	1.194	0.046	0.000	0.000	0.000	1.883

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2179  
 TOTAL HOURS OF STABILITY CLASS G 41  
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS G 41  
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2177  
 TOTAL HOURS CALM 0

METEOROLOGICAL FACILITY: SEQUOYAH NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 9.25 AND 45.99 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 9.73 METER LEVEL

MEAN WIND SPEED = 1.90

DATE PRINTED: 24-JUL-95

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

## JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (DELTA T&lt;=-1.9 C/100 M)

SEQUOYAH NUCLEAR PLANT

JUL 1, 95 - SEP 30, 95

WIND DIRECTION	CALM	WIND SPEED(MPH)									TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.000	0.000	0.248	1.041	0.297	0.000	0.000	0.000	0.000	1.587	
NNE	0.000	0.000	0.942	2.082	0.892	0.347	0.000	0.000	0.000	4.264	
NE	0.000	0.000	0.942	0.347	0.050	0.000	0.000	0.000	0.000	1.339	
ENE	0.000	0.000	0.297	0.198	0.000	0.000	0.000	0.000	0.000	0.496	
E	0.000	0.000	0.198	0.050	0.000	0.000	0.000	0.000	0.000	0.248	
ESE	0.000	0.000	0.198	0.050	0.000	0.000	0.000	0.000	0.000	0.248	
SE	0.000	0.000	0.198	0.050	0.000	0.000	0.000	0.000	0.000	0.248	
SSE	0.000	0.000	0.099	0.099	0.000	0.000	0.000	0.000	0.000	0.198	
S	0.000	0.000	0.297	0.248	0.050	0.000	0.000	0.000	0.000	0.595	
SSW	0.000	0.000	0.297	0.595	0.496	0.000	0.000	0.000	0.000	1.388	
SW	0.000	0.000	0.297	0.496	0.000	0.000	0.000	0.030	0.000	0.793	
WSW	0.000	0.000	0.198	0.050	0.000	0.000	0.000	0.000	0.000	0.248	
W	0.000	0.000	0.050	0.000	0.000	0.000	0.000	0.000	0.000	0.050	
WNW	0.000	0.000	0.050	0.000	0.000	0.000	0.000	0.000	0.000	0.050	
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
NNW	0.000	0.000	0.149	0.050	0.000	0.000	0.000	0.000	0.000	0.198	
SUBTOTAL	0.000	0.000	4.462	5.354	1.785	0.347	0.000	0.000	0.000	11.948	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2067

TOTAL HOURS OF STABILITY CLASS A

248

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS A

241

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS

2017

TOTAL HOURS CALM

0

METEOROLOGICAL FACILITY: SEQUOYAH NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 9.25 AND 45.99 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 9.73 METER LEVEL

DATE PRINTED: 26-OCT-95

MEAN WIND SPEED = 4.11

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

## JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B (-1.9 &lt; DELTA T &lt;= -1.7 C/100 M)

## SEQUOYAH NUCLEAR PLANT

JUL 1, 95 - SEP 30, 95

WIND DIRECTION	CALM	WIND SPEED (MPH)			12.5-18.4	18.5-24.4	>= 24.5	TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4				
N	0.000	0.000	0.198	0.149	0.000	0.000	0.000	0.496
NNE	0.000	0.000	0.347	0.347	0.496	0.149	0.000	1.339
NE	0.000	0.000	0.149	0.099	0.000	0.000	0.000	0.248
ENE	0.000	0.000	0.149	0.000	0.000	0.000	0.000	0.149
E	0.000	0.000	0.000	0.099	0.000	0.000	0.000	0.099
ESE	0.000	0.000	0.248	0.000	0.000	0.000	0.000	0.248
SE	0.000	0.000	0.099	0.000	0.000	0.000	0.000	0.099
SSE	0.000	0.000	0.000	0.000	0.000	0.050	0.000	0.050
S	0.000	0.000	0.198	0.149	0.050	0.000	0.000	0.397
SSW	0.000	0.000	0.347	0.347	0.198	0.000	0.000	0.892
SW	0.000	0.000	0.099	0.198	0.099	0.000	0.000	0.397
WSW	0.000	0.000	0.050	0.000	0.000	0.000	0.000	0.050
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.099	0.000	0.000	0.000	0.000	0.099
NNW	0.000	0.000	0.050	0.000	0.000	0.000	0.000	0.050
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.050
SUBTOTAL	0.000	2.033	1.388	1.041	0.198	0.000	0.000	4.660

TOTAL HOURS OF VALID STABILITY OBSERVATIONS  
 TOTAL HOURS OF STABILITY CLASS B  
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS B  
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS  
 TOTAL HOURS CALM  
 TOTAL HOURS OF VALID STABILITY OBSERVATIONS  
 TOTAL HOURS OF STABILITY CLASS B  
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS B  
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS  
 TOTAL HOURS CALM

METEOROLOGICAL FACILITY: SEQUOYAH NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 9.25 AND 45.99 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 9.73 METER LEVEL

DATE PRINTED: 26-OCT-95  
 MEAN WIND SPEED = 4.12  
 NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

## JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C (-1.7 &lt; DELTA T &lt;= -1.5 C/100 M)

## SEQUOYAH NUCLEAR PLANT

JUL 1, 95 - SEP 30, 95

WIND DIRECTION	CALM	WIND SPEED (MPH)						TOTAL => 24.4
		0-6-1-4	1-5-3-4	3-5-5-4	5-5-7-4	7-5-12-4	12-5-18-4	
N	0.000	0.000	0.117	0.446	0.149	0.000	0.000	0.000
NNE	0.000	0.000	0.117	0.694	0.149	0.099	0.000	0.000
NE	0.000	0.000	0.297	0.099	0.050	0.000	0.000	0.438
ENE	0.000	0.000	0.050	0.050	0.000	0.000	0.000	0.446
E	0.000	0.000	0.050	0.050	0.000	0.000	0.000	0.099
ESE	0.000	0.000	0.099	0.000	0.050	0.000	0.000	0.099
SE	0.000	0.000	0.050	0.000	0.050	0.000	0.000	0.149
SSE	0.000	0.000	0.198	0.000	0.000	0.149	0.000	0.347
S	0.000	0.000	0.050	0.198	0.050	0.099	0.000	0.397
SSW	0.000	0.000	0.248	0.595	0.099	0.000	0.000	0.942
SW	0.000	0.000	0.050	0.050	0.248	0.000	0.000	0.347
WSW	0.000	0.000	0.050	0.000	0.000	0.000	0.000	0.050
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.050	0.000	0.099
NNW	0.000	0.000	0.050	0.000	0.050	0.000	0.000	0.149
SUBTOTAL	0.000	0.149	2.132	2.281	0.694	0.297	0.000	5.553

TOTAL HOURS OF VALID STABILITY OBSERVATIONS  
 TOTAL HOURS OF STABILITY CLASS C  
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS C  
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS  
 TOTAL HOURS OF CALM

2067  
 112  
 112  
 2017  
 0

METEOROLOGICAL FACILITY: SEQUOYAH NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 9.25 AND 45.99 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 9.73 METER LEVEL

MEAN WIND SPEED = 4.00

DATE PRINTED: 26-OCT-95

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

## JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D (-1.5 &lt; DELTA T &lt;= -0.5 C/100 M)

SEQUOYAH NUCLEAR PLANT

JUL 1, 95 - SEP 30, 95

WIND DIRECTION	CALM	WIND SPEED (MPH)									TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.020	0.149	1.735	1.140	0.347	0.099	0.000	0.000	0.000	3.490	
NNE	0.013	0.149	1.091	1.289	0.793	1.041	0.000	0.000	0.000	4.376	
NE	0.006	0.099	0.496	0.099	0.050	0.000	0.000	0.000	0.000	0.750	
ENE	0.003	0.050	0.248	0.149	0.000	0.000	0.000	0.000	0.000	0.449	
E	0.001	0.000	0.050	0.099	0.050	0.000	0.000	0.000	0.000	0.199	
ESE	0.002	0.000	0.198	0.198	0.099	0.000	0.000	0.000	0.000	0.498	
SE	0.003	0.099	0.198	0.000	0.050	0.000	0.000	0.000	0.000	0.350	
SSE	0.006	0.050	0.496	0.595	0.545	0.198	0.000	0.000	0.000	1.890	
S	0.023	0.699	2.132	1.686	0.496	0.545	0.000	0.000	0.000	4.981	
SSW	0.030	0.446	2.429	2.975	0.297	0.099	0.000	0.000	0.000	6.277	
SW	0.013	0.050	1.239	0.892	0.050	0.000	0.000	0.000	0.000	2.244	
WSW	0.008	0.198	0.595	0.297	0.000	0.000	0.000	0.000	0.000	1.099	
W	0.005	0.099	0.397	0.000	0.099	0.000	0.000	0.000	0.000	0.600	
NNW	0.002	0.050	0.149	0.000	0.000	0.000	0.000	0.000	0.000	0.200	
NW	0.005	0.050	0.397	0.099	0.000	0.000	0.000	0.000	0.000	0.550	
NNW	0.009	0.000	0.892	0.347	0.347	0.000	0.000	0.000	0.000	1.596	
SUBTOTAL	0.149	1.587	12.742	9.866	3.223	1.983	0.000	0.000	0.000	29.549	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2067

TOTAL HOURS OF STABILITY CLASS D

605

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS D

596

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS

2017

TOTAL HOURS CALM

3

METEOROLOGICAL FACILITY: SEQUOYAH NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 9.25 AND 45.99 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 9.73 METER LEVEL

DATE PRINTED: 26-OCT-95

MEAN WIND SPEED = 3.83

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

## JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E (-0.5 &lt; DELTA T &lt;= 1.5 C/130 M)

SEQUOYAH NUCLEAR PLANT

JUL 1, 95 - SEP 30, 95

WIND DIRECTION	CALM	WIND SPEED (MPH)									TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.720	1.190	5.553	1.239	0.149	0.000	0.000	0.000	0.000	8.851	
NNE	0.387	1.190	2.429	1.190	0.000	0.000	0.000	0.000	0.000	5.196	
NE	0.037	0.149	0.198	0.050	0.050	0.000	0.000	0.000	0.000	0.483	
ENE	0.026	0.099	0.149	0.000	0.000	0.000	0.000	0.000	0.000	0.274	
E	0.021	0.000	0.198	0.050	0.000	0.000	0.000	0.000	0.000	0.379	
ESE	0.032	0.099	0.198	0.050	0.000	0.000	0.000	0.000	0.000	0.313	
SE	0.016	0.099	0.050	0.149	0.000	0.000	0.000	0.000	0.000	1.202	
SSE	0.111	0.397	0.645	0.050	0.000	0.000	0.000	0.000	0.000	1.795	
S	0.159	0.347	1.140	0.099	0.050	0.000	0.000	0.000	0.000	2.707	
SSW	0.228	0.446	1.686	0.297	0.050	0.000	0.000	0.000	0.000	3.354	
SW	0.281	0.545	2.082	0.347	0.099	0.000	0.000	0.000	0.000	1.850	
WSW	0.164	0.446	1.091	0.099	0.000	0.050	0.000	0.000	0.000	0.917	
W	0.074	0.099	0.595	0.099	0.000	0.050	0.000	0.000	0.000	1.087	
WNW	0.095	0.595	0.297	0.099	0.000	0.000	0.000	0.000	0.000	1.735	
NW	0.148	0.595	0.793	0.050	0.099	0.050	0.000	0.000	0.000	2.558	
NNW	0.228	0.694	1.438	0.149	0.050	0.000	0.000	0.000	0.000	32.970	
SUBTOTAL	2.727	6.991	18.542	4.016	0.545	0.149	0.000	0.000	0.000		

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2067
TOTAL HOURS OF STABILITY CLASS E	684
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS E	665
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2917
TOTAL HOURS CALM	55

METEOROLOGICAL FACILITY: SEQUOYAH NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 9.25 AND 45.99 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 9.73 METER LEVEL

DATE PRINTED: 26-OCT-95

MEAN WIND SPEED = 2.16

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

## JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F ( 1.5 &lt; DELTA T &lt;= 4.0 C/100 M)

## SEQUOYAH NUCLEAR PLANT

JUL 1, 95 - SEP 30, 95

WIND DIRECTION	CALM	WIND SPEED (MPH)			12.5-18.4	18.5-24.4	TOTAL 1 = 24.4
		0-6.1-4	1.5-3.4	3.5-5.4			
N	0.861	1.140	4.958	0.198	0.000	0.000	0.000
NNE	0.399	1.041	1.785	0.000	0.000	0.000	0.000
NE	0.035	0.198	0.050	0.000	0.000	0.000	0.000
NNE	0.007	0.000	0.050	0.000	0.000	0.000	0.057
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.021	0.050	0.099	0.000	0.000	0.000	0.170
E	0.021	0.149	0.000	0.000	0.000	0.000	0.170
SSE	0.049	0.248	0.099	0.000	0.000	0.000	0.396
S	0.035	0.149	0.099	0.000	0.000	0.000	0.283
SSW	0.056	0.099	0.297	0.000	0.000	0.000	0.453
SW	0.042	0.099	0.198	0.000	0.000	0.000	0.339
WSW	0.042	0.149	0.149	0.000	0.000	0.000	0.339
W	0.028	0.149	0.050	0.000	0.000	0.000	0.226
WNW	0.028	0.000	0.198	0.000	0.000	0.000	0.226
NW	0.049	0.149	0.198	0.000	0.000	0.000	0.396
NNW	0.161	0.248	0.892	0.099	0.000	0.000	1.401
SUBTOTAL	1.867	9.122	0.297	0.000	0.000	0.000	15.121

TOTAL HOURS OF VALID STABILITY OBSERVATIONS  
 TOTAL HOURS OF STABILITY CLASS F  
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS F  
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS  
 TOTAL HOURS CALM

2067  
 320  
 305  
 2017  
 37

METEOROLOGICAL FACILITY: SEQUOYAH NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 9.25 AND 45.99 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 9.73 METER LEVEL

MEAN WIND SPEED = 1.68

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 26-OCT-95

## JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G (DELTA T = 4.0 C/100 M)

## SEQUOYAH NUCLEAR PLANT

JUL 1, 95 - SEP 30, 95

WIND DIRECTION	CALM	WIND SPEED (MPH)			12.5-18.4	18.5-24.4	TOTAL
		0-6-1-4	1-5-3-4	3-5-5-4			
N	0.050	0.000	0.050	0.000	0.000	0.000	0.099
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SEE	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.050	0.000	0.050	0.000	0.000	0.000	0.099
SUBTOTAL	0.099	0.000	0.099	0.000	0.000	0.000	0.198

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2067

TOTAL HOURS OF STABILITY CLASS G

4

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS G

4

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS

2017

TOTAL HOURS CALM

2

METEOROLOGICAL FACILITY: SEQUOYAH NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 9.25 AND 45.99 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 9.73 METER LEVEL

MEAN WIND SPEED = 1.29

DATE PRINTED: 26-OCT-95

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

## JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A ( DELTA T &lt;= -1.9 C/100 M )

## SEQUOYAH NUCLEAR PLANT

OCT 1, 95 - DEC 31, 95

WIND DIRECTION	CALM	0.6-1.4			1.5-3.4			3.5-5.4			WIND SPEED(MPH)			5.5-7.4			7.5-12.4			12.5-18.4			18.5-24.4			TOTAL			
		0.000	0.049	0.098	0.342	0.049	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
N	0.000	0.000	0.049	0.098	0.342	0.049	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
NNE	0.000	0.000	0.049	0.098	0.293	0.489	0.293	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
NE	0.000	0.000	0.000	0.440	0.391	0.147	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
ENE	0.000	0.000	0.000	0.293	0.058	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
E	0.000	0.000	0.000	0.078	0.049	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
SSE	0.000	0.000	0.049	0.049	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
S	0.000	0.000	0.049	0.049	0.049	0.049	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
SSW	0.000	0.000	0.000	0.196	0.342	0.244	0.049	0.049	0.049	0.049	0.049	0.049	0.049	0.049	0.049	0.049	0.049	0.049	0.049	0.049	0.049	0.049	0.049	0.049	0.049	0.049	0.049	0.049	
SW	0.000	0.000	0.000	0.196	0.538	0.391	0.049	0.049	0.049	0.049	0.049	0.049	0.049	0.049	0.049	0.049	0.049	0.049	0.049	0.049	0.049	0.049	0.049	0.049	0.049	0.049	0.049	0.049	0.049
WSW	0.000	0.000	0.147	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
W	0.000	0.000	0.090	0.000	0.049	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
HNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
SUBTOTAL	0.000	0.000	1.614	1.907	1.711	1.663	1.711	1.663	1.663	1.663	1.663	1.663	1.663	1.663	1.663	1.663	1.663	1.663	1.663	1.663	1.663	1.663	1.663	1.663	1.663	1.663	1.663	1.663	1.663

TOTAL HOURS OF VALID STABILITY OBSERVATIONS  
 TOTAL HOURS OF STABILITY CLASS A  
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS A  
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS  
 TOTAL HOURS CALM

2191  
 142  
 141  
 2045  
 0

METEOROLOGICAL FACILITY: SEQUOYAH NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 9.25 AND 45.99 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 9.73 METER LEVEL

MEAN WIND SPEED = 5.53

DATE PRINTED: 23-JAN-96

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

## JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B (-1.9 &lt; DELTA T &lt;=-1.7 C/100 M)

SEQUOYAH NUCLEAR PLANT

OCT 1, 95 - DEC 31, 95

WIND DIRECTION	CALM	0.5-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	TOTAL
N	0.000	0.000	0.000	0.147	0.098	0.098	0.049	0.000	0.000	0.391
NNE	0.000	0.000	0.196	0.147	0.293	0.293	0.049	0.000	0.000	0.978
NE	0.000	0.000	0.244	0.293	0.244	0.147	0.020	0.000	0.000	0.929
ENE	0.000	0.000	0.147	0.000	0.000	0.000	0.000	0.000	0.000	0.147
E	0.000	0.000	0.098	0.098	0.000	0.000	0.000	0.000	0.000	0.196
ESE	0.000	0.000	0.098	0.000	0.000	0.000	0.000	0.000	0.000	0.098
SE	0.000	0.000	0.098	0.098	0.000	0.000	0.000	0.000	0.000	0.196
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.147	0.000	0.049	0.049	0.000	0.000	0.000	0.244
SSW	0.000	0.000	0.049	0.440	0.649	0.000	0.000	0.000	0.000	0.538
SW	0.000	0.000	0.196	0.342	0.000	0.000	0.000	0.000	0.000	0.538
WSW	0.000	0.000	0.098	0.000	0.000	0.049	0.000	0.000	0.000	0.147
W	0.000	0.000	0.049	0.000	0.000	0.049	0.000	0.000	0.000	0.098
WNW	0.000	0.000	0.000	0.000	0.000	0.049	0.000	0.000	0.000	0.049
NW	0.000	0.000	0.000	0.049	0.000	0.000	0.000	0.000	0.000	0.049
NNW	0.000	0.000	^ 0.00	0.147	0.147	0.000	0.000	0.000	0.000	0.293
SUBTOTAL	0.000	0.000	1.418	1.760	0.880	0.733	0.098	0.000	0.000	4.890

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2191

TOTAL HOURS OF STABILITY CLASS B

104

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS B

100

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS

2045

TOTAL HOURS CALM

0

METEOROLOGICAL FACILITY: SEQUOYAH NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 9.25 AND 45.99 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 9.73 METER LEVEL

DATE PRINTED: 23-JAN-96

MEAN WIND SPEED = 5.09

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

## JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C (-1.7 &lt; DELTA T &lt;= -1.5 C/100 M)

## SEQUOYAH NUCLEAR PLANT

OCT 1, 95 - DEC 31, 95

WIND DIRECTION	CALM	WIND SPEED(MPH)									TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>24.5		
N	0.000	0.000	0.000	0.049	0.049	0.147	0.000	0.000	0.000	0.244	
NNE	0.000	0.000	0.342	0.098	0.147	0.587	0.098	0.000	0.000	1.271	
NE	0.000	0.000	0.391	0.147	0.196	0.000	0.030	0.000	0.000	0.733	
ENE	0.000	0.000	0.049	0.000	0.000	0.000	0.000	0.000	0.000	0.049	
E	0.000	0.000	0.098	0.000	0.000	0.000	0.000	0.000	0.000	0.098	
EE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
S	0.000	0.000	0.049	0.049	0.000	0.049	0.000	0.000	0.000	0.147	
SSW	0.000	0.000	0.049	0.342	0.049	0.000	0.000	0.000	0.000	0.440	
SW	0.000	0.049	0.147	0.538	0.098	0.000	0.000	0.000	0.000	0.831	
WSW	0.000	0.000	0.147	0.049	0.000	0.098	0.000	0.000	0.000	0.293	
W	0.000	0.000	0.000	0.000	0.000	0.049	0.000	0.000	0.000	0.049	
WNW	0.000	0.000	0.049	0.000	0.000	0.000	0.000	0.000	0.000	0.049	
NW	0.000	0.000	0.000	0.049	0.000	0.000	0.000	0.000	0.000	0.049	
NNW	0.000	0.000	0.000	0.147	0.196	0.049	0.000	0.000	0.000	0.391	
SUBTOTAL	0.000	0.049	1.320	1.467	0.733	0.978	0.098	0.000	0.000	4.645	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2191
TOTAL HOURS OF STABILITY CLASS C	96
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS C	95
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2045
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: SEQUOYAH NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 9.25 AND 45.99 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 9.73 METER LEVEL

DATE PRINTED: 23-JAN-96

MEAN WIND SPEED = 5.40

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

## JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D (-1.5 &lt; DELTA T &lt;= -0.5 C/100 M)

SEQUOYAH NUCLEAR PLANT

OCT 1, 95 - DEC 31, 95

WIND DIRECTION	CALM	WIND SPEED(MPH)									TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>24.5		
N	0.021	0.342	1.222	1.663	2.689	1.467	0.000	0.000	0.000	7.405	
NNE	0.026	0.147	1.809	1.760	1.369	2.298	0.049	0.000	0.000	7.459	
NE	0.007	0.049	0.489	0.391	0.098	0.000	0.098	0.000	0.000	1.132	
ENE	0.004	0.098	0.196	0.049	0.000	0.000	0.000	0.000	0.000	0.346	
E	0.001	0.000	0.098	0.000	0.000	0.000	0.000	0.000	0.000	0.099	
ESE	0.001	0.000	0.049	0.000	0.000	0.049	0.000	0.000	0.000	0.098	
SE	0.002	0.000	0.147	0.000	0.000	0.000	0.000	0.000	0.000	0.149	
SSE	0.005	0.098	0.293	0.049	0.000	0.000	0.000	0.000	0.000	0.445	
S	0.014	0.147	0.929	0.440	0.196	0.636	0.098	0.000	0.000	2.459	
SSW	0.020	0.147	1.369	1.565	0.587	0.489	0.000	0.000	0.000	4.177	
SW	0.021	0.147	1.418	1.369	0.342	0.244	0.000	0.000	0.000	3.542	
WSW	0.006	0.049	0.440	0.049	0.196	0.244	0.000	0.000	0.000	0.984	
W	0.004	0.098	0.196	0.049	0.000	0.196	0.000	0.000	0.000	0.542	
WNW	0.003	0.049	0.196	0.147	0.147	0.244	0.000	0.000	0.000	0.786	
NW	0.005	0.098	0.244	0.538	0.440	0.196	0.000	0.000	0.000	1.520	
NNW	0.006	0.244	0.244	0.782	1.467	0.538	0.000	0.000	0.000	3.283	
SUBTOTAL	0.147	1.711	9.340	8.851	7.531	6.601	0.244	0.000	0.000	34.425	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2191

TOTAL HOURS OF STABILITY CLASS D

728

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS D

704

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS

2045

TOTAL HOURS CALM

3

METEOROLOGICAL FACILITY: SEQUOYAH NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 9.25 AND 45.99 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 9.73 METER LEVEL

DATE PRINTED: 23-JAN-96

MEAN WIND SPEED = 5.14

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

## JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E (-0.5 &lt; DELTA T &lt;= 1.5 C/100 M)

SEQUOYAH NUCLEAR PLANT

OCT 1, 95 - DEC 31, 95

WIND DIRECTION	CALM	WIND SPEED (MPH)									TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.200	0.685	2.836	1.320	0.782	0.342	0.000	0.000	0.000	6.166	
NNE	0.150	0.489	2.152	0.782	0.685	0.293	0.000	0.000	0.000	4.551	
NE	0.017	0.098	0.196	0.049	0.000	0.000	0.000	0.000	0.000	0.359	
ENE	0.011	0.147	0.049	0.000	0.000	0.000	0.000	0.000	0.000	0.207	
E	0.006	0.049	0.049	0.000	0.000	0.000	0.000	0.000	0.000	0.103	
ESE	0.011	0.196	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.207	
SE	0.017	0.244	0.049	0.000	0.000	0.000	0.000	0.000	0.000	0.310	
SSE	0.022	0.196	0.196	0.049	0.000	0.000	0.098	0.000	0.000	0.560	
S	0.080	0.391	1.027	0.636	0.342	0.293	0.098	0.000	0.000	2.868	
SSW	0.150	0.244	2.396	1.174	0.489	0.196	0.000	0.000	0.000	4.649	
SW	0.133	0.196	2.152	1.516	0.391	0.049	0.000	0.000	0.000	4.436	
WSW	0.044	0.196	0.587	0.196	0.196	0.000	0.000	0.000	0.000	1.218	
W	0.025	0.196	0.244	0.049	0.049	0.000	0.000	0.000	0.000	0.563	
WNW	0.033	0.244	0.342	0.342	0.000	0.000	0.049	0.000	0.000	1.011	
NW	0.044	0.196	0.587	0.391	0.196	0.049	0.000	0.000	0.000	1.462	
NNW	0.083	0.342	1.125	0.440	0.342	0.000	0.000	0.000	0.000	2.333	
SUBTOTAL	1.027	4.108	13.985	6.944	3.472	1.222	0.244	0.000	0.000	31.002	

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2191

TOTAL HOURS OF STABILITY CLASS E

685

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS E

634

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS

2045

TOTAL HOURS CALM

21

METEOROLOGICAL FACILITY: SEQUOYAH NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 9.25 AND 45.99 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 9.73 METER LEVEL

DATE PRINTED: 23-JAN-96

MEAN WIND SPEED = 3.38

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

## JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F ( 1.5 &lt; DELTA T &lt;= 4.0 C/100 M)

SEQUOYAH NUCLEAR PLANT

OCT 1, 95 - DEC 31, 95

WIND DIRECTION	CALM	WIND SPEED(MPH)									TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>24.5		
N	0.187	0.342	2.445	0.098	0.000	0.000	0.000	0.000	0.000	3.072	
NNE	0.265	1.222	2.738	0.000	0.000	0.000	0.000	0.000	0.000	4.226	
NE	0.059	0.636	0.244	0.000	0.000	0.000	0.000	0.000	0.000	0.939	
ENE	0.010	0.049	0.098	0.000	0.000	0.000	0.000	0.000	0.000	0.157	
E	0.007	0.098	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.104	
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
SE	0.010	0.147	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.157	
SSE	0.020	0.196	0.098	0.000	0.000	0.000	0.000	0.000	0.000	0.313	
S	0.039	0.342	0.244	0.049	0.000	0.000	0.000	0.000	0.000	0.675	
SSW	0.075	0.196	0.929	0.049	0.000	0.000	0.000	0.000	0.000	1.249	
SW	0.072	0.049	1.027	0.196	0.000	0.000	0.000	0.000	0.000	1.343	
WSW	0.007	0.000	0.098	0.000	0.000	0.000	0.000	0.000	0.000	0.104	
W	0.007	0.000	0.098	0.147	0.000	0.000	0.000	0.000	0.000	0.251	
WNW	0.020	0.098	0.196	0.098	0.000	0.000	0.000	0.000	0.000	0.411	
NW	0.036	0.244	0.293	0.196	0.000	0.000	0.000	0.000	0.000	0.769	
NNW	0.069	0.293	0.733	0.196	0.000	0.000	0.000	0.000	0.000	1.291	
SUBTOTAL	0.880	3.912	9.242	1.027	0.000	0.000	0.000	0.000	0.000	15.061	

AL HOURS OF VALID STABILITY OBSERVATIONS	2191
TOTAL HOURS OF STABILITY CLASS F	357
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS F	308
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2045
TOTAL HOURS CALM	18

METEOROLOGICAL FACILITY: SEQUOYAH NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 9.25 AND 45.99 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 9.73 METER LEVEL

DATE PRINTED: 23-JAN-96

MEAN WIND SPEED = 1.96

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

## JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G ( DELTA T &gt; 4.0 C /100 M)

## SEQUOYAH NUCLEAR PLANT

-T 1, 95 - DEC 31, 95

WIND DIRECTION	CALM	WIND SPEED (MPH)						>= 24.5
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	
N	0.010	0.049	0.147	0.000	0.000	0.000	0.000	0.000
NNE	0.035	0.147	0.538	0.000	0.000	0.000	0.000	0.719
NE	0.015	0.147	0.147	0.000	0.000	0.000	0.000	0.308
ENE	0.005	0.049	0.049	0.000	0.000	0.000	0.000	0.103
E	0.002	0.049	0.000	0.000	0.000	0.000	0.000	0.051
ESE	0.005	0.098	0.000	0.000	0.000	0.000	0.000	0.103
SE	0.007	0.147	0.000	0.000	0.000	0.000	0.000	0.154
SSE	0.005	0.098	0.000	0.000	0.000	0.000	0.000	0.103
S	0.017	0.147	0.196	0.000	0.000	0.000	0.000	0.360
SSW	0.022	0.098	0.342	0.000	0.000	0.000	0.000	0.462
SW	0.012	0.000	0.244	0.049	0.000	0.000	0.000	0.306
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.002	0.006	0.049	0.000	0.000	0.000	0.000	0.051
WNW	0.005	0.000	0.098	0.000	0.000	0.000	0.000	0.103
NNW	0.002	0.000	0.049	0.000	0.000	0.000	0.000	0.051
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.147	1.027	1.358	0.049	0.000	0.000	0.000	3.081

TOTAL HOURS OF VALID STABILITY OBSERVATIONS  
 TOTAL HOURS OF STABILITY CLASS G  
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS G  
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS  
 TOTAL HOURS CALM

2191  
79  
63  
2045  
3

METEOROLOGICAL FACILITY: SEQUOYAH NUCLEAR PLANT  
 STABILITY BASED ON DELTA-T BETWEEN 9.25 AND 45.99 METERS  
 WIND SPEED AND DIRECTION MEASURED AT 9.73 METER LEVEL

MEAN WIND SPEED = 1.69

DATE PRINTED: 23-JAN-96

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS