NRC Form 366 (9/83)					LICENSEE EVENT REPORT (LER)							U.S. NUCLEAR REGULATORY COMMISSION APPROVED OMB NO. 3150-0104 EXPIRES: 8/31/85									
FACILITY NAME (1)													DOCKET NUMBER (2) PAG								
SAN ONOFRE NUCLEAR GENERATING STATION, UNIT 2												5	0	010	1 3	6	1 1	OF	0	1	
SPURIOU		ROL R	DOM ISO		N SY		(CRIS		VATIO		RFAC		FS	INV	21 V	ED (I					
MONTH DAY			seq.	10001	REV.	N. O. L. Will	DAY	YEAR	PACILITY NAMES			-		DOCKET NUMBER(S)							
MONTH DAY	YEAR	YEAR	NUMB	IR N	UMBER	MONTH	DAY	75.24	SONGS, U			UNI	L	3	0 5	0	0 0	L	3 6	12	
10 d	3 8 4	8 4	d 5	7	d o	1 1	d 1	8 4							0 5 0 0 0						
OPERATI		THIS R	EPORT IS SU	BMITTED	PURS	UANT TO	THE R	EQUIRE	MENTS O	F 10 CFR S	(Check	one o	or m	ore o	if the	follo	wing) (1	1)		
MODE (1	2	20.402(b)			70.405(c)			X 50.73(a)(2)(iv)				L	73.71(b)							
POWER		2	0.405(a)(1)(50.36(c)(1)			50.73(a)(2)(v)			L	73.71(c)									
LEVEL (10)	085	. 2	20.405(a)(1)(iii) 20.405(a)(1)(iii) 20.405(a)(1)(iv)			50.36(c)(2) 50.73(a)(2)(i) 50.73(a)(2)(ii)			50.73(a)(2)(vii) 50.73(a)(2)(viii)(A) 50.73(a)(2)(viii)(B)			L	OTHER (Specify in Abstract								
		2										4	Form 366A)								
		2)									
		2	0.405(a)(1)(50.73(a)(2)(iii)			50.73(a)(2)(x)													
					LICE	NSEE CO	ONTAC	TFORT	HIS LE	R (12)											
NAME											TELEPHONE NUMBER										
												AREA CODE									
<u> </u>	J.		YNES, S					IT FAILL	RE DES	CRIBED IN THI	S REPO	DRT (13)	4	4	9 2	-	7	7.0	(
CAUSE SYSTEM	AUSE SYSTEM COMPONER		MANUPAC REPOR					CAUSE 5		YSTEM COMPONENT		MANUPAC- TURER		REPORTABLE TO NPROS							
	11	1	111							111	1	1.1									
	1		1 1 1							1.1.1		1 1									

Abstract (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

YES (IF yes, complete EXPECTED SUBMISSION DATE)

SUPPLEMENTAL REPORT EXPECTED (14)

On 10/3/84, at 0025, with Units 2 and 3 in Mode 1 at 85% and 100% power, respectively, the Control Room Isolation System (CRIS) (EIIS System Code VA) Train 'A' spuriously actuated during the performance of a check-source test. The Control Room Emergency Air Cleanup System (CREACUS) (EIIS System Code VI) actuated as required. The CRIS actuation was verified to be spurious and was reset at 0027.

The cause of the spurious actuation was that during the check-source test the alarm defeat function on CRIS Radiation Monitor 2/3RI-7824 (EIIS Component Code RIT) was removed before the check-source radiation levels dropped below the monitor actuation setpoint. The check-source test was unnecessarily performed by an operator during the shiftly radiation monitor surveillance.

Corrective action was to counsel the operator on the importance of using procedures when performing even minor evolutions. Further corrective action is to discuss this item in shift briefings as an example of where not using procedures for even minor evolutions can result in error.

There are no reasonable or credible circumstances which could have increased the severity of this event. Neither the health and safety of plant personnel nor the public were affected.

9411160065 841101 PDR ADOCK 05000361 PDR

IE 22

MONTH

DATE (15)

YEAR

Southern California Edison Company



SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

J. G. HAYNES

November 1, 1984

TELEPHONE (7)4) 492-7700

U.S. Nuclear Regulatory Commission Document Control Desk Washington, D.C. 20555

Subject:

Docket No. 50-361 30-Day Report

Licensee Event Report No. 84-057

San Onofre Nuclear Generating Station, Units 2 and 3

Pursuant to 10 CFR 50.73(a)(2)(iv), this submittal provides the required 30-day written Licensee Event Report (LER) for an occurrence involving the spurious actuation of the Control Room Isolation System (CRIS). Since this occurrence involved a shared system between Units 2 and 3, a single report is being submitted in accordance with NUREG-1022.

If you require any additional information, please so advise.

Voi Haynes

Enclosure: LER 84-057

cc: F. R. Huey (USNRC Senior Resident Inspector, Units 1, 2 and 3)

J. P. Stewart (USNRC Resident Inspector, Units 2 and 3)

J. B. Martin (Regional Administrator, NRC Region V)

Institute of Nuclear Power Operations (INPO)

TE22