

APPENDIX A

NOTICE OF VIOLATION

Philadelphia Electric Company
Peach Bottom Unit 2

Docket/License: 50-277/DPR-44

As a result of the inspection conducted on September 1 - October 10, 1984, and in accordance with the revised NRC Enforcement Policy (10 CFR 2, Appendix C), published in the Federal Register on March 8, 1984 (49 FR 8583), the following violation was identified:

Technical Specification 6.8 and Regulatory Guide 1.33 (November 1972) require implementation of procedures for control of radioactivity. Procedure HPO/CO-100, Revision 13, April 25, 1983, Health Physics Guides Used in the Control of Exposure to Radioactive Material, requires posting, with "Contaminated Area" signs or a radiation tape barrier line, of areas having removable surface contamination above 1000 disintegrations per minute per 100 square centimeters (dpm/100 cm²).

Contrary to the above, on September 4, 1984, the condensate pump area had removable contamination of up to 12,000 dpm/100 cm² and was not posted with "Contaminated Area" signs or a radiation tape barrier line at the entrance from the condenser area walkway.

This is a Severity Level V Violation (Supplement IV) applicable to DPR-44.

Because the violation was corrected during the inspection period and corrective actions to avoid further violations were also made, no written response is required.

B411160277 841108
PDR ADOCK 05000277
Q PDR