

FEB 28 1985

Docket 50-368

MEMORANDUM TO: File

FROM: Guy S. Vissing, Project Manager  
Operating Reactors Branch #4  
Division of Licensing

SUBJECT: PROPOSED TECHNICAL SPECIFICATIONS CONCERNING KEY LOCK  
SWITCHES FOR PURGE VALVES FOR ANO-2

The enclosed proposed draft Technical Specification was received from Arkansas Power and Light Company via the NRC IBM 5520 system on February 21, 1985 for discussion purpose.

**"ORIGINAL SIGNED BY:"**

Guy S. Vissing, Project Manager  
Operating Reactors Branch #4  
Division of Licensing

Enclosure  
As stated

cc w/enclosure:  
NRC PDR  
L PDR

DISTRIBUTION:  
Memo File  
ORB#4 Rdg  
GVissing

~~DL~~  
GVissing;cf  
2/21/85

ORB#4:DL  
JStolz  
2/21/85

8503070511 850228  
PDR ADOCK 05000368  
P PDR

3.6.1.6 The containment purge supply and exhaust isolation valves shall be closed and handswitch keys removed.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With one containment purge supply and/or exhaust isolation valves not closed with the handswitch keys removed, place the valve(s) in the closed position with handswitch key(s) removed within 1 hour or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

---

4.6.1.6 The containment purge supply and exhaust isolation valves shall be determined closed at least once per 31 days.