



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

NORTHEAST NUCLEAR ENERGY COMPANY
THE CONNECTICUT LIGHT AND POWER COMPANY
THE WESTERN MASSACHUSETTS ELECTRIC COMPANY
DOCKET NO. 50-336
MILLSTONE NUCLEAR POWER STATION, UNIT NO. 2
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 98
License No. DPR-65

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Northeast Nuclear Energy Company, et al. (the licensee), dated December 10, 1984 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-65 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 98, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


James R. Miller, Chief
Operating Reactors Branch #3
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: February 12, 1985

ATTACHMENT TO LICENSE AMENDMENT NO.98

FACILITY OPERATING LICENSE NO. DPR-65

DOCKET NO. 50-336

Remove and replace the following page of the Appendix A Technical Specifications with the enclosed page. The revised page is identified by amendment number and contains vertical lines indicating the area of change. The corresponding overleaf page is provided to maintain document completeness.

Remove

3/4 9-4

Insert

3/4 9-4

REFUELING OPERATIONS

CONTAINMENT PENETRATIONS

LIMITING CONDITION FOR OPERATION

3.9.4 The containment penetrations shall be in the following status:

- a. The equipment door closed and held in place by a minimum of four bolts or the outage equipment door is installed,
- b. A minimum of one door in each airlock is closed, and
- c. Each penetration providing direct access from the containment atmosphere to the outside atmosphere shall be either:
 1. Closed by an isolation valve, blind flange, manual valve, or special device, or
 2. Be capable of being closed by an OPERABLE automatic containment purge valve.

APPLICABILITY: During CORE ALTERATIONS or movement of irradiated fuel within the containment.

ACTION:

With the requirements of the above specification not satisfied, immediately suspend all operations involving CORE ALTERATIONS or movement of irradiated fuel in the containment.

SURVEILLANCE REQUIREMENTS

4.9.4 Each of the above required containment penetrations shall be determined to be either in its isolated condition or capable of being closed by an OPERABLE automatic containment purge valve within 72 hours prior to the start of and at least once per 31 days during CORE ALTERATIONS or movement of irradiated fuel in the containment by:

- a. Verifying the penetrations are in their isolated condition, or
- b. Testing the containment purge valves per the applicable portions of Specification 4.6.3.1.2.

REFUELING OPERATIONS

DECAY TIME

LIMITING CONDITION FOR OPERATION

3.9.3 The reactor shall be subcritical for a minimum of 72 hours prior to movement of irradiated fuel in the reactor pressure vessel.

APPLICABILITY: MODE 6.

ACTION:

With the reactor subcritical for less than 72 hours, suspend all operations involving movement of irradiated fuel in the reactor pressure vessel.

SURVEILLANCE REQUIREMENTS

4.9.3 The reactor shall be determined to have been subcritical for at least 72 hours by verification of the date and time of subcriticality prior to movement of irradiated fuel in the reactor pressure vessel.