

**SOUTH TEXAS PROJECT UNITS 1 & 2
HOUSTON LIGHTING & POWER
CALCULATION COVER SHEET**

CALCULATION NUMBER: NC-6061

CALCULATION TITLE: Main Steam Line Break Doses for Alternate Plugging Criteria (UFSAR Chapter 15.1.5)

SUBJECT: Calculation of offsite doses for the Main Steam Line Break

BUILDING/AREA/SYSTEMS: N/A

DISCIPLINE: NUCLEAR

QUALITY CLASS: 4 (Safety Related)

UNIT: 9 (Units 1 & 2)

CALCULATION STATUS: Final

OBJECTIVE: To determine the offsite dose consequences of a main steamline break incident (MSLBI).

This calculation was performed to support Technical Specification Change 182 (Condition Report #95-2339 Corrective Action 1). It determines the limiting primary to secondary break flow following a MSLB which results in doses which are 90% (an administrative limit set to preserve 10% margin) of the acceptance criteria for offsite, control room and TSC doses. This break flow is used to support the alternate plugging criteria detailed in the referenced Tech. Spec.

Revision 1 changes the allowable primary to secondary leakage before the postulated steam generator break from .1 gpm to .42 gpm (150 gpd per steam generator or a total of 600 gpd). This is done to be consistent with the revised Technical Specification Change.

SCOPE: The calculation is applicable to Units 1& 2. Calculation assumes modifications 93053, and 93054, Replacement of the Target Rock Main Steam Isolation Valve Above Seat Drain Valves have been completed. If these modifications have not been completed the calculation is conservative.

RESULTS: The limiting primary to secondary break flow is ~~5+~~ 5.0 gpm. This flow results in a TSC thyroid dose at 30 days of 27 Rem. A comprehensive summary of the results is given on the next page.

TOTAL NUMBER OF SHEETS: 746 221

REV NO.	1		SUP. ENG.	D. E. Gore	<i>[Signature]</i> 3/86
PREPARER	W. M. Blumberg	<i>WM Blumberg 4/2/96</i>	DIV. MGR.	D.A. Leazar	<i>[Signature]</i> 3/86
REVIEWER	M. A. Whitley	<i>Michael A. Whitley 4/2/96</i>	D.C. ISSUE DATE	2/13/96	

**SOUTH TEXAS PROJECT UNITS 1 & 2
HOUSTON LIGHTING & POWER
CALCULATION COVER SHEET (Continuation)**

- | CALCULATION NUMBER: NC-6061, Revision 0 1
- | CALCULATION TITLE: Main Steam Line Break Doses for Alternate Plugging Criteria (UFSAR
Chapter 15.1.5)
- | RESULTS: The MSLBI doses based upon a 5.4 5.0 gpm primary to secondary break flow
are given below:

	Doses (Rem)	
	MSLBI Doses	Acceptance Criteria (Ref. 16)
Case C 5% Failed Fuel		
EAB (0-2hr) Thyroid Dose	1.33E+2	300
EAB (0-2hr) Whole - Body Gamma Dose	5.62E-1 5.68E-1	25
EAB (0-2hr) Beta- Skin Dose	1.88E-1 1.92E-1	25
LPZ (0-30 days) Thyroid Dose	1.08E+2	300
LPZ (0-30 days) Whole-Body Gamma Dose	2.80E-1 2.85E-1	25
LPZ (0-30 days) Beta-Skin Dose	9.84E-2 1.01E-1	25
CR (0-30 days) Thyroid Dose	1.95E+1	30
CR (0-30 days) Whole - Body Gamma Dose	8.08E-2 9.35E-2	5
CR (0-30 days) Beta- Skin Dose	8.00E-1 9.31E-1	30
TSC (0-30 days) Thyroid Dose	2.70E+1	30
TSC (0-30 days) Whole-Body Gamma Dose	5.18E-2 5.96E-2	5
TSC (0-30 days) Beta-Skin Dose	9.01E-1 1.04E+0	30

WMB MW
4/96 4-96

SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION
HOUSTON LIGHTING AND POWER COMPANY
GENERAL COMPUTATIONAL SHEET

SUBJECT: MAIN STEAM LINE BREAK DOSES FOR ALTERNATE PLUGGING
CRITERIA (UFSAR CHAPTER 15.1.5)

UNIT: 9 (UNITS 1 & 2)

CALC NO: NC-6061

Sheet 4

REV.

PREPARER / DATE

REVIEWER / DATE

1

W. M. Blumberg, 4/96

WmB

M. A. Whitley 4/96

Maw

INDEX TO CALCULATION REVISIONS

CALC REV	CHANGE DOC. NO.	DESCRIPTION OF CHANGES	AFFECTED SHEETS	MODIFIED SHEETS
0	-	Initial Issue.	-	-
1		Revision 1 changes the allowable primary to secondary leakage before the postulated steam generator break from .1 gpm to .42 gpm (150 gpd per steam generator or a total of 600 gpd). This is done to be consistent with the revised Technical Specification Change.	Deleted 2, A-1a- A-1i, A-1 - A-36, B-1a - B1i, B-1 - B-36, C-1a - C-1i, C-1 - C-34, D-1a - D-1i, D-1 - D-34 E-1a- E-1i, E-1 - E-34, F-1a - F1i, F-1 - F-34, G-1a - G-1i, G-1 - G-36, H-1a - H-1i, H-1 - H-36 I-1a- I-1i, I-1 - I-34, J-1a - J1i, J-1 - J-34, M-1a- M-1i, M-1 - M-34, O-1a - O-1i, O-1 - O-34,	Revised 1,3,4,5,6,7,8, 13,15,17,26, 27,31, 32,33,34,35, 36,37,38,39, 40,46 Replaced 41,42, 43, 44, 45

SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION HOUSTON LIGHTING AND POWER COMPANY GENERAL COMPUTATIONAL SHEET	CALC NO: NC-6061	Sheet 5
SUBJECT: MAIN STEAM LINE BREAK DOSES FOR ALTERNATE PLUGGING CRITERIA (UFSAR CHAPTER 15.1.5)	REV.	PREPARER / DATE
UNIT: 9 (UNITS 1 & 2)	1	W. M. Blumberg, 4/96 <i>WMB</i>
		M. A. Whitley 4/96 <i>new</i>

Table of Contents

I. Purpose	6
II. References	6
III Criteria, Codes and Standards	7
IV Assumptions	7
V Input	9
VI Method	15
VII Calculation	18
VIII Future Margin	46

Appendices

A Case A1
B Case A2
C Case A3
D Case A4 and Case B4
E Case A5
F Case A6 and Case B6
G Case B1
H Case B2
I Case B3
J Case B5
K Case C1
L Case C2
M Case C3
N Case C4
O Case C5
P Case C6

List of Effective Pages

~~1-46~~ 1, 3-46

~~A-1a-A-1i, A-1-A-36, B-1a-B1i, B-1-B-36, C-1a-C1i, C-1-C-34, D-1a-D1i, D-1-D-34~~
~~E-1a-E1i, E-1-E-34, F-1a-F1i, F-1-F-34, G-1a-G1i, G-1-G-36, H-1a-H1i, H-1-H-36~~
~~I-1a-I1i, I-1-I-34, J-1a-J1i, J-1-J-34, K-1a-K-1i, K-1-K-36, L-1a-L-1i, L-1-L-36~~
~~M-1a-M1i, M-1-M-34, N-1a-N1i, N-1-N-34, O-1a-O1i, O-1-O-34, P-1a-P-1i, P-1-P-34~~

SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION
HOUSTON LIGHTING AND POWER COMPANY
GENERAL COMPUTATIONAL SHEET

SUBJECT: **MAIN STEAM LINE BREAK DOSES FOR ALTERNATE PLUGGING
CRITERIA (UFSAR CHAPTER 15.1.5)**

UNIT: **9 (UNITS 1 & 2)**

CALC NO: **NC-6061**

Sheet 6

REV.

PREPARER / DATE

REVIEWER / DATE

1

W. M. Blumberg, 4/96
WMB

M. A. Whitley 4/96
MAW

I. Purpose

To determine the limiting primary to secondary steam generator break flow following a MSLB. The limiting flow will be calculated based upon offsite, Technical Support Center (TSC) and Control Room Doses (CR). The flow which corresponds to 90%¹ of the NRC acceptance criteria for any of these locations (See the section entitled Criteria, Codes and Standards) will be the limiting flow. Once this flow is calculated it will be used to determine the offsite, CR and TSC dose consequences utilizing the most limiting source term.

II. References

1. USNRC Standard Review Plan 15.1.5.
2. ST-HL-YB-4136, "STP Atmospheric Dispersion Factors," PFN N2.6, June 12, 1984, Dames and Moore to STP.
3. USAEC Regulatory Guide 1.25, 3-23-72.
4. Westinghouse SIP Vol 3-1, Radiation Analysis Design Manual, Rev. 4, 8/92, TPNS #14926 - 450 (1) or (2) - 002 - EWN.
5. Regulatory Guide 1.4, Revision 2, June 1974
6. K. G. Murphy and K. M. Campe, "Nuclear Power Plant Control Room Ventilation System Design for Meeting General Criterion 19," Paper presented at the 13th AEC Air Cleaning Conference, CONF-740807, Volume 1, pages 401-430, Edited March 1975.
7. Letter # ST-WN-YB-1001, dated 6/13/84, and Letter # ST-WN-YB-650, dated 5-10-84.
8. Calculation NC6020-3, "CPDS Regenerative Source Terms."
9. Letter # ST-WN-BR-1055, 11/11/77.
10. Letter # ST-WN-YB-1030, 6/25/84.
11. "NC-5110, Revision 0, Evaluation of Above Seat Main Steam Line Drain SOV's Deletion."
12. "TRACI-Version 1.0, CCVR," Signed 8/12/94, RMS Document #R16.16, Record TRACI, Revision 0.
13. "TRACI-Version 1.0, Production Computer Code Manual," RMS Document #R16.24, Record # TRACI, Revision 0, Signed 8/8/94.
14. South Texas Project UFSAR, Revision 3.
15. "NE319/2 - LOCADOSE Multi-Region Activity and Dose Calculations," Bechtel Power Corporation, Feb. 4, 1983 (Used for the DCF for Xe-137).
16. "NUREG-0781, Safety Evaluation Report related to the operation of South Texas Project, Units 1 and 2," Controlled copy #319, March 22, 1993, page 15-9.
17. NC-6007, Revision 6, "Fuel Handling Accident in Fuel Handling Building."

¹ 90% of the acceptance criteria was selected as an administrative limit to allow for 10% margin. The 10% margin is reserved for future use.

SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION HOUSTON LIGHTING AND POWER COMPANY GENERAL COMPUTATIONAL SHEET	CALC NO: NC-6061	Sheet 7
SUBJECT: MAIN STEAM LINE BREAK DOSES FOR ALTERNATE PLUGGING CRITERIA (UFSAR CHAPTER 15.1.5)	REV.	PREPARER / DATE
UNIT: 9 (UNITS 1 & 2)	1	W. M. Blumberg, 4/96 <i>LMB</i>
		M. A. Whitley 4/96 <i>maw</i>

18. NE-CE-94-07-00, "Control Room Nodalization Study," RMS STI #95000614, RMS Prefix CALC, File # D7.9.4.1.
19. NC-6013, Revision 8, "Control Room, TSC and Offsite LOCA Radiation Doses."
20. EPRI report TR-103878, "Technical Basis for Considering Uncertainties in I131 Release and Dose Limits for a Postulated Accident."
21. NUREG-1477, "Voltage-Based Interim Plugging Criteria for Steam Generator Tubes - Task Group Report."

III. Criteria, Codes and Standards

The acceptance criteria for the cases considered in this analysis is as follows:

Offsite Doses (per Reference 16)

30 Rem thyroid, 2.5 Rem whole-body and 2.5 Rem beta

The case of a MSLBI with an equilibrium iodine concentration in combination with an assumed accident-generated iodine spike.

300 Rem thyroid, 25 Rem whole-body and 25 Rem beta

The case of a pre-accident iodine spike, or for a MSLBI with the highest worth control rod stuck out of the core (5% failed fuel).

Control Room and TSC Doses (per GDC 19, see Reference 16, page 6-28)

30 Rem thyroid, 5 Rem whole body and 30 Rem beta

IV. Assumptions

1. For a pre-existing iodine spike, the activity in the reactor coolant is based upon an iodine spike which has raised the reactor coolant concentration to 60 micro Ci/gm of dose equivalent I-131. The secondary coolant activity is based on .1 micro Ci/gm of dose equivalent I-131. Noble gas activity is based on 1% failed fuel.
2. The total steam generator tube leak rate prior to the accident and until 8 hours after the start of the accident is ~~-0.1~~ 0.42 gpm (approx. 600 gpd). This is conservatively divided into ~~-0.35~~ 0.147 gpm (35%) to the affected loop and ~~-0.65~~ 0.273 gpm (65%) to the unaffected loops.
3. For a concurrent iodine spike, the accident initiates an iodine spike in the RCS which increases the iodine release rate from the fuel to a value 500 times greater than the release rate corresponding to a RCS concentration of 1 micro Ci/gm dose equivalent I-131. The iodine activity released to the RCS in the duration of the accident is conservatively assumed

SUBJECT: **MAIN STEAM LINE BREAK DOSES FOR ALTERNATE PLUGGING CRITERIA (UFSAR CHAPTER 15.1.5)**
 UNIT: **9 (UNITS 1 & 2)**

CALC NO: **NC-6061**

Sheet 8

REV.	PREPARER / DATE	REVIEWER / DATE
1	W. M. Blumberg, 4/96 <i>WmB</i>	M. A. Whitley 4/96 <i>Maw</i>

to mix instantaneously and uniformly in the RCS. Noble gas activity is based on 1% failed fuel.

4. No iodine spiking is assumed to occur with accident initiated fuel failures. For this case the RCS concentration is based on 5% of failed fuel for both iodines and gases. At the start of the accident the secondary activity is based upon 1% failed fuel. The activity due to failed fuel is assumed to mix instantaneously and uniformly in the RCS.
5. Following the rupture, auxiliary feedwater to the faulted loop is isolated and the steam generator is allowed to steam dry. Thus, the iodine partition factor for the affected steam generator is 1. The iodine partition factor for the unaffected steam generators is 0.01.
6. Offsite Power is lost.
7. The condensers are unavailable for steam dump.
8. All activity is released to the environment with no consideration given to radioactive decay or to cloud depletion by ground deposition during transport to the exclusion zone boundary and low population zone.
9. Eight hours after the accident, ~~co.a~~ town is reached and no further steam or activity is released to the environment. This is based upon the design basis calculation of record NC-6026, Revision 1.
10. Reactor coolant density is 8.33 lbs/gal.
11. The source term is based upon a power level of 4100 MW thermal, 5 w/o enrichment, and a 3 region core with equilibrium cycle core at end of life. The three regions have operated at a specific power of 39.3 MW/MTU for 509, 1018, and 1527 EFPD, respectively.
12. The X/Q for the RCB to CR/TSC intake is assumed to apply for MSLB site to the CR/TSC intake.
13. The primary to secondary leakage in the unaffected steam generator is assumed to instantaneous flash to steam.
14. The offsite, CR and TSC doses change linearly as a function of the primary to secondary break flow.
15. The Source Term data for the reactor coolant iodine activity based on 60 micro Ci/g Dose Equivalent Iodine 131 (DEI) and the Secondary Iodine Activity based upon 0.1 micro Ci/g DEI are valid for the burnups assumed in assumption 11.
16. The equilibrium secondary activity before the Steam Generator rupture is based upon a preexisting primary to secondary leakage of 1 gpm. This is conservative since Technical Specification change 182 will limit the preexisting leakage to 150 gpd per Steam Generator or 600 gpd (0.42 gpm) total.

SUBJECT: MAIN STEAM LINE BREAK DOSES FOR ALTERNATE PLUGGING
CRITERIA (UFSAR CHAPTER 15.1.5)
UNIT: 9 (UNITS 1 & 2)

CALC NO: NC-6061

Sheet 9

REV.

PREPARER / DATE

REVIEWER / DATE

0

W. M. Blumberg, 3/95
WMA

S. F. Huang, 3/95
SFH

V. Input

Input #1

Source Data

- A. Reactor coolant iodine activity based on 60 micro Ci/g Dose Equivalent Iodine 131 (DEI).
Taken from Reference 10.

Isotope	Concentration (micro Ci/g)
I-131	45
I-132	53
I-133	71
I-134	11
I-135	40

- B. Secondary Iodine Activity based upon 0.1 micro Ci/g DEI. Taken from Reference 10.

Isotope	Concentration (micro Ci/g)
I-131	7.5e-2
I-132	8.8e-2
I-133	1.2e-1
I-134	1.8e-2
I-135	6.6e-2

SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION
HOUSTON LIGHTING AND POWER COMPANY
GENERAL COMPUTATIONAL SHEET

SUBJECT: MAIN STEAM LINE BREAK DOSES FOR ALTERNATE PLUGGING
CRITERIA (UFSAR CHAPTER 15.1.5)
UNIT: 9 (UNITS 1 & 2)

CALC NO: NC-6061

Sheet 10

REV.

PREPARER / DATE

REVIEWER / DATE

0

W. M. Blumberg, 3/95

S. F. Huang, 3/95

WMA

ZFH

C. Gap activity based on 4100 MW (See assumption 11). Taken from Table 5-10, page 5-20, Reference 4.

Isotope	Gap Activity (Ci)
I-131	1.1e+7
I-132	1.6e+7
I-133	2.3e+7
I-134	2.5e+7
I-135	2.1e+7
Xe-131m	7.7e+4
Xe-133m	3.3e+6
Xe-133	2.3e+7
Xe-135m	4.6e+6
Xe-135	6.5e+6
Xe-137	2.0e+7
Xe-138	1.9e+7
Kr-83m	1.4e+6
Kr-85m	3.0e+6
Kr-85	3.7e+5
Kr-87	5.5e+6
Kr-88	7.9e+6
Kr-89	9.7e+6

SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION
HOUSTON LIGHTING AND POWER COMPANY
GENERAL COMPUTATIONAL SHEET

SUBJECT: MAIN STEAM LINE BREAK DOSES FOR ALTERNATE PLUGGING
CRITERIA (UFSAR CHAPTER 15.1.5)
UNIT: 9 (UNITS 1 & 2)

CALC NO: NC-6061

Sheet 11

REV.

PREPARER / D1™

REVIEWER / DATE

0

W. M. Blumberg, 3/95

WMB

S. F. Huang, 3/95

SFH

D. Reactor coolant activity based on 1% failed fuel. Taken from Table 5-15, page 5-34,
Reference 4.

Isotope	Gap	Activity (micro Ci/g)
I-131		2.4
I-132		2.7
I-133		3.7
I-134		0.55
I-135		2.1
Xe-131m		1.9
Xe-133m		16.0
Xe-133		240.0
Xe-135m		0.45
Xe-135		8.5
Xe-137		0.17
Xe-138		0.59
Kr-83m		0.38
Kr-85m		1.6
Kr-85		7.7
Kr-87		1.0
Kr-88		2.9
Kr-89		0.084

SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION HOUSTON LIGHTING AND POWER COMPANY GENERAL COMPUTATIONAL SHEET		CALC NO: NC-6061	Sheet 12
SUBJECT: MAIN STEAM LINE BREAK DOSES FOR ALTERNATE PLUGGING CRITERIA (UFSAR CHAPTER 15.1.5)		REV.	PREPARED / DATE
UNIT:	9 (UNITS 1 & 2)	0	W. M. Blumberg, 3/95 <i>WMB</i>
			S. F. Huang, 3/95 <i>MF</i>

Input #2

Volume Of Affected and Unaffected Steam Generators and RCS

Unaffected Steam Generators is: 4.14E+5 lbm Ref. 9

Affected Steam Generator is: 1.38E+5 lbm Ref. 9

RCS is: 5.73E+5 lbm Ref. 4, pg. 5-35

Utilizing assumption #10 (8.33 lbm/gal) this converts into:

Unaffected Steam Generators: 4.97E+4 gallons

Affected Steam Generator 1.66E+4 gallons

RCS is: 6.88E+4 gallons

Input #3

Flow Rate Out the Orifices Which Replace the Target Rock Valves

Flow out of orifices which replace the Target Rock Valves

Ref. 11, pg 19

Utilizing assumption #10 the time dependent flow rates out the orifices which replace the Target Rock Valves are calculated on the next page.

For the orifices in the main steam loops with the unaffected and affected Steam Generators:

Time (hours)	Flow Rate Input #1 (lbm/sec loop)	Affected Loop Flow Rate (gpm) ²	Unaffected Loops Flow Rate (total) (gpm) ³
0 to 8 ⁴	1.93	13.9	41.7

² Column 2 times (1gal/ 8.33 lbm x 60 sec/min).

³ Column 3 times 3.

⁴ See assumption 9.

SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION
HOUSTON LIGHTING AND POWER COMPANY
GENERAL COMPUTATIONAL SHEET

SUBJECT: **MAIN STEAM LINE BREAK DOSES FOR ALTERNATE PLUGGING CRITERIA (UFSAR CHAPTER 15.1.5)**
UNIT: **9 (UNITS 1 & 2)**

CALC NO: **NC-6061**

Sheet 13

REV. **1** PREPARER / DATE

W. M. Blumberg, 4/96

WMB

REVIEWER / DATE

M. A. Whitley 4/96

Maw

Input #4

Steam Releases from the Affected and Unaffected Steam Generators

Reference 7

Unaffected Steam Generator

0-2 hours 484,000 lbm or time averaged 4033 lbm/min or utilizing assumption 10: 4.84e+2 gpm
2-8 hours 1,106,000 lbm, or time averaged 3072 lbm/min or utilizing assumption 10: 3.69e+2 gpm

Affected Steam Generator

0-.5 hrs 210,000 lbm or utilizing assumption 10: 2.52e+4 gallons

Input #5

TSC HVAC Flowrates and Filtration and Volume

Reference 17 19, pg M-13

Utilizing 1 ft³ cubic feet (cf) = 7.48 gallons

Filtered Intake Flow 1210 cfm

Unfiltered Flow 16.2 cfm

Exhaust Flow 1226.2 cfm 9.17E+3 gpm

Filtered Recirc. Flow 4750 cfm 3.55E+4 gpm

Intake and Recirc. Filtration

Part/Org/Elemental .990 for all

Volume 48170 cfr.t 3.60e+5 gallons

Input #6

Control Room Volume

Reference 19, page 24

274080 ft³ or 2.050E+6 Gallons

Input #7

LPZ and EAB or EPZ Atmospheric Dispersion Factors (sec/m³)

Reference 2, Table 2.3-25

Time	EAB	LPZ
2	1.3e-4	3.8e-5
8		1.6e-5
16		1.1e-5
72		4.3e-6
624		1.2e-6

SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION HOUSTON LIGHTING AND POWER COMPANY GENERAL COMPUTATIONAL SHEET	CALC NO: NC-6061	Sheet 14
SUBJECT: MAIN STEAM LINE BREAK DOSES FOR ALTERNATE PLUGGING CRITERIA (UFSAR CHAPTER 15.1.5)	REV.	PREPARER / DATE
UNIT: 9 (UNITS 1 & 2)	0	W. M. Blumberg, 3/95 <i>WMB</i>
		S. F. Huang, 3/95 <i>SFH</i>

Input #8

Regulatory Guidance

Reference 5

Radioactive Inventory

91% Elemental

4% Organic

5% Particulate

Breathing Rates Offsite

Time (hr)	BR (m ³ /sec)
0-8	3.47e-4
8-24	1.75e-4
24- thereafter	2.32e-4

Input #9

TSC and Control Room Occupancy Factors

Reference 6, pg 413

Time (hr)	Occupancy Factor
0-24	1.0
24-96	0.60
96-720	0.40

Input #10

Atmospheric Dispersion Factors for the Control Room and TSC (sec/m³)

Containment LOCA leakage to CR/TSC intake

Reference 19, pg 17

Time (hr)	Chi/Q
0-8	1.06e-3
8-24	7.01e-4
24-96	4.44e-4
96-720	1.90e-4

SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION HOUSTON LIGHTING AND POWER COMPANY GENERAL COMPUTATIONAL SHEET	CALC NO: NC-6061	Sheet 15
SUBJECT: MAIN STEAM LINE BREAK DOSES FOR ALTERNATE PLUGGING CRITERIA (UFSAR CHAPTER 15.1.5)	REV.	PREPARER / DATE
UNIT: 9 (UNITS 1 & 2)	1	W. M. Blumberg, 4/96 <i>WMB</i>
		M. A. Whitley 4/96 <i>MAW</i>

VI. Method


Following a main steamline break, auxiliary feedwater to the faulted loop is isolated and the steam generator is allowed to steam dry. Thus, radionuclides carried from the primary coolant to the generator via leaking tubes are assumed to be released directly to the environment. Radionuclides released from the generators in the intact loops via the relief valves are assumed to be mixed with the secondary coolant and partitioned between the generator liquid and steam before release to the environment. Three cases are considered:

- A) A preexisting iodine spike has raised the concentration in the RCS to 60 micro Ci/g DEI 131.
- B) The main steamline break causes an iodine spike which increases the release rate to the RCS to a value 500 times greater than the release rate corresponding to an RCS iodine concentration of 1 micro Ci/g DEI 131.
- C) The break causes 5% fuel cladding failures.

All three cases are considered in Revision 0 of this calculation. From Revision 0, the source term for the fuel failures (Case C) yields the most limiting primary to secondary break flow. For Revision 1 only the Case C configurations will be rerun, but the calculations of the source terms for Cases A and B will be retained in the calculation.

The TRACI code (Reference 12, 13) will be utilized to perform the analysis.

A schematic of the TRACI model used for this analysis is given below. Note the radiation is transported via the node 9 (using an atmospheric dispersion factor) to the offsite dose locations, the control room (node 8) and the TSC (node 4).



SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION HOUSTON LIGHTING AND POWER COMPANY GENERAL COMPUTATIONAL SHEET	CALC NO: NC-6061	Sheet 17
SUBJECT: MAIN STEAM LINE BREAK DOSES FOR ALTERNATE PLUGGING CRITERIA (UFSAR CHAPTER 15.1.5)	REV.	PREPARER / DATE
UNIT: 9 (UNITS 1 & 2)	1	W. M. Blumberg, 4/96 <i>LMO</i>
		M. A. Whitley 4/96 <i>Maw</i>

Utilizing assumption #14 the maximum primary to secondary flow rate can be determined based upon the following equation:

$$Q = (0.9 * D_{\text{limit}} - D_{\text{base}}) / ((D_{\text{base}+10 \text{ gpm}} - D_{\text{base}}) / 10 \text{ gpm}) \quad \text{Equation 1}$$

where:

- Q = The primary to secondary flow rate which corresponds to 90% of the acceptance dose criteria
- D_{limit} = The acceptance criteria dose limit (see **Criteria, Codes and Standards** section)
- D_{base} = The base case dose which corresponds to equilibrium secondary activity (based upon a primary to secondary flow rate of ± 0.42 gpm) and a ~~an-existing~~ primary to secondary flow rate of ± 0.42 gpm (same flow which created the equilibrium secondary activity).
- $D_{\text{base}+10 \text{ gpm}}$ = The base case dose which corresponds to equilibrium secondary activity (based upon a primary to secondary flow rate of ± 0.42 gpm) and a ~~an-existing~~ primary to secondary flow rate of ± 0.42 gpm plus ~~and an additional~~ 10 gpm

Once the maximum Q is calculated the doses for the offsite, TSC and CR are back calculated based upon the following equation:

$$D = (Q/10 * (D_{\text{base}+10 \text{ gpm}} - D_{\text{base}})) + D_{\text{base}} \quad \text{Equation 2}$$

SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION HOUSTON LIGHTING AND POWER COMPANY GENERAL COMPUTATIONAL SHEET		CALC NO: NC-6061	Sheet 18
SUBJECT:	MAIN STEAM LINE BREAK DOSES FOR ALTERNATE PLUGGING CRITERIA (UFSAR CHAPTER 15.1.5)	REV.	PREPARER / DATE
UNIT:	9 (UNITS 1 & 2)	0	W. M. Blumberg, 3/95 <i>VMB</i>
			S. F. Huang, 3/95 <i>SPH</i>

VII. Calculation

Source Term Calculations

Case A Preexisting Iodine Spike

First the total iodine activity in the system is determined.

Isotope	RCS Preexisting Iodine Spike Input 1A	RCS Activity due to Preexisting Iodine Spike Col 2 *	Steam Generator Preexisting Iodine Spike Input 1B	Steam Generator Activity due to Preexisting Iodine Spike Col 4 *2.5e+8 gm (input 2 tot. SG mass)	Total Activity
	(micro Ci/ g)	(Ci)	(micro Ci/g)	(Ci)	(Ci)
I-131	45	1.17e+4	7.5e-2	1.88e+1	1.17e+4
I-132	53	1.38e+4	8.8e-2	2.2e+1	1.38e+4
I-133	71	1.85e+4	1.2e-1	3e+1	1.85e+4
I-134	11	2.86e+3	1.8e-2	4.5	2.86e+3
I-135	40	1.04e+4	6.6e-2	1.65e+1	1.04e+4

$$\text{SG Fraction} = \text{I-131 SG Activity} / \text{I-131 Total Activity} = 1.61\text{e-}3$$

$$\text{RCS Fraction} = 1 - \text{SG Fraction} = 1 - 1.61\text{e-}3 = 9.984\text{e-}1$$

Per Assumption 2

$$\text{Affected SG Fraction} = .35 * 1.61\text{e-}3 = 5.64\text{e-}4$$

$$\text{Unaffected SG Fraction} = .65 * 1.61\text{e-}3 = 1.05\text{e-}3$$

SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION HOUSTON LIGHTING AND POWER COMPANY GENERAL COMPUTATIONAL SHEET		CALC NO: NC-6061	Sheet 19
SUBJECT: MAIN STEAM LINE BREAK DOSES FOR ALTERNATE PLUGGING CRITERIA (UFSAR CHAPTER 15.1.5)		REV.	PREPARER / DATE
UNIT: 9 (UNITS 1 & 2)		0	W. M. Blumberg, 3/95 <i>WMB</i>
			S. F. Huang, 3/95 <i>SFH</i>

Case A Noble Gases

Isotope	Col 1 RCS Con. ntration Input 1D (micro Ci/g)	Col 2 SG Activity (Ci)	Col 3 RCS Activity (Ci)	Col 4 Total Activity (Ci)
Kr-83m	0.38	1.98e-3	9.88e+1	9.88e+1
Kr-85m	1.6	8.33e-3	4.16e+2	4.16e+2
Kr-85	7.7	4.01e-2	2.00e+3	2.00e+3
Kr-87	1.0	5.21e-3	2.6e+2	2.6e+2
Kr-88	2.9	1.51e-2	7.54e+2	7.54e+2
Kr-89	0.084	4.37e-4	2.18e+1	2.18e+1
Xe-131m	1.9	9.89e-3	4.94e+2	4.94e+2
Xe-133m	16.0	8.33e-2	4.16e+3	4.16e+3
Xe-133	240.0	1.25e+0	6.24e+4	6.24e+4
Xe-135m	0.45	2.34e-3	1.17e+2	1.17e+2
Xe-135	8.5	4.42e-2	2.21e+3	2.21e+3
Xe-137	0.17	8.85e-4	4.42e+1	4.42e+1
Xe-138	0.59	3.07e-3	1.53e+2	1.53e+2

To determine the activity in the steam generators, the methodology from Reference 8 is used:

$$\text{SG Concentration} = (\text{Primary Conc} * \text{Appearance Rate}) / \text{Flow Rate}$$

Therefore,

$$\text{Col 2} = \text{Col 1} * 1\text{e-}6 * C * \text{mass of all SG (Input 2)} \text{ where:}$$

$$\text{mass of all SG} = (4.14\text{e+}5 + 1.38\text{e+}5 \text{ lbm}) * 453.6 \text{ gm/lbm} = 2.5\text{e+}8 \text{ gm}$$

From Reference 8:

$$C = \text{Appearance Rate/ Flow Rate}$$

$$\text{Appearance Rate} = 1.592\text{e+}5 \text{ g/hr}$$

SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION HOUSTON LIGHTING AND POWER COMPANY GENERAL COMPUTATIONAL SHEET	CALC NO: NC-6061	Sheet 20
SUBJECT: MAIN STEAM LINE BREAK DOSES FOR ALTERNATE PLUGGING CRITERIA (UFSAR CHAPTER 15.1.5)	REV.	PREPARED / DATE
UNIT: 9 (UNITS 1 & 2)	0	W. M. Blumberg, 3/95 <i>WPB</i>
		S. F. Huang, 3/95 <i>SOH</i>

Flow Rate = 16,858,312 lb/hr x 453.6 g/lbm

$$C = 2.082e-5$$

$$\text{Col 2} = \text{Col 1} * 1e-6 * 2.082e-5 * 2.5e+8 = \text{Col 1} * 5.205e-3$$

$$\text{Col 3} = \text{Col 1} * 1e-6 * \text{mass of RCS (Input 2)}$$

$$\text{Col 3} = \text{Col 1} * 5.73e+5 \text{ lbm} * 453.6 \text{ gm/lbm} = \text{Col 1} * 2.6e+2$$

$$\text{Col 4} = \text{Col 2} + \text{Col 3}$$

$$\text{SG Fraction} = \text{Col 2}/\text{Col 4}$$

$$\text{For all noble gases } \text{Col 2}/\text{Col 4} = 2.0e-5$$

$$\text{RCS Fraction} = 1-2.0e-5 = \text{approximately 1.0}$$

Per Assumption 2

$$\text{Affected SG Fraction} = .35 * 2.0 e-5 = 7.0e-6$$

$$\text{Unaffected SG Fraction} = .65 * 2.0e-5 = 1.3e-5$$

Case B) Coexisting Iodine Spike

First, the iodine activity in the system is determined. From assumption #3, the release rate to the RCS is increased to a valve 500 times greater than the release rate corresponding to an RCS concentration of 1 uCi/g dose equivalent I-131.

The release rate corresponding to an RCS concentration of 1 uci/g dose equivalent I-131 can be found from Reference 4.

From Reference 4,

$$\text{Iodine Appearance Rate} = (\text{Core Inventory}) * \text{FFF} * \text{ER}$$

FFF = Failed Fuel Fraction

ER = Escape Rate Coefficient

From Reference 4, page 5-5, ER = $1.3 \times 10^{-8} \text{ sec}^{-1}$ for iodines.

Also from Reference 4, page 5-27, 1% FF is equal to 3.7 uci/g DE I-131.

$$\text{For 1 uci/g DE I-131, FFF} = 1\%/3.7 = .01/3.7 = 0.00270$$

$$\begin{aligned} \text{Thus, Iodine Appearance Rate} &= (\text{Core Inventory}) * (.00270) (1.3 \times 10^{-8} \text{ sec}^{-1}) \\ &= (\text{Core Inventory}) * 3.51 \times 10^{-11} \text{ sec}^{-1} \end{aligned}$$

SUBJECT: MAIN STEAM LINE BREAK DOSES FOR ALTERNATE PLUGGING CRITERIA (UFSAR CHAPTER 15.1.5)
 UNIT: 9 (UNITS 1 & 2)

CALC NO: NC-6061

Sheet 21

REV.

PREPARER / DATE

REVIEWER / DATE

0

W. M. Blumberg, 3/95
(WMB)

S. F. Huang, 3/95
SHH

Case B) Coexisting Iodine Spike

Isotope	Column 1 Core Inventory, Ci	Column 2 0-8 Hour Release to RCS, Ci
I-131	1.1 E8	5.56 E4
I-132	1.6 E8	8.08 E4
I-133	2.3 E8	1.16 E5
I-134	2.5 E8	1.26 E5
I-135	2.1 E8	1.06 E5

Column 1 = Input 1 C/.1 where .1 is the gap activity release fraction

Column 2 = Iodine App. Rate x 500 x 8 hrs x 3600 sec/hr =

Column 1 x 5.05 E-4

Then assuming 1% failed fuel prior to the spike, by assumption #3, the 0-8 hour release above is added to the initial RCS activity.

Isotope	Column 1 RCS (1% FF) Concentration uCi/g Input 1D	Column 2 RCS 1% FF Activity Ci	Column 3 RCS Spike Activity Ci	Column 4 SG 1% FF Activity Ci, Ref. 8	Total Activity, Ci
I-131	2.4	6.24 E2	5.56 E4	.95	5.62 E4
I-132	2.7	7.02 E2	8.08 E4	.64	8.15 E4
I-133	3.7	9.62 E2	1.16 E5	1.4	1.17 E5
I-134	.55	1.43 E2	1.26 E5	4.1 E-3	1.26 E5
I-135	2.1	5.46 E2	1.06 E5	.66	1.07 E5

Column 2 = Column 1 * RCS Vol x 1.0 E-6 Ci/micro Ci = Column 1 * 2.6E2, Column 3 from Column 2 in the table above.

Total Activity = Column 2 + Column 3 + Column 4

SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION HOUSTON LIGHTING AND POWER COMPANY GENERAL COMPUTATIONAL SHEET	CALL NO NC-6061	Sheet 22
SUBJECT: MAIN STEAM LINE BREAK DOSES FOR ALTERNATE PLUGGING CRITERIA (UFSAR CHAPTER 15.1.5)	REV.	PREPARER / DATE
UNIT: 9 (UNITS 1 & 2)	0	W. M. Blumberg, 3/95 <i>WMB</i>
		S. F. Huang, 3/95 <i>SFH</i>

The SG Fraction = .95/5.62 E4 = 1.69 E-5

RCS Fraction = 1 - 1.69 E-5 = 9.9998 E-1 = approximately 1.0

Affected SG Fraction = .35 (1.69 E-5) = 5.92 E-6

Unaffected SG Fraction = .65 (1.69 E-5) = 1.10 E-5

Case C) 5% Failed Fuel Cladding

From Assumption #4, the RCS concentration is based on 5% failed fuel. The initial steam generator activity is based on 1% failed fuel.

Iodines:

Isotope	Column 1 GAP Activity Ci	Column 2 5% RCS GAP Activity Ci	Column 3 SG Activity Ci Ref. 8	Total Activity, Ci Col. 2+Col. 3	SG/Total
I-131	1.1 E7	5.5 E5	.95	5.5 E5	1.73 E-6
I-132	1.6 E7	8 E5	.64	8 E5	8.00 E-7
I-133	2.3 E7	1.15 E6	1.4	1.15 E6	1.22 E-6
I-134	2.5 E7	1.25 E6	4.1 E-3	1.25 E6	3.28 E-9
I-135	2.1 E7	1.05 E6	.66	1.05 E6	6 E-7

Column 1 = Input 1C

Column 2 = Column 1 * .05

SG Fraction = 1.73 E-6

RCS Fraction = 1 - 1.73 E-6 = approximately 1.0

Affected SG Fraction = .35 (1.73 E-6) = 6.06 E-7

Unaffected SG Fraction = .65 (1.73 E-6) = 1.12 E-6

SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION HOUSTON LIGHTING AND POWER COMPANY GENERAL COMPUTATIONAL SHEET	CALC NO: NC-6061	Sheet 23
SUBJECT: MAIN STEAM LINE BREAK DOSES FOR ALTERNATE PLUGGING CRITERIA (UFSAR CHAPTER 15.1.5)	REV.	PREPARED / DATE
UNIT: 9 (UNITS 1 & 2)	0	W. M. Blumberg, 3/95 <i>WMB</i>
		S. F. Huang, 3/95 <i>SHH</i>

For the Noble Gases,

Isotope	Column 1 Gap Activity Input 1C Ci	Column 2 RCS 5% Gap Activity Ci	Column 3 SG Activity Ci	Column 4 Total Activity Ci	Column 5 SG/Total
KR-83M	1.40E + 06	7.00E + 04	1.98E-03	7.00E + 04	2.83E-08
KR-85M	3.00E + 06	1.50E + 05	8.33E-03	1.50E + 05	5.55E-08
KR-85	3.70E + 05	1.85E + 04	4.01E-02	1.85E + 04	2.17E-06
KR-87	5.50E + 06	2.75E + 05	5.21E-03	2.75E + 05	1.89E-08
KR-88	7.90E + 06	3.95E + 05	1.51E-02	3.95E + 05	3.82E-08
KR-89	9.70E + 06	4.85E + 05	4.37E-04	4.85E + 05	9.01E-10
XE-131M	7.70E + 04	3.85E + 03	9.89E-03	3.85E + 03	2.57E-06
XE-133M	3.30E + 06	1.65E + 05	8.33E-02	1.65E + 05	5.05E-07
XE-133	2.30E + 07	1.15E + 06	1.25E+00	1.15E + 06	1.09E-06
XE-135M	4.60E + 06	2.30E + 05	2.34E-03	2.30E + 05	1.02E-08
XE-135	6.50E + 06	3.25E + 05	4.42E-02	3.25E + 05	1.36E-07
XE-137	2.00E + 07	1.00E + 06	8.85E-04	1.00E + 06	8.85E-10
XE-138	1.90E + 07	9.50E + 05	3.07E-03	9.50E + 05	3.23E-09

Column 2 = Column 1 x .05

Column 3 = Case A Steam Generator Noble Gas Activity.

Column 4 = Column 2 + Column 3

Column 5 = Column 3 ÷ Column 4

SG Fraction = 2.57e-6

RCS Fraction = 1 - 2.57e-6 = approx 1.0

SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION
HOUSTON LIGHTING AND POWER COMPANY
GENERAL COMPUTATIONAL SHEET

SUBJECT: **MAIN STEAM LINE BREAK DOSES FOR ALTERNATE PLUGGING
CRITERIA (UFSAR CHAPTER 15.1.5)**

UNIT: **9 (UNITS 1 & 2)**

CALC NO: **NC-6061**

Sheet 24

REV.	PREPARER / DATE	REVIEWER / DATE
0	W. M. Blumberg, 3/95 <i>WMB</i>	S. F. Huang, 3/95 <i>SPH</i>

$$\text{Affected SG} = .35 * 2.57\text{e-}6 = 9.00\text{e-}7$$

$$\text{Unaffected SG} = .65 * 2.57\text{e-}6 = 1.67\text{e-}6$$

SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION HOUSTON LIGHTING AND POWER COMPANY GENERAL COMPUTATIONAL SHEET	CALC NO: NC-6061	Sheet 25
SUBJECT: MAIN STEAM LINE BREAK DOSES FOR ALTERNATE PLUGGING CRITERIA (UFSAR CHAPTER 15.1.5)	REV.	PREPARED / DATE
UNIT: 9 (UNITS 1 & 2)	0	W. M. Blumberg, 3/95 <i>W.M.B.</i>
		S. F. Huang, 3/95 <i>S.F.H.</i>

The following information summarizes the source terms in the form of TRACI input.

Case A Preexisting Iodine Spike

Iodines Only

fract_activity_node = 0.9984, 5.64e-4, 1.05e-3

activity1 = 3*1.17e+4, 3*1.38e+4, 3*1.85e+4, 3*2.86e+3, 3*1.04e+4

Noble Gases Only

fract_activity_node = 1.0, 7.0e-6, 1.3e-5

activity1 = 9.88e+1, 4.16e+2, 2.00e+3, 2.60e+2, 7.54e+2,
2.18e+1, 4.94e+2, 4.16e+3, 6.24e+4, 1.17e+2,
2.21e+3, 4.42e+1, 1.53e+2

Case B Coexisting Iodine Spike

Iodines Only

fract_activity_node = 1.0, 5.92e-6, 1.10e-5

activity1 = 3*5.62e+4, 3*8.15e+4, 3*1.17e+5, 3*1.26e+5, 3*1.07e+5

Noble Gases Only(Note these are the same as case A)

fract_activity_node = 1.0, 7.0e-6, 1.3e-5

activity1 = 9.88e+1, 4.16e+2, 2.00e+3, 2.60e+2, 7.54e+2,
2.18e+1, 4.94e+2, 4.16e+3, 6.24e+4, 1.17e+2,
2.21e+3, 4.42e+1, 1.53e+2

Case C 5% Fuel Failure

Iodines Only

fract_activity_node = 1.0, 6.06e-7, 1.12e-6

activity1 = 3*5.5e+5, 3*8.0e+5, 3*1.15e+6, 3*1.25e+6, 3*1.05e+6

Noble Gases Only

fract_activity_node = 1.0, 9.00e-7, 1.67e-6

activity1 = 7.00e+4, 1.50e+5, 1.85e+4, 2.75e+5, 3.95e+5,
4.85e+5, 3.85e+3, 1.65e+5, 1.15e+6, 2.30e+5,
3.25e+5, 1.00e+6, 9.50e+5

SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION HOUSTON LIGHTING AND POWER COMPANY GENERAL COMPUTATIONAL SHEET	CALC NO: NC-6061	Sheet 26
SUBJECT: MAIN STEAM LINE BREAK DOSES FOR ALTERNATE PLUGGING CRITERIA (UFSAR CHAPTER 15.1.5)	REV.	PREPARED / DATE
UNIT: 9 (UNITS 1 & 2)	1	W. M. Blumberg, 4/96 <i>WMB</i>
		M. A. Whitley 4/96

Partition Factor

The partition factor (assumption 5) will be modelled in TRACI as a filter removal efficiency between the reactor coolant and the steam generators in the unaffected loops. The filter removal efficiency will be equal to 1 minus the partition factor ($1 - .01 = .99$). This will be input into TRACI using input variable filt_flow_remove.

Steam Releases

The steam releases from the affected generator due to the primary to secondary leakage are assumed to flash to steam (Assumption 13). Therefore, from 0-8 hours (see assumption 9) the steam releases due to the primary and secondary leakage are:

- | For the base case (ie. ± 0.42 gpm total leakage, ± 0.35 0.147 gpm to the affected SG)
 $.035 \times 0.147 \text{ gpm} \times 8 \text{ hrs} \times 60 \text{ min/hr} = 16.8 \text{ 70.6 gallons}$
- | For the base case plus ± 10 gpm (ie. ± 10.42 gpm total leakage, ± 0.035 10.147 gpm to the affected SG)
 $\pm 0.035 \times 10.147 \text{ gpm} \times 8 \text{ hrs} \times 60 \text{ min/hr} = 4817 \text{ 4870 gallons}$

These values must be added to the steam released from 0-30 minutes due to the SG boiling dry.

For the base case

$$\begin{aligned}
 0.5 \text{ hrs} &= \text{steam released from 0-30 min (input 4)} + \text{steam from primary to sec. leakage} \\
 &= 2.52e+4 \text{ gal} + .5/8 (16.8 70.6 \text{ gal}) = 2.52e+4 \text{ gal or time averaged } 8.40e+2 \text{ gpm} \\
 .5-8 \text{ hrs} &= \text{steam from primary to secondary leakage} \\
 &= 7.5/8 (16.8 70.6) = 15.75 66.2 \text{ gal or time averaged } 3.50e-2 1.47e-1 \text{ gpm}
 \end{aligned}$$

For the base case + 10 gpm

$$\begin{aligned}
 0.5 \text{ hrs} &= \text{steam released from 0-30 min (input 4)} + \text{steam from primary to secondary leakage} \\
 &= 2.52e+4 \text{ gal} + .5/8 (4817 4870.6 \text{ gal}) = 2.55e+4 \text{ gal or time averaged } 8.50e+2 \text{ gpm} \\
 .5-8 \text{ hrs} &= \text{steam from primary to secondary leakage} \\
 &= 7.5/8 (4817 4870.6) = 4.516e+3 4.566e+3 \text{ gal or time averaged } 10.0 1.01e+1 \text{ gpm}
 \end{aligned}$$

SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION HOUSTON LIGHTING AND POWER COMPANY GENERAL COMPUTATIONAL SHEET	CALC NO: NC-6061	Sheet 27
SUBJECT: MAIN STEAM LINE BREAK DOSES FOR ALTERNATE PLUGGING CRITERIA (UFSAR CHAPTER 15.1.5)	REV.	PREPARER / DATE
UNIT: 8 (UNITS 1 & 2)	1	W. M. Blumberg, 4/96 <i>WMB</i>
		M. A. Whitley 4/96 <i>Maw</i>

Control Room Model and TSC Model

The control room (CR) model and TSC models are taken from the Reference 19 models (flow rates). The X/Qs for the RCB to CR/TSC intake (Input 10) is assumed to apply for MSLB site to the CR/TSC intake (Assumption 12).

Per Revision 0 the worst control room HVAC thyroid configuration is 1A. Below are the filter efficiencies taken from Reference 17 for configuration 1A. Note 1A is conservative since it considers two single failures (loss of a train, ie. Standby Diesel Generator, and loss of a intake heater with no operator action to secure the failed heater train). Configuration 7 was used to calculate the worst case whole body and beta doses since it maximizes the control room intake flow (3300 cfm vs. the 1A flowrate of 2200 cfm). It is used for the cases with noble gas source terms.

The filter efficiencies for the CR-HVAC are taken from Reference 17, page 21. Page 7 of Reference 17 gives a table of the thyroid, whole body and beta skin doses for various CR single failure assumptions. The Cases used to determine the limiting doses are those which alter only the CR single failure criteria and not the FHB single failure criteria (See the Execution Matrix in Reference 17, page 5). Cases 3,4, 6, 7, 8, and 9 were considered (case 2 was not considered since it was rerun with a more realistic assumption (see case 8). Case 8 yields the largest thyroid dose, while cases 5-7 yield the highest whole body doses and beta doses. Therefore, CR-HVAC Configurations 1A and 4, 6 and 7 were considered (see Reference 17, page 21). Since CR-HVAC Configurations 4, 6, and 7 all yielded the same beta and whole body doses, only one of these will be considered. Since configuration 7 has the least iodine removal capability, it will be used. Therefore, for the CR-HVAC two configurations will be considered, 1A and 7. The Table below summarizes these configuration:

CRE HVAC Filter Efficiency Summary

Train	Config.	Single Failure	HVAC		Intake		Recirculation	
			Elemental	Organic	Elemental	Organic	Elemental	Organic
3	7	Intake heater	99.	98.17	93.33	73.33		
2	1A	Intake heater	98.86	94.32	95.	95.		

SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION HOUSTON LIGHTING AND POWER COMPANY GENERAL COMPUTATIONAL SHEET	CALC NO: NC-6061	Sheet 28
SUBJECT: MAIN STEAM LINE BREAK DOSES FOR ALTERNATE PLUGGING CRITERIA (UFSAR CHAPTER 15.1.5)	REV.	PREPARED / DATE
UNIT: 9 (UNITS 1 & 2)	0	W. M. Blumberg, 3/95 <i>WMB</i>
		S. F. Huang 3/95 <i>SFH</i>

Configuration 7

<u>TRACI Variable</u>	<u>Description</u>	<u>Value</u>
filt_cr	Filtered intake flow for the CR in CFM	3300
unfilt_cr	Unfiltered intake flow for the CR in CFM	10
filt_remove_cr	Intake filter efficiencies	0.9900, 0.9817, 0.990, 8*0.0
filt_recirc_cr	Recirc filter efficiencies	0.9333, 0.7333, 0.99, 8*0.0
exhaust_cr	Control room HVAC exhaust rate in CFM	3310
recirc_cr	Control room recirc flow in CFM	14250

Configuration 1A

<u>TRACI Variable</u>	<u>Description</u>	<u>Value</u>
filt_cr	Filtered intake flow for the CR in CFM	2200
unfilt_cr	Unfiltered intake flow for the CR in CFM	10
filt_remove_cr	Intake filter efficiencies	0.9886, 0.9432, 0.99, 8*0.0
filt_recirc_cr	Recirc filter efficiencies	2*0.950, 0.99, 8*0.0
exhaust_cr	Control room HVAC exhaust rate in CFM	2210
recirc_cr	Control room recirc flow in CFM	9500

SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION HOUSTON LIGHTING AND POWER COMPANY GENERAL COMPUTATIONAL SHEET	CALC NO: NC-6061	Sheet 23
SUBJECT: MAIN STEAM LINE BREAK DOSES FOR ALTERNATE PLUGGING CRITERIA (UFSAR CHAPTER 15.1.5)	REV.	PREPARER / DATE
UNIT: 9 (UNITS 1 & 2)	0	W. M. Blumberg, 3/95 <i>WNB</i>
		S. F. Huang, 3/95 <i>SFH</i>

Converted to Units of Gallons

Configuration 7

<u>TRACI Variable</u>	<u>Description</u>	<u>Value</u>
filt_cr	Filtered intake flow for the CR in gpm	24,684
unfilt_cr	Unfiltered intake flow for the CR in gpm	74.8
filt_remove_cr	Intake filter efficiencies	0.9900, 0.9817, 0.99,8*0.0
filt_recirc_cr	Recirc filter efficiencies	0.9333, 0.7333, 0.99, 8*0.0
exhaust_cr	Control room HVAC exhaust rate in gpm	24,758.8
recirc_cr	Control room recirc flow in gpm	1.066E+5

Configuration 1A

<u>TRACI Variable</u>	<u>Description</u>	<u>Value</u>
filt_cr	Filtered intake flow for the CR in gpm	16,456
unfilt_cr	Unfiltered intake flow for the CR in gpm	74.8
filt_remove_cr	Intake filter efficiencies	0.9886, 0.9432, 0.99, 8*0.0
filt_recirc_cr	Recirc filter efficiencies	2*0.950, 0.99, 8*0.0
exhaust_cr	Control room HVAC exhaust rate in gpm	16530.8
recirc_cr	Control room recirc flow in gpm	71,060

And from Input #6

The Control Room Volume is 2.050E+6 Gallons

SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION HOUSTON LIGHTING AND POWER COMPANY GENERAL COMPUTATIONAL SHEET	CALC NO: NC-6061	Sheet 30
SUBJECT: MAIN STEAM LINE BREAK DOSES FOR ALTERNATE PLUGGING CRITERIA (UFSAR CHAPTER 15.1.5)	REY	PREPARER / DATE
UNIT: 9 (UNITS 1 & 2)	0	W. M. Blumberg, 3/95 <i>WMB</i>
		S. F. Huang, 3/95 <i>SFH</i>

TSC model

The TRACI code models up to 8 nodes (rooms or groups of rooms) and can transport radioactivity to 2 offsite locations and 1 control room location utilizing a X/Q factor. In order to decrease the number of TRACI runs a TSC model will utilize node 4 which is an inner node (the control room will be modelled in node 8 as shown above). Since the TSC model requires radioactivity to be transported (utilizing a X/Q factor) to an inner node, a calculation to simulate this was performed. This calculation determines "effective" flow rates to the TSC from the affected and unaffected steam generators. This effective flow incorporates the transport of radioactivity due to the leakage from the generators, the X/Q from the steam generators to the TSC intake, and the TSC intake flows. The equation utilized to calculate the effective flow is given below:

$$Q_{eff} = Q_{leak} * X/Q * Q_{intake} \text{ where:}$$

Q_{eff} = The effective flow from the SGs to the TSC

Q_{leak} = The leakage from SGs to the environment

X/Q = The atmospheric dispersion factor from the containment to the TSC intake

Q_{intake} = The intake flow from the TSC intake into the TSC

This methodology was successfully utilized in Reference 18, page 33 and 34.

The time dependent Q_{eff} are developed below and put into matrices in the form of TRACI input.

	A	B	C	D	E	F	G	H	I	J	K	L	M
46													
47													
48													
49				Steam Released		TSC Intake Flow		TSC Intake Flow		Effective	Effective	Total Steam	
50										Flow	Flow		
51	Chi/Q	Chi/Q	SG	TR Valve	filtered	unfiltered	filtered	unfiltered	filtered	unfiltered	unfiltered		
52	R18, pg 34		Input 4	Input 3	R19, pg M9	R19, pg M9				Col D*M*I	Col D*M*J	Col E+ F	
53	Time (hrs)	(sec/m3)	(min/gal)	gpm	gpm	cfm	cfm	gpm	gpm	gpm	gpm	gpm	
54	0-2	1.06E-03	6.69E-08	4.84E+02	41.7	1210	16.2	9050.8	121.176	3.18E-01	4.26E-03	5.26E+02	
55	2-8	1.06E-03	6.69E-08	3.69E+02	41.7	1210	16.2	9050.8	121.176	2.49E-01	3.33E-03	4.11E+02	
56													
57													
58		Base Case Affected Loop	Node 2										
59				Transport of Steam to the TSC HVAC Intake									
60													
61				Steam Released		TSC Intake Flow		TSC Intake Flow		Effective	Effective	Total Steam	
62										Flow	Flow		
63	Chi/Q	Chi/Q	SG	TR Valve	filtered	unfiltered	filtered	unfiltered	filtered	unfiltered	unfiltered		
64	R18, pg 34		see footnote 1	Input 3	R19, pg M9	R19, pg M9				Col D*M*I	Col D*M*J	Col E+ F	
65	Time (hrs)	(sec/m3)	(min/gal)	gpm	gpm	cfm	cfm	gpm	gpm	gpm	gpm	gpm	
66	0-0.5	1.06E-03	6.69E-08	8.40E+02	13.9	1210	16.2	9050.8	121.176	5.17E-01	6.92E-03	8.54E+02	
67	.5-8	1.06E-03	6.69E-08	1.47E-01	13.9	1210	16.2	9050.8	121.176	8.48E-03	1.13E-04	1.40E+01	
68		footnote 1 - values taken from calc section entitled "Steam Releases"											
69													
70		Base Case + 10 gpm Affected Loop Node 2											
71				Transport of Steam to the TSC HVAC Intake									
72													
73				Steam Released		TSC Intake Flow		TSC Intake Flow		Effective	Effective	Total Steam	
74				see footnote 1						Flow	Flow		
75	Chi/Q	Chi/Q	SG	TR Valve	filtered	unfiltered	filtered	unfiltered	filtered	unfiltered	unfiltered		
76	R18, pg 34			Input 3	R19, pg M9	R19, pg M9				Col D*M*I	Col D*M*J	Col E+ F	
77	Time (hrs)	(sec/m3)	(min/gal)	gpm	gpm	cfm	cfm	gpm	gpm	gpm	gpm	gpm	
78	0-.5	1.06E-03	6.69E-08	8.50E+02	13.9	1210	16.2	9050.8	121.176	5.23E-01	7.00E-03	8.64E+02	
79	.5-8	1.06E-03	6.69E-08	1.01E+01	13.9	1210	16.2	9050.8	121.176	1.45E-02	1.95E-04	2.40E+01	

NC-6061, REVISION 1

MSLB DOSES FOR ALT. PLUGGING

PREPARER:
W. M. BLUMBERG 4/96REVIEWER:
M. A. WHITLEY 4/96
*new**Pg 32* *for 21*

	A	B	C	D	E	F	G	H	I	J	K	L	M
80													
81		Base Case											
82		Unfiltered Flow 0-.5 hrs.											
83													
84	To/ From	1	2	3	4	5	6	7	8				
85	1	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
86	2	1.47E-01	0.00E+00										
87	3	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
88	4	0.00E+00	6.92E-03	4.26E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
89	5	0.00E+00	0.00E+00	0.00E+00	9.17E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
90	6	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
91	7	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
92	8	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
93	9	0.00E+00	8.54E+02	5.26E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
94													
95													
96	Base Case												
97	Filtered Flow 0-.5 hours												
98													
99	To/ From	1	2	3	4	5	6	7	8				
100	1	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
101	2	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
102	3	2.73E-01	0.00E+00										
103	4	0.00E+00	5.17E-01	3.18E-01	3.55E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
104	5	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
105	6	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
106	7	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
107	8	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
108	9	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
109													
110													
111													
112													

NC-6061, REVISION 1

MSLB DOSES FOR ALT. PLUGGING

WHO PREFERER:
W. M. BLUMBERG 4/96REVIEWER:
M. A. WHITLEY 4/96
-maw

	A	B	C	D	E	F	G	H	I	J	K	L	M
113													
114	Base Case				Flow Rates Between Nodes								
115	Unfiltered Flow 0.5 - 2 hrs.												
116													
117	To/ From	1	2	3	4	5	6	7	8				
118	1	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
119	2	1.47E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
120	3	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
121	4	0.00E+00	1.13E-04	4.26E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
122	5	0.00E+00	0.00E+00	0.00E+00	9.17E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
123	6	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
124	7	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
125	8	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
126	9	0.00E+00	1.40E+01	5.26E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
127													
128													
129	Base Case												
130	Filtered Flow 0.5-2 hrs.												
131													
132	To/ From	1	2	3	4	5	6	7	8				
133	1	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
134	2	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
135	3	2.73E-01	0.00E+00	6.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
136	4	0.00E+00	8.48E-03	3.18E-01	3.55E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
137	5	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
138	6	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
139	7	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
140	8	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
141	9	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
142													
143													
144													
145													

NC-6061, REVISION 1
MSLB DOSES FOR ALT. PLUGGING

PREPARER:
W. M. BLUMBERG 4/96
P934-1 33
WMA

REVIEWER:
M. A. WHITLEY 4/96
maw

	A	B	C	D	E	F	G	H	I	J	K	L	M
146													
147													
148													
149	Base Case												
150	Unfiltered Flow 2-8 hrs.												
151													
152	To/ From	1	2	3	4	5	6	7	8				
153	1	0.00E+00											
154	2	1.47E-01	0.00E+00										
155	3	0.00E+00											
156	4	0.00E+00	1.13E-04	3.33E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
157	5	0.00E+00	0.00E+00	0.00E+00	9.17E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
158	6	0.00E+00											
159	7	0.00E+00											
160	8	0.00E+00											
161	9	0.00E+00	1.40E+01	4.11E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
162													
163													
164	Base Case												
165	Filtered Flow 2-8 hours												
166													
167	To/ From	1	2	3	4	5	6	7	8				
168	1	0.00E+00											
169	2	0.00E+00	0.30E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
170	3	2.73E-01	0.00E+00										
171	4	0.50E+00	8.48E-03	1.49E-01	3.55E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
172	5	0.00E+00											
173	6	0.00E+00											
174	7	0.00E+00											
175	8	0.00E+00											
176	9	0.00E+00											
177													
178													
179													

NC-6061, REVISION 1
MSLB DOSES FOR ALT. PLUGGING

PREPARER:
W. M. BLUMBERG 4/96

REVIEWER:
M. A. WHITLEY 4/96
new

	A	B	C	D	E	F	G	H	I	J	K	L	M
180													
181													
182													
183	To/ From	1	2	3	4	5	6	7	8				
184	1	0.00E+00											
185	2	1.01E+01	0.00E+00										
186	3	0.00E+00											
187	4	0.00E+00	7.00E-03	4.26E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
188	5	0.00E+00	0.00E+00	0.00E+00	9.17E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
189	6	0.00E+00											
190	7	0.00E+00											
191	8	0.00E+00											
192	9	0.00E+00	8.64E+02	5.26E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
193													
194													
195													
196													
197													
198	To/ From	1	2	3	4	5	6	7	8				
199	1	0.00E+00											
200	2	0.00E+00											
201	3	2.73E-01	0.00E+00										
202	4	0.00E+00	5.23E-01	3.18E-01	3.55E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
203	5	0.00E+00											
204	6	0.00E+00											
205	7	0.00E+00											
206	8	0.00E+00											
207	9	0.00E+00											
208													
209													
210													

NC-6061, REVISION 1

MSLB DOSES FOR ALT. PLUGGING

wmb PREPARER:
W. M. BLUMBERG 4/96

35

REVIEWER:
M. A. WHITLEY 4/96
New

	A	B	C	D	E	F	G	H	I	J	K	L	M
211													
212													
213	Base Case + 10 gpm												
214	Unfiltered Flow 0.5 - 2 hrs.												
215													
216	To/ From	1	2	3	4	5	6	7	8				
217	1	0.00E+00											
218	2	1.01E+01	0.00E+00										
219	3	0.00E+00											
220	4	0.00E+00	1.95E-04	4.26E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
221	5	0.00E+00	0.00E+00	0.00E+00	9.17E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
222	6	0.00E+00											
223	7	0.00E+00											
224	8	0.00E+00											
225	9	0.00E+00	2.40E+01	5.26E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
226													
227													
228	Base Case + 10 gpm												
229	Filtered Flow 0.5-2 hrs.												
230													
231	To/ From	1	2	3	4	5	6	7	8				
232	1	0.00E+00											
233	2	0.00E+00											
234	3	2.73E-01	0.00E+00										
235	4	0.00E+00	1.45E-02	3.18E-01	3.55E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00				
236	5	0.00E+00											
237	6	0.00E+00											
238	7	0.00E+00											
239	8	0.00E+00											
240	9	0.00E+00											
241													
242													
243													
244													

NC-6061, REVISION 1

MSLB DOSES FOR ALT. PLUGGING

PREPARER:
W. M. BLUMBERG 4/96REVIEWER:
M. A. WHITLEY 4/96

NC-6061, REVISION 1
MSLB DOSES FOR ALT. PLUGGING

WMB PREPARER:
W. M. BLUMBERG 4/96

REVIEWER:
M. A. WHITLEY 4/96

SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION HOUSTON LIGHTING AND POWER COMPANY GENERAL COMPUTATIONAL SHEET	CALC NO: NC-6061	Sheet 38
SUBJECT: MAIN STEAM LINE BREAK DOSES FOR ALTERNATE PLUGGING CRITERIA (UFSAR CHAPTER 15.1.5)	REV. P. PREPARER / DATE	REV. EWER / DATE
UNIT: 9 (UNITS 1 & 2)	1 W. M. Blumberg, 4/96 <i>WMB</i>	M. A. Whitley 4/96 <i>Maw</i>

The Table below was developed to describe the TRACI models developed for this calculation. As previously discussed three source terms are analyses, 2 HVAC configurations, and two primary to secondary flow models (The base case and the base case + 10 gpm). In addition In the table the flow models are separated into iodines and noble gases. This was done due to the limitations of the TRACI code. The code specifies the sources terms in each node based upon a single node dependent multiplier. Since the relative fractions of isotopes in each node is not a single value for these models, the isotopes are split up into iodines and noble gases. The values below in the table give the designations for each Cases and the appendix for the case input and output.

SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION HOUSTON LIGHTING AND POWER COMPANY GENERAL COMPUTATIONAL SHEET		CALC NO: NC-6061	Sheet 39
OBJECT: MAIN STEAM LINE BREAK DOSES FOR ALTERNATE PLUGGING CRITERIA (UFSAR CHAPTER 15.1.5)		REV.	PREPARER / DATE
UNIT:	9 (UNITS 1 & 2)	1	W. M. Blumberg, 4/96 <i>VMG</i>
			M. A. Whitley 4/96 <i>MAW</i>

Case designator and Appendix number for the TRACI input and output

		Scenario:	C 5% Failed Fuel, No Iodine Spike	C 5% Failed Fuel, No Iodine Spike
		CR HVAC Configuration:	IA	7
D	Base Case	Iodines	C1	
O	Secondary side equilibrium + .42 gpm		K	
S				
E				
C	primary to secondary leakage	Noble Gases		C4
O				N
N				
T				
R	Base Case + 10 gpm	Iodines	C2	
I	Secondary side equilibrium (due to .42 gpm leakage) + 10.42 gpm		L	
B				
U				
T				
I				
O				
N				
		Noble Gases		C6
				P

The TRACI models described in the above table are given in the Appendices. Cases A1 C1 and A2 C2 are representative of all the cases run with the exception of the source terms and CR-HVAC configurations. The references for the input for cases A1 C1 and A2 C2 are given in appendices K and L, respectively. The different source terms and CR-HVAC configurations are given for other cases in the sections calculation section on pages 25 and 29. The source terms for Cases C4 and C6 are given on page 25.

SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION HOUSTON LIGHTING AND POWER COMPANY GENERAL COMPUTATIONAL SHEET	CALC NO: NC-6061	Sheet 40
SUBJECT: MAIN STEAM LINE BREAK DOSES FOR ALTERNATE PLUGGING CRITERIA (UFSAR CHAPTER 15.1.5)	REV.	PREPARED / DATE
UNIT: 9 (UNITS 1 & 2)	1	W. M. Blumberg, 4/96 <i>W.M.B.</i>
		M. A. Whitley 4/96 <i>M.A.W.</i>

The following pages present the results of the TRACI models, calculate the limiting primary to secondary flow rate to obtain 90% of the acceptance criteria doses, and use this value to calculate the resulting doses for the TSC, CR and offsite locations. Below is a description of each spreadsheet and how it was generated.

TRACI results

The TRACI results for each case are taken directly from the appendices.

Offsite, TSC and Control Room Doses - Base Case

This spreadsheet determines the maximum thyroid, whole body and beta skin doses for the three two scenarios. These doses are based upon a secondary side equilibrium activity from ± 0.42 gpm primary to secondary flow. In addition there is an active primary to secondary flow of ± 0.42 gpm. These dose values are denoted as D_{base} in Equations 1 and 2.

Offsite, TSC and Control Room Doses - Base Case + 10 gpm

This spreadsheet determines the maximum thyroid, whole body and beta skin doses for the three two scenarios. These doses are based upon a secondary side equilibrium activity from ± 10.42 gpm primary to secondary flow. In addition there is an active primary to secondary flow of ± 10.42 gpm. These dose values are denoted as $D_{base+10\text{ gpm}}$ in Equations 1 and 2.

Maximum Post- MSLB SG Tube Leakage

This spreadsheet utilizes the NRC "limits" (denoted as D_{limit} in equation 1) and Equation 1 to determine the maximum post MSLB SG Tube leakage. The minimum value of 5.128 5.02 gpm is considered to be the maximum allowable tube leakage.

Offsite, TSC and Control Room Doses - Base Case + max. post MSLB Leakage

This spreadsheet uses the maximum allowable tube leakage and Equation 2 to calculate the thyroid, whole body and beta doses. The results presented in this spreadsheet are also given in the calculational cover sheet.

	A	B	C	D	E	F	G	H	I	J	K	L	M	N
15														
16														
17														
18														
19	Case		EAB			LPZ			Control Room				TSC	
20	Limiting	Thyroid	Whole Body	Beta-skin	Thyroid	Whole Body	Beta-skin	Thyroid	Whole Body	Beta-skin	Thyroid	Whole Body	Beta-skin	
21	C1	Iodines	.3612E+01	.1254E-01	.3454E-02	.2476E+01	.5714E-02	.1716E-02	.4247E+00	.4461E-04	.2443E-03	.5874E+00	.3590E-04	.3494E-03
22	C2	Iodines	.2616E+03	.8935E+00	.2472E+00	.2128E+03	.4579E+00	.1400E+00	.3838E+02	.3830E-02	.2129E-01	.5319E+02	.3077E-02	.3044E-01
23	C4	Noble Gases	.0000E+00	.1117E-01	.6189E-02	.0000E+00	.8084E-02	.4586E-02	.0000E+00	.1859E-01	.1906E+00	.0000E+00	.1160E-01	.2076E+00
24	C6	Noble Gases	.0000E+00	.2147E+00	.1251E+00	.0000E+00	.9612E-01	.5578E-01	.0000E+00	.1640E+00	.1645E+01	.0000E+00	.1041E+00	.1836E+01
25														

	R	S	T	U	V	W	X
36	Offsite, TSC and Control Room Doses - Base Case						
37	Equilibrium Secondary Side Activity (due to .147 gpm leak) + .147 gpm prim. to sec. leak						
38							
39							
40	Position	Thyroid		Whole Body		Beta Skin	
41		Dose	Case	Dose	Case	Dose	Case
42							
43							
44	EAB	3.612E+00	C1	2.371E-02	C1+C4	9.643E-03	C1+C4
45	LPZ	2.476E+00	C1	1.380E-02	C1+C4	6.302E-03	C1+C4
46	Control Room	4.247E-01	C1	1.863E-02	C1+C4	1.908E-01	C1+C4
47	TSC	5.874E-01	C1	1.164E-02	C1+C4	2.079E-01	C1+C4
48	*Including iodine contribution from limiting thyroid case						

WMO

Preparer: W. M. Blumberg

4/96

Reviewer: M. A. Whitley

Mer

4/95

	R	S	T	U	V	W	X
15							
16	Offsite, TSC and Control Room Doses - Base Case + 10 gpm						
17	Equilibrium Secondary Side Activity (due to .147 gpm leak) + 10.147 gpm prim. to sec. leak						
18							
19	Position	Thyroid		Whole Body		Beta Skir.	
20		Dose	Case	Dose	Case	Dose	Case
21	EAB	2.616E+02	C2	1.108E+00	C2+C6	3.723E-01	C2+C6
22	LPZ	2.128E+02	C2	5.540E-01	C2+C6	1.958E-01	C2+C6
23	Control Room	3.838E+01	C2	1.678E-01	C2+C6	1.666E+00	C2+C6
24	TSC	5.319E+01	C2	1.072E-01	C2+C6	1.866E+00	C2+C6
25	*Including iodine contribution from limiting thyroid case						

WMB

Preparer: W. M. Blumberg
4/96
43

	Y	Z	AA	AB	AC	AD	AE
4	Maximum Post-MSLB SG Tube Leakage						
5							
6			EAB				
7	Position	Thyroid		Whole Body		Beta Skin	
8		Limit	GPM	Limit	GPM	Limit	GPM
9	EAB	3.000E+02	1.033E+01	2.500E+01	2.073E+02	2.500E+01	6.202E+02
10	LPZ	3.000E+02	1.272E+01	2.500E+01	4.163E+02	2.500E+01	1.187E+03
11	Control Room	3.000E+01	7.002E+00	5.000E+00	3.004E+02	3.000E+01	1.817E+02
12	TSC	3.000E+01	5.021E+00	5.000E+00	4.697E+02	3.000E+01	1.616E+02
13							
14	*Including iodine contribution from limiting thyroid case						

	R	S	T	U	V	W
3	Offsite, TSC and Control Room Doses - Base Case + max. post MSLB Leakage					
4	Maximum Leak =	5.021E+00	gpm primary to sec. leakage			
5						
6						
7	Position	Thyroid		Whole Body		Beta Skin
8		Dose		Dose		Dose
9	EAB	1.33E+02		5.68E-01		1.92E-01
10	LPZ	1.08E+02		2.85E-01		1.01E-01
11	Control Room	1.95E+01		9.35E-02		9.31E-01
12	TSC	2.70E+01		5.96E-02		1.04E+00
13						
14		*Including iodine contribution from limiting thyroid case				

SOUTH TEXAS PROJECT ELECTRIC GENERATING STATION HOUSTON LIGHTING AND POWER COMPANY GENERAL COMPUTATIONAL SHEET	CALC NO: NC-6061	Sheet 46
SUBJECT: MAIN STEAM LINE BREAK DOSES FOR ALTERNATE PLUGGING CRITERIA (UFSAR CHAPTER 15.1.5)	REV. PREPARER / DATE	REVIEWER / DATE
UNIT: 9 (UNITS 1 & 2)	1 W. M. Blumberg 4/96 <i>VMB</i>	M. A. Whitley 4/96 <i>MW</i>

VIII Future Margin

This analysis contains a couple of some key conservatisms which might be used in the future if a larger primary to secondary leakage. The first conservatism is with the flow assumed out the target rock valve. The flow from 0-15 seconds is assumed to remain constant for the 8 hours of the accident. A more realistic approach would be to take credit for the gradual decrease in flow out these valves. Reference 11 contains more realistic flow rates.

The second conservatism is the analysis which assumes 5% failed fuel. This conservatism is the result of a commitment to the NRC which is documented in the SER (Reference 16). Since plant and fuel is designed for no fuel failures as a result of a MSLB, this conservatism could potentially be removed. This change would be more difficult since it would require review by the NRC staff. This was not considered for the TS 182, since the NRC requested that this TS submittal have minimal deviation from the Byron/Braidwood submittal from which it was modelled after.

Additionally, References 20 and 21 might be utilized to gain further insight which could be applied to gaining additional dose and primary to secondary break flow margin.

~~Also please note that in the future Cases A3, A5, B3, B5, C3, and C5 do not need to be rerun. These cases are bounded by Cases A1, A2, B1, B2, C1, and C2. This is justified based upon the TRACI results.~~

Another conservatism (that overestimates the control room doses) is in the control room HVAC model utilized. It was determined after the completion of Revision 1 of this calculation that a double failure was considered in the determination of the control room doses. Configuration 1A considers failure of a control room HVAC train and failure of a HVAC heater in one of the two remaining trains. The dose analysis should determine the limiting doses from a single failure. If the heater fails an operator action to shut off the train with the failed heater could be assumed to occur at 30 minutes. A sensitivity analysis to determine which of these failures yield the most limiting doses will need to be done. The double failure now assumed is more limiting than either of these single failure cases. Changing this assumption to a single failure assumption will not change the maximum break flow. This flow is limited by the TSC doses and is independent of the control room model.

Preparer: wmb

Reviewer:

```

# ##### # ##### #####
## # # ## # # # #
# # # # # # # #
# ##### # # # #####
# # # # # # #
# # # # # # #####
##### ##### ##### # ##### #####
##### ##### #####
# ##### # ##### #####
# # # # # # # # # # #
# # # # # # # # # # #
# # # # # # # # # # #
# # # # # # # # # # #
# # # # # # # # # # #
##### ##### # ##### #####
# ##### # ##### #####
## # # # # # # # # #
# # # # # # # # # #
# ##### # # # # #
# # # # # # # # # #
# # # # # # # # # #
##### ##### # ##### #####

```

```
*****
*           INSTALLATION OPERATING ENVIRONMENT
* Wed Sep 13 07:54:03 CDT 1995
*
* AIX nfad 2 3 000510106700
* XLFCMP.OBJ fortran compiler version 02.03.0000.0000
* XLF RTE.OBJ fortran runtime environment version 02.03.0000.0000
*
```

```
*****
*           CURRENT OPERATING ENVIRONMENT
* Tue Mar 26 16:50:51 CST 1996
*
* AIX nfad 2 3 000510106700
* XLFCMP.OBJ fortran compiler version 02.03.0000.0000
* XLF RTE.OBJ fortran runtime environment version 02.03.0000.0000
*
```

** RTE Verified **

Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A K-1b
Preparer: wmb Reviewer:

```
##### ##### ## #####
# $ # # # # #
# # # # # #
# ##### ##### #
# # # # # # #
# # # # # #####
# # # # # # # #
```



```
# #
# # ##      ##
# # # #
# # #
# # #
# # #
# # #
## ##### ##### # #
```

Dose Conversion Factors "dcf_input.f" were taken from the QA area

Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A K-1c
Preparer: wmb Reviewer:

```
# # # ##### # # #####
# ## # # # # # #
# # # # # # # #
# # # # ##### # # #
# # # # # # # #
# # # # # ##### # #

$ngeneral
preparer = 'wmb',
inode8 = 2,
ioffsite =1,
calc_title = 'Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A',
page_prefix = 'K',
print_dcf = 1,
print_instantaneous_activity = 0,
print_instantaneous_dose_rate = 0,
print_instantaneous_dose =0,
print_cumulative_dose = 0,
print_summary_dose =1,
print_laserjet = 1,
idebug = 0,
sub_time_step =10.0000,
$end

$nsource_term
num_isotope= 15,
iactivity_unit=0,
num_sources=1,
fract_activity_node= 1.0, 6.06E-7, 1.12E-6, 5*0.0, Pg 25 ✓
fract_release = .91, 4.0E-2, 5.0E-0/, 8*1.0, Pg 25 ✓
$end

$nsource1
activity1_name='rcs ',
activity1= 3*5.5e+5, 3*8.00e+5, 3*1.15E+6, 3*1.25e+6, 3*1.05e+6, Pg 25
activity1_unit= 'Ci',
activity1_mult=1.0
activity1_mult_unit= '',
activity1_mult_name= '',
$end

$nnodes
num_nodes=5,
node_volume_unit = 3,
flow_unit = 3,
ispray_cutoff = 0,
spray_df = 11*0.0,
node_name = ' RCS ', 'AFF. SG ', 'UNAFF SG ',
' TSC ', 'DUMMY ENV ', 'node 66666',
' node 77777 ', 'control rm ', 'epz ', 'ipz ',
node_volume = 6.88e+4, 1.66e+4, 4.97e+4, 3.60e+5, 1e+6, 2*0.0, 2.050e+6, Input 2, 5 + 6
geometry_factor = 3*1.0, 0.0, 3*1.0, 0.0,
$end

$ntime_steps
num_tsteps = 6,
tstep_unit = 1,
ieq_tstep = 0,
sdtime = 0.0,
first_tstep = 00.0 ,
last_tstep = 720.,
tstep = 0, .5, 2, 8, 24, 96,
$end

$nchi_over_q_cr
```

chi_over_q_control_room = 3*1.06e-3, 38*0.0, Input 10
\$end

\$nchi_over_q_offsite
chi_over_q_epz = 2*1.30e-4, 38*0.0, Input 7
chi_over_q_lpz = 2*3.80e-5, 1.6e-5, 1.1e-5, 4.3e-6, 1.2e-6, 34*0.0, Input 7
\$end

\$read
itime_step = 1, iunfilt = 1, ifilt =1, ifilt_remove = 1,1,1,0,7*0,
iremove = 0, ibreath_rate = 1, ioccupancy =1, icontrol = 1,
\$end

\$unfilt_flow
unfilt_flow =
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
1.470e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 6.920e-3, 4.260e-3, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 9.170e+3, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 8.540e+2, 5.260e+2, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
\$end

\$filt_flow
filt_flow =
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
2.730e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 5.170e-1, 3.180e-1, 3.550e+4, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
\$end

\$filt_remove1
filt_remove1=
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
9.900e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 9.900e-1, 9.900e-1, 9.900e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
\$end

\$filt_remove2
filt_remove2=
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
9.900e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 9.900e-1, 9.900e-1, 9.900e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
\$end

\$filt_remove3

```
filt_remove3=
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
9.900e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 9.900e-1, 9.900e-1, 9.900e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
$end
$occupbr
occupancy = 10*1.0,          J. put E and 9
br = 10*3.47e-4,           10*3.47e-4
$end
$incontrol
filt_cr = 16456.0, unfilter_cr = 74.8,
filt_remove_cr = 0.9886, 0.9432, 0.99, 8*0.0,
filt_recirc_cr = 0.9500, 0.9500, 0.99, 8*0.0,      10*0.0
exhaust_cr = 16530.8, recirc_cr= 71060.0,
$end
$read
itime_step = 2, iunfilter = 1, ifilt =1, ifilt_remove = 0,0,0,0,7*0,
iremove = 0,ibreath_rate = 0, ioccupancy =0, icontrol = 1,
$end
$unfilter_flow
unfilter_flow =
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
1.470e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 1.130e-4, 4.260e-3, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 9.170e+3, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 1.400e+1, 5.260e+2, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
$end
$filter_flow
filter_flow =
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
2.730e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 8.480e-3, 3.180e-1, 3.550e+4, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
$end
$incontrol
filt_cr = 16456.0, unfilter_cr = 74.8,
filt_remove_cr = 0.9886, 0.9432, 0.99, 8*0.0,
filt_recirc_cr = 0.9500, 0.9500, 0.99, 8*0.0,
exhaust_cr = 16530.8, recirc_cr= 71060.0,
$end
$read
itime_step = 3, iunfilter = 1, ifilt =1, ifilt_remove = 0,0,0,0,7*0,
iremove = 0,ibreath_rate = 0, ioccupancy =0, icontrol = 1,
$end
$unfilter_flow
```

```
unfilt_flow =
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
1.470e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 1.130e-4, 3.330e-3, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 9.170e+3, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 1.400e+1, 4.110e+2, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
$end
$nfilt_flow
  filt_flow =
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
2.730e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 8.480e-3, 2.490e-1, 3.550e+4, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
$end
$control
  filt_cr = 16456.0, unfilt_cr = 74.8,
  filt_remove_cr = 0.9886, 0.9432, 0.99, 8*0.0,
  filt_recirc_cr = 0.9500, 0.9500, 0.99, 8*0.0,
  exhaust_cr = 16530.8, recirc_cr= 71060.0,
$end
$read
  itime_step = 4, iunfilt = 1, ifilt =1, ifilt_remove = 0,0,0,0,7*0,
  iremove = 0, ibreath_rate = 1, ioccupancy =1, icontrol = 1,
$end
$unfilt_flow
  unfilt_flow =
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 9.170e+3, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
$end
$nfilt_flow
  filt_flow =
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 3.550e+4, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
$end
$occupbr
  occupancy = 10*1.0,
  br = 8*3.47e-4, 2*1.75e-4,
```

PJ 34

PJ 34

PJ 37 ✓

PJ 34 ✕

PJ 34 ✕

* Only 4.2 min
100% is
100% is
occupancy (4%)
occupancy

-1.01 ± 0.01

Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpx, HVAC 1A K-1g
Preparer: wmb Reviewer:

\$end
\$ncontrol
filt_cr = 16456.0, unfilt_cr = 74.8,
filt_remove_cr = 0.9886, 0.9432, 0.99, 8*0.0,
filt_recirc_cr = 0.9500, 0.9500, 0.99, 8*0.0,
exhaust_cr = 16530.8, recirc_cr= 71060.0, Pg 29
\$end
\$nread
itime_step = 5, iunfilt = 0, ifilt =0, ifilt_remove = 0,0,0,0,7*0,
iremove = 0,ibreath_rate = 1, ioccupancy =1, icontrol = 1,
\$end
\$noccupbr
occupancy = 8*0.6, 2*1.0,
br = 8*3.47e-4, 2*2.32e-4, Input 8.99
\$end
\$ncontrol
filt_cr = 16456.0, unfilt_cr = 74.8,
filt_remove_cr = 0.9886, 0.9432, 0.99, 8*0.0,
filt_recirc_cr = 0.9500, 0.9500, 0.99, 8*0.0,
exhaust_cr = 16530.8, recirc_cr= 71060.0, Pg 29
\$end
\$nread
itime_step = 6, iunfilt = 0, ifilt =0, ifilt_remove = 0,0,0,0,7*0,
iremove = 0,ibreath_rate = 1, ioccupancy =1, icontrol = 1,
\$end
\$noccupbr
occupancy = 8*0.4, 2*1.0,
br = 8*3.47e-4, 2*2.32e-4, Input 0.99
\$end
\$ncontrol
filt_cr = 16456.0, unfilt_cr = 74.8,
filt_remove_cr = 0.9886, 0.9432, 0.99, 8*0.0,
filt_recirc_cr = 0.9500, 0.9500, 0.99, 8*0.0,
exhaust_cr = 16530.8, recirc_cr= 71060.0, Pg 30
\$end

Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A K-1h
Preparer: wmb Reviewer:

#

Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A K-1i

Preparer: wmb

Reviewer:

*****TRACI VER. 1.0*****

Transient Radiological Assessment Code for

Isotopes

SOUTH TEXAS ELECTRIC GENERATING STATION

SEPTEMBER 24, 1992

CREATED BY WM. MARK BLUMBERG

RELOAD ENGINEERING SECTION

TRACI VERSION 1.0

JSN 15172

calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A

Mar 26 1996 16:50:53 page K - 1
preparer: wmb

GENERAL DATA

preparer	wmb	preparer initials
inode8	2	use node 8 0=no/ 1 =yes, treat as a region, 2=yes, model as control room
ioffsite	1	calculate offsite dose 0=no/1=yes

OUTPUT OPTIONS PRINT FLAGS 0 = NO / 1 = YES

print_dcf	1	print dose conversion factors
print_instantaneous_activity	0	print inst. activity for each time step as a function of isotope and node
print_instantaneous_dose_rate	0	print inst. dose rate for each time step as a function of isotope and node
print_instantaneous_dose	0	print accumulated dose for each time step as a function of isotope and node
print_cumulative_dose	0	print cumulative dose up to the ending time of each time step as a function of isotope and node
print_summary_dose	1	print summary of cumulative dose for all time steps as a function of whole body, skin & thyroid doses
idebug	0	print namelist variables as read in
print_laserjet	1	print laserjet compressed print
sub_time_step	.100E+02	time interval of sub_time_steps (in sec) note: if = 0.0, default time steps are used

TRACI VERSION 1.0

JSN 15172

Mar 26 1996 16:50:53 page K - 2
calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A
preparer: wmb

SOURCE TERM

num_isotope	15	number of isotopes (default 27, max 50)
iactivity_unit	0 : Ci	units of act. of source term 0=Ci / 1= Ci/ml / 2 = Bq / 3 = Bq/m ³
num_sources	1	number of sources at shutdown
fract_activity_node	.10E+01 .61E-06	fract. of total activity in each node
	.11E-05 .00E+00	
	.00E+00 .00E+00	
	.00E+00 .00E+00	
fract_release	.91E+00 .40E-01	fract. released from each isotope group
	.50E-01 .10E+01	
	.10E+01	

Note: the echo of fract_activity_node gives 8 values. Only "num_nodes" values will be used.

TRACI VERSION 1.0

JSN 15172

Mar 26 1996 16:50:53 page K - 3
preparer: wmb

calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A

SOURCE #1

activity1_name	rcs	name of source and reference #
activity1	see note below	activity of source term at shutdown
activity1_unit	Ci	units of activity of source
activity1_mult	1.000	value multiplied by activity1 to get units of iactivity_unit
activity1_mult_unit		units of activity1_mult

note: values for activity1, activity2, & activity3 are given in table entitled: "calculation of initial activities"

TRACI VERSION 1.0

JSN 15172

Mar 26 1996 16:50:53 page K - 4
preparer: wmb

calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A

NODES

num_nodes	5	number of nodes (max 7). Note: nodes 8,9 & 10 are reserved for cr, epz and lpz
node_volume_unit	3	unit of node vol. 1=m3/ 2=ft3 /3=gallons
flow_unit	3	unit of flow 1=cu. m/sec, 2=cfm/ 3=gpm
ispray_cutoff	0	auto. spray cutoff option 0=no/ 1=yes
spray_df	.0	spray decon. factor (for each isotope grp)
	.0	
	.0	
	.0	
	.0	
	.0	

NODE VOLUMES (gal) AND GEOMETRY FACTORS (dimensionless)

NODE	1	2	3	4	5
------	---	---	---	---	---

NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV
VOLUME	.6880E+05	.1660E+05	.4970E+05	.3600E+06	.1000E+07
GF*	.1000E+01	.1000E+01	.1000E+01	.3067E+02	.1000E+01

NODE	6	7	8	9	10
------	---	---	---	---	----

NODE NAME	node 66666	node 77777	control rm	epz	lpz
VOLUME	.0000E+00	.0000E+00	.2050E+07		
GF*	.1000E+01	.1000E+01	.1703E+02		

Notes: Format for echo of spray_df is f7.1, ie.
values of spray_dcf >99,999.9 will not echo properly.

* If "geometry_factor" is entered as zero or not entered a
geometry factor is calculated, otherwise the value entered is used.

TRACI VERSION 1.0

JSN 15172

Mar 26 1996 16:50:53 page K - 5
preparer: wmb

calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A

TIME STEPS

num_tsteps 6 number of time steps
tstep_unit 1:hours units of time steps 0=sec/ 1=hr. / 2=days
ieq_tstep 0 equal time step 0 = no, input times in
variable "tstep"/ 1 = yes
sdtime .0000E+00 time between shutdown and beginning of
first time step
first_tstep .0000E+00 time of beginning of first time step
(units of tstep_unit)
last_tstep .7200E+03 time of end of last time_step
(units of tstep_unit)
tstep see table below beginning time of 6 time steps
(required only if ieq_tstep=0
ie. unequal time steps are used)

TIME STEP NUMBER	BEGINNING TIME (hours)	TIME STEP NUMBER	BEGINNING TIME (hours)
1	.0000E+00	4	.8000E+01
2	.5000E+00	5	.2400E+02
3	.2000E+01	6	.9600E+02

TRACI VERSION 1.0
calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A

JSN 15172

Mar 26 1996 16:50:53 page K - 6
preparer: wmb

calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A

CHI/Q (sec/cubic meter)

TIME STEP (hours)	CONTROL RM	NODE 8	NODE 9	NODE 10
		EPZ	LPZ	
.0000E+00 to .5000E+00	.1060E-02	.1300E-03	.3800E-04	
.5000E+00 to .2000E+01	.1060E-02	.1300E-03	.3800E-04	
.2000E+01 to .8000E+01	.1060E-02	.0000E+00	.1600E-04	
.8000E+01 to .2400E+02	.0000E+00	.0000E+00	.1100E-04	
.2400E+02 to .9600E+02	.0000E+00	.0000E+00	.4300E-05	
.9600E+02 to .7200E+03	.0000E+00	.0000E+00	.1200E-05	

TRACI VERSION 1.0

JSN 15172

Mar 26 1996 16:50:53 page K - 7
preparer: smb

calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A

DOSE CONVERSION FACTORS AND DECAY CONSTANTS

DOSE CONVERSION FACTORS

ISOTOPE GROUP	DECAY CONSTANT (1/sec)	THYROID (rem/Ci)	BETA SKIN (rem * cu. meter)/(Ci * sec)	WHOLE BODY
I---131 1	.998E-06	.149E+07	.317E-01	.872E-01
I-- 131 2	.998E-06	.149E+07	.317E-01	.872E-01
I---131 3	.998E-06	.149E+07	.317E-01	.872E-01
I---132 1	.843E-04	.143E+05	.132E+00	.513E+00
I---132 2	.843E-04	.143E+05	.132E+00	.513E+00
I---132 3	.843E-04	.143E+05	.132E+00	.513E+00
I---133 1	.921E-05	.269E+06	.735E-01	.155E+00
I---133 2	.921E-05	.269E+06	.735E-01	.155E+00
I---133 3	.921E-05	.269E+06	.735E-01	.155E+00
I---134 1	.220E-03	.373E+04	.923E-01	.532E+00
I---134 2	.220E-03	.373E+04	.923E-01	.532E+00
I---134 3	.220E-03	.373E+04	.923E-01	.532E+00
I---135 1	.291E-04	.560E+05	.129E+00	.421E+00
I---135 2	.291E-04	.560E+05	.129E+00	.421E+00
I---135 3	.291E-04	.560E+05	.129E+00	.421E+00

TRACI VERSION 1.0
calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A

Mar 26 1996 16:50:53 page K - 8
preparer: wmb

JSN 15172

CALCULATION OF INITIAL ACTIVITIES - BEFORE SHUTDOWN

SOURCE NAME	NUMBER	ISOTOPE	GROUP	COL. 1			COL. 2			COL. 3			COL. 4			COL. 5			COL. 6			COL. 7			TOTAL ACTIVITY		
				UNITS	rcs	ci	UNITS	rcs	ci	UNITS	rcs	ci	UNITS	rcs	ci	UNITS	rcs	ci	UNITS	rcs	ci	UNITS	rcs	ci	UNITS	rcs	ci
1	1---131	1	.5500E+06				.1000E+01			.0000E+00			.5500E+06														
2	1---131	2	.5500E+06				.1000E+01			.0000E+00			.5500E+06														
3	1---131	3	.5500E+06				.1000E+01			.0000E+00			.5500E+06														
4	1---132	1	.8000E+06				.1000E+01			.0000E+00			.8000E+06														
5	1---132	2	.8000E+06				.1000E+01			.0000E+00			.8000E+06														
6	1---132	3	.8000E+06				.1000E+01			.0000E+00			.8000E+06														
7	1---133	1	.1150E+07				.1000E+01			.0000E+00			.1150E+07														
8	1---133	2	.1150E+07				.1000E+01			.0000E+00			.1150E+07														
9	1---133	3	.1150E+07				.1000E+01			.0000E+00			.1150E+07														
10	1---134	1	.1250E+07				.1000E+01			.0000E+00			.1250E+07														
11	1---134	2	.1250E+07				.1000E+01			.0000E+00			.1250E+07														
12	1---134	3	.1250E+07				.1000E+01			.0000E+00			.1250E+07														
13	1---135	1	.1050E+07				.1000E+01			.0000E+00			.1050E+07														
14	1---135	2	.1050E+07				.1000E+01			.0000E+00			.1050E+07														
15	1---135	3	.1050E+07				.1000E+01			.0000E+00			.1050E+07														

note: col. 7 = (col. 1*col. 2 + col. 3*col. 4 + col. 5*col. 6)

TRACI VERSION 1.0
calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A

JSN 15172

Mar 26 1996 16:50:53 page K - 9
preparer: wmb

NODAL DISTRIBUTION OF INITIAL ACTIVITIES - BEFORE SHUTDOWN (Ci)

NODES	1	2	3	4	5	8
NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm
I---131	1	.550E+06	.333E+00	.616E+00	.000E+00	.000E+00
I---131	2	.550E+06	.333E+C0	.616E+00	.000E+00	.000E+00
I---131	3	.550E+06	.333E+00	.616E+0C	.000E+00	.000E+00
I---132	1	.800E+06	.485E+00	.896E+00	.000E+00	.000E+00
I---132	2	.800E+06	.485E+00	.896E+00	.000E+00	.000E+00
I---132	3	.800E+06	.485E+00	.896E+00	.000E+00	.000E+00
I---133	1	.115E+07	.697E+00	.129E+01	.000E+00	.000E+00
I---133	2	.115E+07	.697E+00	.129E+01	.000E+00	.000E+00
I---133	3	.115E+07	.697E+00	.129E+01	.000E+00	.000E+00
I---134	1	.125E+07	.757E+00	.140E+01	.000E+00	.000E+00
I---134	2	.125E+07	.757E+00	.140E+01	.000E+00	.000E+00
I---134	3	.125E+07	.757E+00	.140E+01	.000E+00	.000E+00
I---135	1	.105E+07	.636E+00	.118E+01	.000E+00	.000E+00
I---135	2	.105E+07	.636E+00	.118E+01	.000E+00	.000E+00
I---135	3	.105E+07	.636E+00	.118E+01	.100E+00	.000E+00

TRACI VERSION 1.0

JSN 15172

Mar 26 1996 16:50:53 page K - 10
calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A
preparer: wmb

ACTIVITIES - AFTER .0000E+00 hours (Ci)							
NODES	1	2	3	4	5	8	
NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm	
IOTOP	GROUP						
1---131	1	.500E+06	.303E+00	.561E+00	.000E+00	.000E+00	
1---131	2	.220E+05	.133E-01	.246E-01	.000E+00	.000E+00	
1---131	3	.275E+05	.167E-01	.308E-01	.000E+00	.000E+00	
1---132	1	.728E+06	.441E+00	.815E+00	.000E+00	.000E+00	
1---132	2	.320E+05	.194E-01	.358E-01	.000E+00	.000E+00	
1---132	3	.400E+05	.242E-01	.448E-01	.000E+00	.000E+00	
1---133	1	.105E+07	.634E+00	.117E+01	.000E+00	.000E+00	
1---133	2	.460E+05	.279E-01	.515E-01	.000E+00	.000E+00	
1---133	3	.575E+05	.348E-01	.644E-01	.000E+00	.000E+00	
1---134	1	.114E+07	.689E+00	.127E+01	.000E+00	.000E+00	
1---134	2	.500E+05	.303E-01	.560E-01	.000E+00	.000E+00	
1---134	3	.625E+05	.379E-01	.700E-01	.000E+00	.000E+00	
1---135	1	.956E+06	.579E+00	.107E+01	.000E+00	.000E+00	
1---135	2	.420E+05	.255E-01	.470E-01	.000E+00	.000E+00	
1---135	3	.525E+05	.318E-01	.588E-01	.000E+00	.000E+00	

TRACI VERSION 1.0

JSN 15172

calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A

Mar 26 1996 16:50:54

page K - 11

preparer: wmb

TIME STEP NUMBER 1 - .0000E+00 to .5000E+00 (hours)

TIME DEPENDENT INPUT
(REPEATED FOR EACH TIME STEP)

itime_step	1	time step which corresponds to the time dependent data
iunfilt	1	read in unfiltered flow data for this time step 0 = no / 1 = yes
ifilt	1	read in filtered flow data for this time step 0 = no / 1 = yes
ifilt_remove	1 1 1 0 0 0 0 0 0 0 0	read in filter removal effic. for each isotope group for this time step. 0 = no / 1= yes ie. (ifilt_remove(1)=1 : read ... group 1 data)
iremove	0	read in removal constants for this time step 0 = no/ 1 = yes (in units "1/tste_unit") (1/hours)
ioccupancy	1	read in occupancy factors for this time step 0 = no/ 1 = yes (in units of %/day)
ibreath_rate	1	read in breathing rates for this time step 0 = no/ 1 = yes (in units of m3/sec)
icontrol	1	read in control room data 0 = no/ 1 = yes

TRACI VERSION 1.0
calc. title: Case C1-ne6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A

JSN 15172
page K - 12
preparer: Wmb

TIME STEP NUMBER 1 - .0000E+00 to .5000E+00 (hours)

Mar 26 1996 16:50:54

UNFILTERED FLOW RATE BETWEEN NODES - VARIABLE "UNFILT_FLOW" (gpm)

TO NODES	1	2	3	4	5	8	
NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm	environment
FROM NODE							
1	.000E+00	.147E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
2	.000E+00	.000E+00	.000E+00	.692E-02	.000E+00	.000E+00	.854E+03
3	.000E+00	.000E+00	.000E+00	.426E-02	.000E+00	.000E+00	.526E+03
4	.000E+00	.000E+00	.000E+00	.000E+00	.917E+04	.000E+00	.000E+00
5	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
8	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00

FILTERED FLOW RATE BETWEEN NODES - VARIABLE "FILT_FLOW" (gpm)

TO NODES	1	2	3	4	5	8	
NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm	environment
FROM NODE							
1	.000E+00	.000E+00	.273E+00	.000E+00	.000E+00	.000E+00	.000E+00
2	.000E+00	.000E+00	.000E+00	.517E+00	.000E+00	.000E+00	.000E+00
3	.000E+00	.000E+00	.000E+00	.318E+00	.000E+00	.000E+00	.000E+00
4	.000E+00	.000E+00	.000E+00	.355E+05	.000E+00	.000E+00	.000E+00
5	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
8	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00

note: a flow rate from node x to node y represents recirculation flow

TRACI VERSION 1.0

JSN 15172

Mar 26 1996 16:50:54 page K - 13
preparer: webb

calc. title: Case C1-nc6961, rev. 1. MSLB Accident Iodines only, .42 gpm, HVAC TA

TIME STEP NUMBER 1 - .0000E+00 to .5000E+00 (hours)

FOR: ELEM. I

1 FILTERED REMOVAL EFFICIENCY BETWEEN NODES "FILT FLOW REMOVE" (IN EFFICIENCY FRACTION)

FOR: ORG. 1

FILTERED REMOVAL EFFICIENCY BETWEEN NODES "FILT_FLOW REMOVE" (IN EFFICIENCY FRACTION)

TRACI VERSION 1.0 acal.c. title: Case C1-nc6061; rev. 1. HSLB Accident Loglines on\y. 42 qm. HVAC 1A Mar 26 1996 16:50:54 page K - 14
preparer: wmb

TIME STEP NUMBER 1 - 0000E+00 to .5000E+00 (hours)

Mar 26 1996 16:50:56

11

préparer : 100

FOR: PART. I
FILTERED REMOVAL EFFICIENCY BETWEEN NODES "FILT FLOW REMOVE" (IN EFFICIENCY FRACTION)

SOCIAL INFLUENCE ON DATE /MEETINGS, PRACTICALLY SEPARATED FROM THE TIME SIDE

TRACI VERSION 1.0

JSN 15172

Mar 26 1996 16:50:54 page K - 15
calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A
preparer: wmb

TIME STEP NUMBER 1 - .0000E+00 to .5000E+00 (hours)

CONTROL ROOM FILTER EFFICIENCY FRACTION AND FLOW (gpm) - MODEL 2

filt_cr .1646E+05 filtered intake rate
unfilt_cr .7480E+02 unfiltered intake rate
recirc_cr .7106E+05 recirculation rate
exhaust_cr .1653E+05 exhaust rate from control room

ISOTOPE GROUP FILTER EFFICIENCY FRACTION
INTAKE RECIRCULATION

ELEM. I	.9886E+00	.9500E+00
ORG. I	.9432E+00	.9500E+00
PART. I	.9900E+00	.9900E+00
NOB. GAS	.0000E+00	.0000E+00
Cs, Rb	.0000E+00	.0000E+00
Te, Se	.0000E+00	.0000E+00
Sr, Ba	.0000E+00	.0000E+00
NOB. MET.	.0000E+00	.0000E+00
RARE EARTH	.0000E+00	.0000E+00
MISC.	.0000E+00	.0000E+00
HALOGENS	.0000E+00	.0000E+00

TRACI VERSION 1.0

JSN 15172

calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A

Mar 26 1996 16:50:56 page K - 16
preparer: wmb

TIME STEP NUMBER 2 + .5000E+00 to .2000E+01 (hours)

TIME DEPENDENT INPUT
(REPEATED FOR EACH TIME STEP)

itime_step	2	time step which corresponds to the time dependent data
iunfilt	1	read in unfiltered flow data for this time step 0 = no / 1 = yes
ifilt	1	read in filtered flow data for this time step 0 = no / 1 = yes
ifilt_remove	0 0 0 0 0 0 0 0 0 0 0	read in filter removal effic. for each isotope group for this time step. 0 = no / 1= yes ie. (ifilt_remove(1)=1 : read in group 1 data)
iremove	0	read in removal constants for this time step 0 = no/ 1 = yes (in units "1/tstep_unit") (1/hours)
ioccupancy	0	read in occupancy factors for this time step 0 = no/ 1 = yes (in units of %/day)
ibreath_rate	0	read in breathing rates for this time step 0 = no/ 1 = yes (in units of m3/sec)
icontrol	1	read in control room data 0 = no/ 1 = yes

TRACI VERSION 1.0
calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A

JSN 15172
TIME STEP NUMBER 2 - .5000E+00 to .2000E+01 (hours)
page K - 17
preparer: wmb

Mar 26 1996 16:50:56

UNFILTERED FLOW RATE BETWEEN NODES - VARIABLE "UNFILT_FLOW" (gpm)

TO NODES	1	2	3	4	5	8	
FROM NODE	NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm environment
1	.000E+00	.147E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
2	.000E+00	.000E+00	.000E+00	.000E+00	.113E-03	.000E+00	.140E+02
3	.000E+00	.000E+00	.000E+00	.000E+00	.426E-02	.000E+00	.525E+03
4	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.917E+04	.000E+00
5	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
8	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00

FILTERED FLOW RATE BETWEEN NODES - VARIABLE "FILT_FLOW" (gpm)

TO NODES	1	2	3	4	5	8	
FROM NODE	NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm environment
1	.000E+00	.000E+00	.273E+00	.000E+00	.000E+00	.000E+00	.000E+00
2	.000E+00	.000E+00	.000E+00	.000E+00	.848E-02	.000E+00	.000E+00
3	.000E+00	.000E+00	.000E+00	.000E+00	.318E+00	.000E+00	.000E+00
4	.000E+00	.000E+00	.000E+00	.000E+00	.355E-05	.000E+00	.000E+00
5	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
8	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00

note: a flow rate from node x to node y represents recirculation flow

TRACI VERSION 1.0

JSN 15172

Mar 26 1996 16:50:56 page K - 18
preparer: wmb

calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A

TIME STEP NUMBER 2 - .5000E+00 to .2000E+01 (hours)

CONTROL ROOM FILTER EFFICIENCY FRACTION AND FLOW (gpm) - MODEL 2

filt_cr	.1646E+05	filtered intake rate
unfilt_cr	.7480E+02	unfiltered intake rate
recirc_cr	.7106E+05	recirculation rate
exhaust_cr	.1653E+05	exhaust rate from control room

ISOTOPE GROUP FILTER EFFICIENCY FRACTION
INTAKE RECIRCULATION

ELEM. I	.9886E+00	.9500E+00
ORG. I	.9432E+00	.9500E+00
PART. I	.9900E+00	.9900E+00
NOB. GAS	.0000E+00	.0000E+00
Cs, Rb	.0000E+00	.0000E+00
Te, Se	.0000E+00	.0000E+00
Sr, Ba	.0000E+00	.0000E+00
NOB. MET.	.0000E+00	.0000E+00
RARE EARTH	.0000E+00	.0000E+00
MISC.	.0000E+00	.0000E+00
HALOGENS	.0000E+00	.0000E+00

TRACI VERSION 1.0

JSN 15172

calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A

Mar 26 1996 16:51:00 page K - 19
preparer: wmb

TIME STEP NUMBER 3 - .2000E+01 to .8000E+01 (hours)

TIME DEPENDENT INPUT
(REPEATED FOR EACH TIME STEP)

itime_step	3	time step which corresponds to the time dependent data
iunfilt	1	read in unfiltered flow data for this time step 0 = no / 1 = yes
ifilt	1	read in filtered flow data for this time step 0 = no / 1 = yes
ifilt_remove	0 0 0 0 0 0 0 0 0 0 0	read in filter removal effic. for each isotope group for this time step. 0 = no / 1= yes ie. (ifilt_remove(1)=1 : read in group 1 data)
iremove	0	read in removal constants for this time step 0 = no/ 1 = yes (in units "1/tstep_unit") (1/hours)
ioccupancy	0	read in occupancy factors for this time step 0 = no/ 1 = yes (in units of %/day)
ibreath_rate	0	read in breathing rates for this time step 0 = no/ 1 = yes (in units of m ³ /sec)
icontrol	1	read in control room data 0 = no/ 1 = yes

TRACI VERSION 1.0
calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A

Mar 26 1996 16:51:01
page K - 20
preparer: wmb

TIME STEP NUMBER 3 - .2000E+01 to .8000E+01 (hours)

UNFILTERED FLOW RATE BETWEEN NODES - VARIABLE "UNFILT_FLOW" (gpm)

TO NODES	1	2	3	4	5	8	
FROM NODE	NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm environment
1		.000E+00	-14.7E+00	.000E+00	.000E+00	.000E+00	.000E+00
2		.000E+00	.000E+00	.000E+00	.113E-03	.000E+00	.140E+02
3		.000E+00	.000E+00	.000E+00	.333E-02	.000E+00	.411E+03
4		.000E+00	.000E+00	.000E+00	.000E+00	.917E+04	.000E+00
5		.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
8		.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00

FILTERED FLOW RATE BETWEEN NODES - VARIABLE "FILT_FLOW" (gpm)

TO NODES	1	2	3	4	5	8	
FROM NODE	NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm environment
1		.000E+00	.000E+00	.273E+00	.000E+00	.000E+00	.000E+00
2		.000E+00	.000E+00	.000E+00	.848E-02	.000E+00	.000E+00
3		.000E+00	.000E+00	.000E+00	.249E+00	.000E+00	.000E+00
4		.000E+00	.000E+00	.000E+00	.355E+05	.000E+00	.000E+00
5		.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
8		.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00

note: a flow rate from node x to node y represents recirculation flow

TRACI VERSION 1.0

JSN 15172

Mar 26 1996 16:51:01 page K - 21
calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A
preparer: wmb

TIME STEP NUMBER 3 - .2000E+01 to .8000E+01 (hours)

CONTROL ROOM FILTER EFFICIENCY FRACTION AND FLOW (gpm) - MODEL 2

filt_cr .1646E+05 filtered intake rate
unfilt_cr .7480E+02 unfiltered intake rate
recirc_cr .7106E+05 recirculation rate
exhaust_cr .1653E+05 exhaust rate from control room

ISOTOPE GROUP FILTER EFFICIENCY FRACTION
INTAKE RECIRCULATION

ELEM. I	.9886E+00	.9500E+00
ORG. I	.9432E+00	.9500E+00
PART. I	.9900E+00	.9900E+00
NOB. GAS	.0000E+00	.0000E+00
Cs, Rb	.0000E+00	.0000E+00
Te, Se	.0000E+00	.0000E+00
Sr, Ba	.0000E+00	.0000E+00
NOB. MET.	.0000E+00	.0000E+00
RARE EARTH	.0000E+00	.0000E+00
MISC.	.0000E+00	.0000E+00
HALOGENS	.0000E+00	.0000E+00

TRACI VERSION 1.0

JSN 15172

calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A

Mar 26 1996 16:51:34 page K - 22
preparer: wmb

TIME STEP NUMBER 4 - .8000E+01 to .2400E+02 (hours)

TIME DEPENDENT INPUT
(REPEATED FOR EACH TIME STEP)

itime_step	4	time step which corresponds to the time dependent data
iunfilt	1	read in unfiltered flow data for this time step 0 = no / 1 = yes
ifilt	1	read in filtered flow data for this time step 0 = no / 1 = yes
ifilt_remove	0 0 0 0 0 0 0 0 0 0 0	read in filter removal effic. for each isotope group for this time step. 0 = no / 1= yes ie. (ifilt_remove(1)=1 : read in group 1 data)
iremove	0	read in removal constants for this time step 0 = no/ 1 = yes (in units "1/tstep_unit") (1/hours)
ioccupancy	1	read in occupancy factors for this time step 0 = no/ 1 = yes (in units of %/day)
ibreath_rate	1	read in breathing rates for this time step 0 = no/ 1 = yes (in units of m3/sec)
icontrol	1	read in control room data 0 = no/ 1 = yes

TRACI VERSION 1.0
calc. title: Case C1-nc

JSN 15172
nt iodines only, .42 gpm, HVAC 1A

page K - 23
preparer: who

TIME STEP NUMBER 4 - .8000E+01 to .2400E+02 (hours)

THE JOURNAL OF CLIMATE

CHINESE MIGRATION AND CHINESE COMMUNITIES IN THE UNITED STATES

TO NODES	1	2	3	4	5	8
NODE NAME	RCS	AFF.	UNAFF	SG	TSC	DUMMY ENV
FROM NODE						control rm environment

1	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
2	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
3	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
4	.000E+00	.000E+00	.000E+00	.917E+04	.000E+00
5	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
6	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00

FILTERED FLOW RATE BETWEEN NODES - VARIABLE "FILT_FLOW" (cm³)

note: a flow rate from node x to node y represents recirculation flow

BREATHING RATE (M³/SEC), OCCUPANCY FACTORS (%/TIME STEP)

TRACI VERSION 1.0

JSN 15172

Mar 26 1996 16:51:34 page K - 24
calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A
preparer: wmb

TIME STEP NUMBER 4 - .8000E+01 to .2400E+02 (hours)

CONTROL ROOM FILTER EFFICIENCY FRACTION AND FLOW (gpm) - MODEL 2

filter_cr .1646E+05 filtered intake rate
unfilter_cr 7480E+02 unfiltered intake rate
recircr_cr .7105E+05 recirculation rate
exhaust_cr .1653E+05 exhaust rate from control room

ISOTOPE GROUP FILTER EFFICIENCY FRACTION
INTAKE RECIRCULATION

ELEM. I	.9886E+00	.9500E+00
ORG. I	.9432E+00	.9500E+00
PART. I	.9900E+00	.9900E+00
NOB. GAS	.0000E+00	.0000E+00
Cs, Rb	.0000E+00	.0000E+00
Te, Se	.0000E+00	.0000E+00
Sr, Ba	.0000E+00	.0000E+00
NOB. MET.	.0000E+00	.0000E+00
RARE EARTH	.0000E+00	.0000E+00
MISC.	.0000E+00	.0000E+00
HALOGENS	.0000E+00	.0000E+00

TRACI VERSION 1.0

JSN 15172

Mar 26 1996 16:53:12 page K - 25
preparer: smb

calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A

TIME STEP NUMBER 5 - .2400E+02 to .9600E+02 (hours)

TIME DEPENDENT INPUT
(REPEATED FOR EACH TIME STEP)

itime_step 5 time step which corresponds
to the time dependent data

iunfilt 0 read in unfiltered flow data for this time step
0 = no / 1 = yes

ifilt 0 read in filtered flow data for this time step
0 = no / 1 = yes

ifilt_remove 0 0 0 0 0 read in filter removal effic. for each isotope
group for this time step. 0 = no / 1= yes
0 ie. (ifilt_remove(1)=1 : read in group 1 data)

iremove 0 read in removal constants for this time step
0 = no/ 1 = yes (in units "1/tstep_unit")
(1/hours)

ioccupancy 1 read in occupancy factors for this time step
0 = no/ 1 = yes (in units of %/day)

ibreath_rate 1 read in breathing rates for this time step
0 = no/ 1 = yes (in units of m3/sec)

icontrol 1 read in control room data
0 = no/ 1 = yes

BREATHING RATE (M3/SEC), OCCUPANCY FACTORS (%/TIME STEP)

NODES	1	2	3	4	5	8	9	10
NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm epz		lpz
BREATH. RATE	.347E-03	.347E-03	.347E-03	.347E-03	.347E-03	.347E-03	.232E-03	.232E-03
OCCUPANCY	.600E+00	.600E+00	.600E+00	.600E+00	.600E+00	.600E+00	.100E+01	.100E+01

TRACI VERSION 1.0

JSN 15172

Mar 26 1996 16:53:12 page K - 26
calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A
preparer: wmb

TIME STEP NUMBER 5 - .2400E+02 to .9600E+02 (hours)

CONTROL ROOM FILTER EFFICIENCY FRACTION AND FLOW (gpm) - MODEL 2

filt_cr	.1646E+05	filtered intake rate
unfilt_cr	.7480E+02	unfiltered intake rate
recirc_cr	.7106E+05	recirculation rate
exhaust_cr	.1653E+05	exhaust rate from control room

ISOTOPE GROUP FILTER EFFICIENCY FRACTION
INTAKE RECIRCULATION

ELEM. I	.9886E+00	.9500E+00
ORG. I	.9432E+00	.9500E+00
PART. I	.9900E+00	.9900E+00
NOB. GAS	.0000E+00	.0000E+00
Cs, Rb	.0000E+00	.0000E+00
Te, Se	.0000E+00	.0000E+00
Sr, Ba	.0000E+00	.0000E+00
NOB. MET.	.0000E+00	.0000E+00
RARE EARTH	.0000E+00	.0000E+00
MISC.	.0000E+00	.0000E+00
HALOGENS	.0000E+00	.0000E+00

TRACI VERSION 1.0

JSN 15172

Mar 26 1996 17:00:32 page K - 27
preparer: wmb

calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A

TIME STEP NUMBER 6 - .9600E+02 to .7200E+03 (hours)

TIME DEPENDENT INPUT
(REPEATED FOR EACH TIME STEP)

itime_step 6 time step which corresponds
to the time dependent data

iunfilt 0 read in unfiltered flow data for this time step
0 = no / 1 = yes

ifilt 0 read in filtered flow data for this time step
0 = no / 1 = yes

ifilt_remove 0 0 0 0 0 read in filter removal effic. for each isotope
group for this time step. 0 = no / 1= yes
0 0 0 0 0 ie. (ifilt_remove(1)=1 : read in group 1 data)

iremove 0 read in removal constants for this time step
0 = no/ 1 = yes (in units "1/tstep_unit")
(1/hours)

ioccupancy 1 read in occupancy factors for this time step
0 = no/ 1 = yes (in units of %/day)

ibreath_rate 1 read in breathing rates for this time step
0 = no/ 1 = yes (in units of m3/sec)

icontrol 1 read in control room data
0 = no/ 1 = yes

BREATHING RATE (M3/SEC), OCCUPANCY FACTORS (%/TIME STEP)

NODES	1	2	3	4	5	8	9	10
NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm epz		lpz
BREATH. RATE	.347E-03	.347E-03	.347E-03	.347E-03	.347E-03	.347E-03	.232E-03	.232E-03
OCCUPANCY	.400E+00	.400E+00	.400E+00	.400E+00	.400E+00	.400E+00	.100E+01	.100E+01

TRACI VERSION 1.0
calc. title: Case G1-nc6061, rev. 1, MSIB Accident Iodines only, .42 gpm, HVAC 1A

Mar 26 1996 17:00:32 page K - 28
preparer: wmb

TIME STEP NUMBER 6 - .9600E+02 to .7200E+03 (hours)

CONTROL ROOM FILTER EFFICIENCY FRACTION AND FLOW (gpm) - MODEL 2

filt_cr	.1646E+05	filtered intake rate
unfilt_cr	.7480E+02	unfiltered intake rate
recirc_cr	.7106E+05	recirculation rate
exhaust_cr	.1653E+05	exhaust rate from control room

ISOTOPE GROUP	FILTER EFFICIENCY FRACTION INTAKE	FILTER EFFICIENCY FRACTION RECIRCULATION
ELEM. I	.9886E+00	.9500E+00
ORG. I	.9432E+00	.9500E+00
PART. I	.9900E+00	.9900E+00
NOB. GAS	.0000E+00	.0000E+00
Cs, Rb	.0000E+00	.0000E+00
Te, Se	.0000E+00	.0000E+00
Sr, Ba	.0000E+00	.0000E+00
NOB. MET.	.0000E+00	.0000E+00
RARE EARTH	.0000E+00	.0000E+00
MISC.	.0000E+00	.0000E+00
HALOGENS	.0000E+00	.0000E+00

TRACI VERSION 1.0

JSN 15172

Mar 26 1996 18:10:39 page K - 29
calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A
preparer: wmb

NODE NAME: RCS

SUMMARY OF CUMULATIVE DOSE FOR NODE 1 (REM) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.2871E+10	.1095E+08	.2946E+07
.5000E+00 to .2000E+01	.1131E+11	.3482E+08	.9902E+07
.2000E+01 to .8000E+01	.4308E+11	.8415E+08	.2661E+08
.8000E+01 to .2400E+02	.1173E+12	.1396E+09	.4802E+08
.2400E+02 to .9600E+02	.2653E+12	.1837E+09	.6591E+08
.9600E+02 to .7200E+03	.5418E+12	.2315E+09	.8340E+08

TRACI VERSION 1.0

JSN 15172

Mar 26 1996 18:10:39

page K - 30

preparer: smb

calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A

NODE NAME: AFF. SG

SUMMARY OF CUMULATIVE DOSE FOR NODE 2 (REM) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.3899E+06	.1444E+04	.3915E+03
.5000E+00 to .2000E+01	.6009E+07	.1668E+05	.4884E+04
.2000E+01 to .8000E+01	.8982E+08	.1375E+06	.4651E+05
.8000E+01 to .2400E+02	.4061E+09	.3737E+06	.1377E+06
.2400E+02 to .9600E+02	.1036E+10	.5616E+06	.2139E+06
.9600E+02 to .7200E+03	.2214E+10	.7649E+06	.2884E+06

TRACI VERSION 1.0

JSN 15172

Mar 26 1996 18:10:39 page K - 31
calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A
preparer: wrb

NODE NAME: UNAFF SG

SUMMARY OF CUMULATIVE DOSE FOR NODE 3 (REM) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.6826E+04	.2576E+02	.6951E+01
.5000E+00 to .2000E+01	.5464E+05	.1569E+03	.4550E+02
.2000E+01 to .8000E+01	.6229E+06	.9814E+03	.3292E+03
.8000E+01 to .2400E+02	.2697E+07	.2530E+04	.9269E+03
.2400E+02 to .9600E+02	.6828E+07	.3762E+04	.1427E+04
.9600E+02 to .7200E+03	.1455E+08	.5096E+04	.1915E+04

TRACI VERSION 1.0

JSN 15172

calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A

Mar 26 1996 18:10:39 page K - 32
preparer: wmb

NODE NAME: TSC

SUMMARY OF CUMULATIVE DOSE FOR NODE 4 (REM) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.6509E-01	.7789E-05	.6492E-04
.5000E+00 to .2000E+01	.1354E+00	.1484E-04	.1265E-03
.2000E+01 to .8000E+01	.5723E+00	.3535E-04	.3433E-03
.8000E+01 to .2400E+02	.5874E+00	.3590E-04	.3494E-03
.2400E+02 to .9600E+02	.5874E+00	.3590E-04	.3494E-03
.9600E+02 to .7200E+03	.5874E+00	.3590E-04	.3494E-03

TRACI VERSION 1.0

JSN 15172

calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A

Mar 26 1996 18:10:39 page K - 33
preparer: wmb

NODE NAME: DUMMY ENV

SUMMARY OF CUMULATIVE DOSE FOR NODE 5 (REM) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.5156E-02	.1870E-04	.5099E-05
.5000E+00 to .2000E+01	.9771E-01	.2765E-03	.8054E-04
.2000E+01 to .8000E+01	.1084E+01	.1680E-02	.5654E-03
.8000E+01 to .2400E+02	.5585E+01	.5041E-02	.1863E-02
.2400E+02 to .9600E+02	.1455E+02	.7715E-02	.2948E-02
.9600E+02 to .7200E+03	.3132E+02	.1061E-01	.4098E-02

TRACI VERSION 1.0

JSN 15172

Mar 26 1996 18:10:39 page K - 34
calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A
preparer: wmb

NODE NAME: control rm

SUMMARY OF CUMULATIVE DOSE FOR NODE 8 (REM) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.2439E-01	.5235E-05	.2426E-04
.5000E+00 to .2000E+01	.9182E-01	.1719E-04	.8254E-04
.2000E+01 to .8000E+01	.3928E+00	.4258E-04	.2317E-03
.8000E+01 to .2400E+02	.4247E+00	.4461E-04	.2443E-03
.2400E+02 to .9600E+02	.4247E+00	.4461E-04	.2443E-03
.9600E+02 to .7200E+03	.4247E+00	.4461E-04	.2443E-03

TRACI VERSION 1.0

JSN 15172

Mar 26 1996 18:10:39

page K - 35

preparer: wmb

calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A

NODE NAME: epz

SUMMARY OF CUMULATIVE DOSE FOR NODE 9 (REM) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.2761E+01	.1022E-01	.2772E-02
.5000E+00 to .2000E+01	.3612E+01	.1254E-01	.3454E-02
.2000E+01 to .8000E+01	.3612E+01	.1254E-01	.3454E-02
.8000E+01 to .2400E+02	.3612E+01	.1254E-01	.3454E-02
.2400E+02 to .9600E+02	.3612E+01	.1254E-01	.3454E-02
.9600E+02 to .7200E+03	.3612E+01	.1254E-01	.3454E-02

TRAC1 VERSION 1.0

JSN 15172

Mar 26 1996 18:10:40 page K - 36
preparer: wmb

calc. title: Case C1-nc6061, rev. 1, MSLB Accident Iodines only, .42 gpm, HVAC 1A

NODE NAME: lpz

SUMMARY OF CUMULATIVE DOSE FOR NODE 10 (REM) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.8069E+00	.2988E-02	.8103E-03
.5000E+00 to .2000E+01	.1056E+01	.3665E-02	.1010E-02
.2000E+01 to .8000E+01	.2476E+01	.5714E-02	.1716E-02
.8000E+01 to .2400E+02	.2476E+01	.5714E-02	.1716E-02
.2400E+02 to .9600E+02	.2476E+01	.5714E-02	.1716E-02
.9600E+02 to .7200E+03	.2476E+01	.5714E-02	.1716E-02

Preparer: wmb

Reviewer:

```

#   # ##### ###### #####
##  ## # # # # #
# # # # # # # #
#   # # ##### # # #
#   # # # # # # #
##### ##### # ##### #####
##### ##### # ##### #####
# # # # # # # # # #
# # # # # # # # #
# # ##### # ##### #####
# # # # # # # # #
# # # # # # # # #
##### ##### # ##### #####
#   ##### # ##### #####
##  # # ### # # # #
# # # # # # # #
# ##### # # #
# # # # # # # #
# # # # # # # #
##### ##### # ##### #####
#   ##### # ##### #####
##  # # ### # # # #
# # # # # # # #
# ##### # # #
# # # # # # # #
# # # # # # # #
##### ##### # ##### #####

```

*Input References
See the Site AS for
Case C1 except
AS Noted*

```
*****
*           INSTALLATION OPERATING ENVIRONMENT *
* Wed Sep 13 07:54:03 CDT 1995 *
*
* AIX nfad 2 3 000510106700 *
* XLFCMP.OBJ fortran compiler version 02.03.0000.0000 *
* XLF RTE.OBJ fortran runtime environment version 02.03.0000.0000 *
*
*****
```

```
*****
*           CURRENT OPERATING ENVIRONMENT *
* Tue Mar 26 16:51:09 CST 1996 *
*
* AIX nfad 2 3 000510106700 *
* XLFCMP.OBJ fortran compiler version 02.03.0000.0000 *
* XLF RTE.OBJ fortran runtime environment version 02.03.0000.0000 *
*
*****
```

** RTE Verified **

Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A L-1b
Preparer: wmb Reviewer:

#

#

Dose Conversion Factors "dcf_input.f" were taken from the QA area

Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A L-1c
Preparer: wmb Reviewer:

```
# # # ##### # # #####  
# ## # # # # # #  
# # # # # ##### # #  
# # # # # ##### #  
# # # # # ##### #  
# # # # # ##### #  
  
$ngeneral  
preparer = 'wmb',  
inode8 = 2,  
ioffsite =1,  
calc_title = 'Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A',  
page_prefix = 'L',  
print_dcf = 1,  
print_instantaneous_activity = 0,  
print_instantaneous_dose_rate = 0,  
print_instantaneous_dose =0,  
print_cumulative_dose = 0,  
print_summary_dose =1,  
print_laserjet = 1,  
idebug = 0,  
sub_time_step =10.0000,  
$end  
$nsource_term  
num_isotope= 15,  
iactivity_unit=0,  
num_sources=1,  
fract_activity_node= 1.0, 6.06E-7, 1.12E-6, 5*0.0,  
fract_release = .91, 4.0E-2, 5.0E-02, 8*1.0,  
$end  
$nsource1  
activity1_name='rcs ',  
activity1= 3*5.5e+5, 3*8.00e+5, 3*1.15E+6, 3*1.25e+6, 3*1.05e+6,  
activity1_unit= 'Ci ',  
activity1_mult=1.0 ,  
activity1_mult_unit=' ',  
activity1_mult_name=' ',  
$end  
$nnodes  
num_nodes=5,  
node_volume_unit = 3,  
flow_unit = 3,  
ispray_cutoff = 0,  
spray_df = 11*0.0,  
node_name = ' RCS ','AFF. SG ','UNAFF SG ',  
' TSC ','DUMMY ENV ','node 66666',  
'node 77777','control rm','epz ','lpz ',  
node_volume = 6.88e+4,1.66e+4, 4.97e+4, 3.60e+5, 1e+6, 2*0.0, 2.050e+6,  
geometry_factor = 3*1.0,0.0,3*1.0, 0.0,  
$end  
$ntime_steps  
num_tsteps = 6,  
tstep_unit = 1,  
ieq_tstep = 0,  
sdtime = 0.0,  
first_tstep = 00.0 ,  
last_tstep = 720.,  
tstep = 0, .5, 2, 8, 24, 96,  
$end  
$nchi_over_q_cr
```

```
chi_over_q_control_room = 3*1.06e-3, 38*0.0,
$end
$nchi_over_q_offsite
chi_over_q_epz = 2*1.30e-4, 38*0.0,
chi_over_q_lpz = 2*3.80e-5, 1.6e-5, 1.1e-5, 4.3e-6, 1.2e-6, 34*0.0,
$end
$nread
itime_step = 1, iunfilt = 1, ifilt = 1, ifilt_remove = 1, 1, 1, 0, 7*0,
iremove = 0, ibreath_rate = 1, ioccupancy = 1, icontrol = 1,
$end
$nunfilt_flow
unfilt_flow =
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
1.010e+1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 7.000e-3, 4.260e-3, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 9.170e+3, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 8.640e+2, 5.260e+2, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
$end
$nfilt_flow
filt_flow =
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
2.730e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 5.230e-1, 3.180e-1, 3.550e+4, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
$end
$nfilt_remove1
filt_remove1=
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
9.900e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 9.900e-1, 9.900e-1, 9.900e-1, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
$end
$nfilt_remove2
filt_remove2=
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
9.900e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 9.900e-1, 9.900e-1, 9.900e-1, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
$end
$nfilt_remove3
```

17 25

17 35

```
filt_remove3=
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
9.900e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 9.900e-1, 9.900e-1, 9.900e-1, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
$end
$occupancy
occupancy = 10*1.0,
br = 10*3.47e-4,
$end
$control
filt_cr = 16456.0, unfilter_cr = 74.8,
filt_remove_cr = 0.9886, 0.9432, 0.99, 8*0.0,
filt_recirc_cr = 0.9500, 0.9500, 0.99, 8*0.0,
exhaust_cr = 16530.8, recirc_cr= 71060.0,
$end
$read
itime_step = 2, iunfilt = 1, ifilt =1, ifilt_remove = 0,0,0,0,7*0,
iremove = 0, ibreath_rate = 0, ioccupancy =0, icontrol = 1,
$end
$unfilt_flow
unfilt_flow =
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
1.010e+1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 1.950e-4, 4.260e-3, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 9.170e+3, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 2.400e+1, 5.260e+2, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
$end
$filt_flow
filt_flow =
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
2.730e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 1.450e-2, 3.180e-1, 3.550e+4, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
$end
$control
filt_cr = 16456.0, unfilter_cr = 74.8,
filt_remove_cr = 0.9886, 0.9432, 0.99, 8*0.0,
filt_recirc_cr = 0.9500, 0.9500, 0.99, 8*0.0,
exhaust_cr = 16530.8, recirc_cr= 71060.0,
$end
$read
itime_step = 3, iunfilt = 1, ifilt =1, ifilt_remove = 0,0,0,0,7*0,
iremove = 0, ibreath_rate = 0, ioccupancy =0, icontrol = 1,
$end
$unfilt_flow
```

Pj 34

Pj 36

unfilt_flow =
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
1.010e+1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 1.950e-4, 3.330e-3, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 9.170e+3, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 2.400e+1, 4.110e+2, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
\$end

\$nfilt_flow
filt_flow =
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
2.730e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 1.450e-2, 2.490e-1, 3.550e+4, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
\$end

\$ncontrol
filt_cr = 16456.0, unfilt_cr = 74.8,
filt_remove_cr = 0.9886, 0.9432, 0.99, 8*0.0,
filt_recirc_cr = 0.9500, 0.9500, 0.99, 8*0.0,
exhaust_cr = 16530.8, recirc_cr = 71060.0,
\$end

\$nread
itime_step = 4, iunfilt = 1, ifilt =1, ifilt_remove = 0,0,0,0,7*0,
iremove = 0, ibreath_rate = 1, ioccupancy =1, icontrol = 1,
\$end

\$nunfilt_flow
unfilt_flow =
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 9.170e+3, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
\$end

\$nfilt_flow
filt_flow =
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 3.550e+4, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
\$end

\$noccupbr
occupancy = 10*1.0,
br = 8*3.47e-4, 2*1.75e-4,

PJ 37

PJ 37

Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A L-1g
Preparer: wmb Reviewer:

```
$end
$control
filt_cr = 16456.0, unfilt_cr = 74.8,
filt_remove_cr = 0.9886, 0.9432, 0.99, 8*0.0,
filt_recirc_cr = 0.9500, 0.9500, 0.99, 8*0.0,
exhaust_cr = 16530.8, recirc_cr= 71060.0,
$end
$read
itime_step = 5, iunfilt = 0, ifilt =0, ifilt_remove = 0,0,0,0,7*0,
iremove = 0,ibreath_rate = 1, ioccupancy =1, icontrol = 1,
$end
$occupbr
occupancy = 8*0.6, 2*1.0,
br = 8*3.47e-4, 2*2.32e-4,
$end
$control
filt_cr = 16456.0, unfilt_cr = 74.8,
filt_remove_cr = 0.9886, 0.9432, 0.99, 8*0.0,
filt_recirc_cr = 0.9500, 0.9500, 0.99, 8*0.0,
exhaust_cr = 16530.8, recirc_cr= 71060.0,
$end
$read
itime_step = 6, iunfilt = 0, ifilt =0, ifilt_remove = 0,0,0,0,7*0,
iremove = 0,ibreath_rate = 1, ioccupancy =1, icontrol = 1,
$end
$occupbr
occupancy = 8*0.4, 2*1.0,
br = 8*3.47e-4, 2*2.32e-4,
$end
$control
filt_cr = 16456.0, unfilt_cr = 74.8,
filt_remove_cr = 0.9886, 0.9432, 0.99, 8*0.0,
filt_recirc_cr = 0.9500, 0.9500, 0.99, 8*0.0,
exhaust_cr = 16530.8, recirc_cr= 71060.0,
$end
```

Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A L-1h
Preparer: wmb Reviewer:

#

Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A L-1i

Preparer: wmb

Reviewer:

*****TRACI VER. 1.0*****

Transient Radiological Assessment Code for

Isotopes

SOUTH TEXAS ELECTRIC GENERATING STATION

SEPTEMBER 24, 1992

CREATED BY WM. MARK BLUMBERG

RELOAD ENGINEERING SECTION

TRACI VERSION 1.0

JSN 11750

Mar 26 1996 16:51:11

page L - 1

calc. title: Case C2-REGU61, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A

preparer: wmb

GENERAL DATA

preparer	wmb	preparer initials
inode8	2	use node 8 0=no/ 1 =yes, treat as a region, 2=yes, model as control room
ioffsite	1	calculate offsite dose 0=no/1=yes

OUTPUT OPTIONS PRINT FLAGS 0 = NO / 1 = YES

print_dcf	1	print dose conversion factors
print_instantaneous_activity	0	print inst. activity for each time step as a function of isotope and node
print_instantaneous_dose_rate	0	print inst. dose rate for each time step as a function of isotope and node
print_instantaneous_dose	0	print accumulated dose for each time step as a function of isotope and node
print_cumulative_dose	0	print cumulative dose up to the ending time of each time step as a function of isotope and node
print_summary_dose	1	print summary of cumulative dose for all time steps as a function of whole body, skin & thyroid doses
idebug	0	print namelist variables as read in
print_laserjet	1	print laserjet compressed print
sub_time_step	.100E+02	time interval of sub_time_steps (in sec) note: if = 0.0, default time steps are used

TRACI VERSION 1.0

JSN 11750

Mar 26 1996 16:51:11 page L - 2

calc. title: Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A

SOURCE TERM

num_isotope	15	number of isotopes (default 27, max 50)
iactivity_unit	0 : Ci	units of act. of source term 0=Ci / 1= Ci/ml / 2 = Bq / 3 = Bq/m ³
num_sources	1	number of sources at shutdown
fract_activity_node	.10E+01 .61E-06 .11E-05 .00E+00 .00E+00 .00E+00 .00E+00 .00E+00	fract. of total activity in each node
fract_release	.91E+00 .40E-01 .50E-01 .10E+01 .10E+01 .10E+01 .10E+01 .10E+01 .10E+01 .10E+01	fract. released from each isotope group

Note: the echo of fract_activity_node gives 8 values. Only "num_nodes" values will be used.

TRACI VERSION 1.0

JSN 11750

Mar 26 1996 16:51:12 page L - 3
calc. title: Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A
preparer: wmb

SOURCE #1

activity1_name	rcs	name of source and reference #
activity1	see note below	activity of source term at shutdown
activity1_unit	Ci	units of activity of source
activity1_mult	1.000	value multiplied by activity1 to get units of iactivity_unit
activity1_mult_unit		units of activity1_mult

note: values for activity1, activity2, & activity3 are given in table entitled: "calculation of initial activities"

TRACI VERSION 1.0

JSN 11750

Mar 26 1996 16:51:12 page L - 4
preparer: wmb

calc. title: Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A

NODES

num_nodes 5 number of nodes (max 7). Note: nodes
 8,9 & 10 re reserved for cr, epz and lpz
 node_volume_unit 3 unit of node vol. 1=m3/ 2=ft3 /3=gallons
 flow_unit 3 unit of flow 1=cu. m/sec, 2=cfm/ 3=gpm
 ispray_cutoff 0 auto. spray cutoff option 0=no/ 1=yes
 spray_df .0 .0 spray decon. factor (for each isotope grp)
 .0 .0
 .0 .0
 .0 .0
 .0 .0
 .0

NODE VOLUMES (gal) AND GEOMETRY FACTORS (dimensionless)

NODE	1	2	3	4	5
------	---	---	---	---	---

NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV
-----------	-----	---------	----------	-----	-----------

VOLUME	.6880E+05	.1660E+05	.4970E+05	.3600E+06	.1000E+07
--------	-----------	-----------	-----------	-----------	-----------

GF*	.1000E+01	.1000E+01	.1000E+01	.3067E+02	.1000E+01
-----	-----------	-----------	-----------	-----------	-----------

NODE	6	7	8	9	10
------	---	---	---	---	----

NODE NAME	node 66666	node 77777	control rm	epz	lpz
-----------	------------	------------	------------	-----	-----

VOLUME	.0000E+00	.0000E+00	.2050E+07		
--------	-----------	-----------	-----------	--	--

GF*	.1000E+01	.1000E+01	.1703E+02		
-----	-----------	-----------	-----------	--	--

Notes: Format for echo of spray_df is f7.1, ie.
 values of spray_dcf >99,999.9 will not echo properly.

* If "geometry_factor" is entered as zero or not entered a
 geometry factor is calculated, otherwise the value entered is used.

TRACI VERSION 1.0

JSN 11750

Mar 26 1996 16:51:12 page L - 5
calc. title: Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A
preparer: wmb

TIME STEPS

num_tsteps 6 number of time steps
tstep_unit 1:hours units of time steps 0=sec/ 1=hr. / 2=days
ieq_tstep 0 equal time step 0 = no, input times in
variable "tstep"/ 1 = yes
sdtime .0000E+00 time between shutdown and beginning of
first time step
first_tstep .0000E+00 time of beginning of first time step
(units of tstep_unit)
last_tstep .7200E+03 time of end of last time_step
(units of tstep_unit)
tstep see table below beginning time of 6 time steps
(required only if ieq_tstep=0
ie. unequal time steps are used)

TIME STEP NUMBER	BEGINNING		TIME STEP NUMBER	BEGINNING	
	TIME (hours)	TIME (hours)		TIME (hours)	TIME (hours)
1	.0000E+00		4	.8000E+01	
2	.5000E+00		5	.2400E+02	
3	.2000E+01		6	.9600E+02	

TRACI VERSION 1.0
calc. title: Case C2-mc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A

JSN 11750 Mar 26 1996 16:51:12 page L - 6
MSLB Accident Iodines only, 10.42 gpm, HVAC 1A
preparer: wmb

CH1/Q (sec/cubic meter)

TIME STEP (hours)	NODE 8 CONTROL RM	NODE 9 EPZ	NODE 10 LPZ
.0000E+00 to .5000E+00	.1060E-02	.1300E-03	.3800E-04
.5000E+00 to .2000E+01	.1060E-02	.1300E-03	.3800E-04
.2000E+01 to .8000E+01	.1060E-02	.0000E+00	.1600E-04
.8000E+01 to .2400E+02	.0000E+00	.0000E+00	.1100E-04
.2400E+02 to .9600E+02	.0000E+00	.0000E+00	.4300E-05
.9600E+02 to .7200E+03	.0000E+00	.0000E+00	.1200E-05

TRACI VERSION 1.0

JSN 11750

Mar 26 1996 16:51:12 page L - 7

calc. title: Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A

preparer: wmb

DOSE CONVERSION FACTORS AND DECAY CONSTANTS

DOSE CONVERSION FACTORS

ISOTOPE GROUP	DECAY CONSTANT (1/sec)	THYROID (rem/Ci)	BETA SKIN (rem * cu. meter)/(Ci * sec)	WHOLE BODY
I--131 1	.998E-06	.149E+07	.317E-01	.872E-01
I-- 131 2	.998E-06	.149E+07	.317E-01	.872E-01
I--131 3	.998E-06	.149E+07	.317E-01	.872E-01
I--132 1	.843E-04	.143E+05	.132E+00	.513E+00
I--132 2	.843E-04	.143E+05	.132E+00	.513E+00
I--132 3	.843E-04	.143E+05	.132E+00	.513E+00
I--133 1	.921E-05	.269E+06	.735E-01	.155E+00
I--133 2	.921E-05	.269E+06	.735E-01	.155E+00
I--133 3	.921E-05	.269E+06	.735E-01	.155E+00
I--134 1	.220E-03	.373E+04	.923E-01	.532E+00
I--134 2	.220E-03	.373E+04	.923E-01	.532E+00
I--134 3	.220E-03	.373E+04	.923E-01	.532E+00
I--135 1	.291E-04	.560E+05	.129E+00	.421E+00
I--135 2	.291E-04	.560E+05	.129E+00	.421E+00
I--135 3	.291E-04	.560E+05	.129E+00	.421E+00

CALCULATION OF INITIAL ACTIVITIES - BEFORE SHUTDOWN

SOURCE NAME	UNITS	NUMBER	ISOTOPE	GROUP	COL. 1 rCS Ci	COL. 2	COL. 3	COL. 4	COL. 5	COL. 6	COL. 7 TOTAL ACTIVITY Ci
1	1---	131	1	.5500E+06	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.5500E+06
2	1---	131	2	.5500E+06	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.5500E+06
3	1---	131	3	.5500E+06	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.5500E+06
4	1---	132	1	.8000E+06	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.8000E+06
5	1---	132	2	.8000E+06	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.8000E+06
6	1---	132	3	.8000E+06	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.8000E+06
7	1---	133	1	.1150E+07	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.1150E+07
8	1---	133	2	.1150E+07	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.1150E+07
9	1---	133	3	.1150E+07	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.1150E+07
10	1---	134	1	.1250E+07	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.1250E+07
11	1---	134	2	.1250E+07	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.1250E+07
12	1---	134	3	.1250E+07	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.1250E+07
13	1---	135	1	.1050E+07	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.1050E+07
14	1---	135	2	.1050E+07	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.1050E+07
15	1---	135	3	.1050E+07	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.1050E+07

note: col. 7 = (col. 1*col. 2 + col. 3*col.4 + col. 5*col. 6)

TRACI VERSION 1.0
calc. title: Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A

JSN 11750

Mar 26 1996 16:51:12 page L - 9
preparer: kmb

NODAL DISTRIBUTION OF INITIAL ACTIVITIES - BEFORE SHUTDOWN (Ci)

NODES	1	2	3	4	5	6	7	8
NODE NAME	RCS	AFF.	UNAFF	SG	TSC	DUMMY	ENV	control rm
I---131	1	.55CE+06	.333E+00	.616E+00	.000E+00	.000E+00	.000E+00	.000E+00
I---131	2	.550E+06	.333E+00	.616E+00	.000E+00	.000E+00	.000E+00	.000E+00
I---131	3	.550E+06	.333E+00	.616E+00	.000E+00	.000E+00	.000E+00	.000E+00
I---132	1	.800E+06	.485E+00	.696E+00	.000E+00	.000E+00	.000E+00	.000E+00
I---132	2	.800E+06	.485E+00	.696E+00	.000E+00	.000E+00	.000E+00	.000E+00
I---132	3	.800E+06	.485E+00	.696E+00	.000E+00	.000E+00	.000E+00	.000E+00
I---133	1	.115E+07	.697E+00	.129E+01	.000E+00	.000E+00	.000E+00	.000E+00
I---133	2	.115E+07	.697E+00	.129E+01	.000E+00	.000E+00	.000E+00	.000E+00
I---133	3	.115E+07	.697E+00	.129E+01	.000E+00	.000E+00	.000E+00	.000E+00
I---134	1	.125E+07	.757E+00	.140E+01	.000E+00	.000E+00	.000E+00	.000E+00
I---134	2	.125E+07	.757E+00	.140E+01	.000E+00	.000E+00	.000E+00	.000E+00
I---134	3	.125E+07	.757E+00	.140E+01	.000E+00	.000E+00	.000E+00	.000E+00
I---135	1	.105E+07	.636E+00	.118E+01	.000E+00	.000E+00	.000E+00	.000E+00
I---135	2	.105E+07	.636E+00	.118E+01	.000E+00	.000E+00	.000E+00	.000E+00
I---135	3	.105E+07	.636E+00	.118E+01	.000E+00	.000E+00	.000E+00	.000E+00

TRACI VERSION 1.0
calc. title: Case C2-nc60s1, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A

JSN 11750

Mar 26 1996 16:51:12 page L - 10
preparer: wmdo

ACTIVITIES - AFTER .0000E+00 hours (Ci)

NODES	1	2	3	4	5	6	7	8
NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm		
I---131	1	.500E+06	.303E+00	.561E+00	.000E+00	.000E+00	.000E+00	.000E+00
I---131	2	.225E+05	.133E-01	.246E-01	.000E+00	.000E+00	.000E+00	.000E+00
I---131	3	.275E+05	.167E-01	.308E-01	.000E+00	.000E+00	.000E+00	.000E+00
I---132	1	.728E+06	.441E+00	.815E+00	.000E+00	.000E+00	.000E+00	.000E+00
I---132	2	.320E+05	.194E-01	.358E-01	.000E+00	.000E+00	.000E+00	.000E+00
I---132	3	.400E+05	.242E-01	.448E-01	.000E+00	.000E+00	.000E+00	.000E+00
I---133	1	.102E+07	.634E+00	.117E+01	.050E+00	.000E+00	.000E+00	.000E+00
I---133	2	.460E+05	.279E-01	.515E-01	.000E+00	.000E+00	.000E+00	.000E+00
I---133	3	.575E+05	.348E-01	.644E-01	.000E+00	.000E+00	.000E+00	.000E+00
I---134	1	.114E+07	.689E+00	.127E+01	.000E+00	.000E+00	.000E+00	.000E+00
I---134	2	.500E+05	.303E-01	.560E-01	.000E+00	.000E+00	.000E+00	.000E+00
I---134	3	.625E+05	.379E-01	.700E-01	.000E+00	.000E+00	.000E+00	.000E+00
I---135	1	.950E+06	.579E+00	.107E+01	.000E+00	.000E+00	.000E+00	.000E+00
I---135	2	.420E+05	.255E-01	.470E-01	.000E+00	.000E+00	.000E+00	.000E+00
I---135	3	.525E+05	.318E-01	.588E-01	.000E+00	.000E+00	.000E+00	.000E+00

TRACI VERSION 1.0

JSN 11750

Mar 26 1996 16:51:12 page L - 11
calc. title: Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A
preparer: wmb

TIME STEP NUMBER 1 - .0000E+00 to .5000E+00 (hours)

TIME DEPENDENT INPUT
(REPEATED FOR EACH TIME STEP)

itime_step	1	time step which corresponds to the time dependent data
iunfilt	1	read in unfiltered flow data for this time step 0 = no / 1 = yes
ifilt	1	read in filtered flow data for this time step 0 = no / 1 = yes
ifilt_remove	1 1 1 0 0 0 0 L 0 0 0	read in filter removal effic. for each isotope group for this time step. 0 = no / 1= yes ie. (ifilt_remove(1)=1 : read in group 1 data)
iremove	0	read in removal constants for this time step 0 = no/ 1 = yes (in units "1/tstep_unit") (1/hours)
ioccupancy	1	read in occupancy factors for this time step 0 = no/ 1 = yes (in units of %/day)
ibreath_rate	1	read in breathing rates for this time step 0 = no/ 1 = yes (in units of m ³ /sec)
icontrol	1	read in control room data 0 = no/ 1 = yes

TRACI VERSION 1.0

JSN 11750

Mar 26 1996 16:51:12 page L - 12
preparer: smb

calc. title: Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A

TIME STEP NUMBER 1 - .0000E+00 to .5000E+00 (hours)

UNFILTERED FLOW RATE BETWEEN NODES - VARIABLE "UNFILT_FLOW" (gpm)

TO NODES	1	2	3	4	5	8	
NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm	environment
FROM NODE							
1	.000E+00	.101E+02	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
2	.000E+00	.000E+00	.000E+00	.700E-02	.000E+00	.000E+00	.864E+03
3	.000E+00	.000E+00	.000E+00	.426E-02	.000E+00	.000E+00	.526E+03
4	.000E+00	.000E+00	.000E+00	.000E+00	.917E+04	.000E+00	.000E+00
5	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
8	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00

FILTERED FLOW RATE BETWEEN NODES - VARIABLE "FILT_FLOW" (gpm)

TO NODES	1	2	3	4	5	8	
NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm	environment
FROM NODE							
1	.000E+00	.000E+00	.273E+00	.000E+00	.000E+00	.000E+00	.000E+00
2	.000E+00	.000E+00	.000E+00	.523E+00	.000E+00	.000E+00	.000E+00
3	.000E+00	.000E+00	.000E+00	.318E+00	.000E+00	.000E+00	.000E+00
4	.000E+00	.000E+00	.000E+00	.355E+05	.000E+00	.000E+00	.000E+00
5	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
8	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00

note: a flow rate from node x to node x represents recirculation flow

TRACI VERSION 1.0

JSN 11750

Mar 26 1996 16:51:12 page L - 13

calc. title: Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gram, HVAC 1A

preparer: wmb

TIME STEP NUMBER 1 - .0000E+00 to .5000E+00 (hours)

FOR: ELEM. I

FILTERED REMOVAL EFFICIENCY BETWEEN NODES "FILT FLOW REMOVE" (IN EFFICIENCY FRACTION)

FOR: ORG. I

FILTERED REMOVAL EFFICIENCY BETWEEN NODES "FILT_FLOW REMOVE" (IN EFFICIENCY FRACTION)

TRACI VERSION 1.0 calc title: Case C2-nr6061 rev: 4 MSB Accident Iodines only. 10-42 gsm, HVAC 1A JSON 11750 Mar 26 1996 16:51:13 page L - 14 preparer: wmb

TIME STEP NUMBER 1 = .0000E+00 to .5000E+00 (hours)

TRACI VERSION 1.0 calc title: Case C2-nr6061 rev: 4 MSB Accident Iodines only. 10-42 gsm, HVAC 1A JSON 11750 Mar 26 1996 16:51:13 page L - 14 preparer: wmb

TIME STEP NUMBER 1 = .0000E+00 to .5000E+00 (hours)

```
FOR : PART_1
      FILTERED REMOVAL EFFICIENCY BETWEEN NODES "FILT_FLOW_REMOVE" ( IN EFFICIENCY FRACTION )
```

BREATHING RATE (M³/SEC) - OCCUPANCY FACTORS (%/TIME STEP)

TRACI VERSION 1.0

JSN 11750

Mar 26 1996 16:51:13 page L - 15
calc. title: Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A
preparer: wmb

TIME STEP NUMBER 1 - .3000E+00 to .5000E+00 (hours)

CONTROL ROOM FILTER EFFICIENCY FRACTION AND FLOW (gpm) - MODEL 2

filt_cr	.1646E+05	filtered intake rate
unfilt_cr	.7480E+02	unfiltered intake rate
recirc_cr	.7106E+05	recirculation rate
exhaust_cr	.1653E+05	exhaust rate from control room

ISOTOPE GROUP FILTER EFFICIENCY FRACTION
INTAKE RECIRCULATION

ELEM. I	.9886E+00	.9500E+00
ORG. I	.9432E+00	.9500E+00
PART. I	.9900E+00	.9900E+00
NOB. GAS	.0000E+00	.0000E+00
Cs, Rb	.0000E+00	.0000E+00
Te, Se	.0000E+00	.0000E+00
Sr, Ba	.0000E+00	.0000E+00
NOB. MET.	.0000E+00	.0000E+00
RARE EARTH	.0000E+00	.0000E+00
MISC.	.0000E+00	.0000E+00
HALOGENS	.0000E+00	.0000E+00

TRACI VERSION 1.0

JSN 11750

Mar 26 1996 16:51:16 page L - 16
calc. title: Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A
preparer: wmb

TIME STEP NUMBER 2 - .5000E+00 to .2000E+01 { hours }

TIME DEPENDENT INPUT
(REPEATED FOR EACH TIME STEP)

itime_step 2 time step which corresponds
to the time dependent data
iunfilt 1 read in unfiltered flow data for this time step
0 = no / 1 = yes
ifilt 1 read in filtered flow data for this time step
0 = no / 1 = yes
ifilt_remove 0 0 0 0 0 read in filter removal effic. for each isotope
group for this time step. 0 = no / 1= yes
0 ie. (ifilt_remove(1)=1 : read in group 1 data)
iremove 0 read in removal constants for this time step
0 = no/ 1 = yes (in units "1/tstep_unit")
(1/hours)
ioccupancy 0 read in occupancy factors for this time step
0 = no/ 1 = yes (in units of %/day)
ibreath_rate 0 read in breathing rates for this time step
0 = no/ 1 = yes (in units of m3/sec)
icontrol 1 read in control room data
0 = no/ 1 = yes

TRACI VERSION 1.0
calc. title: Case G2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A

JSN 11750
TIME STEP NUMBER 2 - .5000E+00 to .2000E+01 (hours)
page L - 17
preparer: wmb

Mar 26 1996 16:51:16

UNFILTERED FLOW RATE BETWEEN NODES - VARIABLE "UNFILT_FLOW" (gpm)

TO NODES	1	2	3	4	5	6	7	8
FROM NODE	NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm	environment
1		.000E+00	.101E+02	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
2		.000E+00	.000E+00	.000E+00	.195E-03	.000E+00	.000E+00	.240E+02
3		.000E+00	.000E+00	.000E+00	.426E-02	.000E+00	.000E+00	.526E+03
4		.000E+00	.000E+00	.000E+00	.000E+00	.917E+04	.000E+00	.000E+00
5		.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
8		.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00

FILTERED FLOW RATE BETWEEN NODES - VARIABLE "FILT_FLOW" (gpm)

TO NODES	1	2	3	4	5	6	7	8
FROM NODE	NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm	environment
1		.000E+00	.000E+00	.273E+00	.000E+00	.000E+00	.000E+00	.000E+00
2		.000E+00	.000E+00	.000E+00	.145E-01	.000E+00	.000E+00	.000E+00
3		.000E+00	.000E+00	.000E+00	.318E+00	.000E+00	.000E+00	.000E+00
4		.000E+00	.000E+00	.000E+00	.355E+05	.000E+00	.000E+00	.000E+00
5		.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
8		.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00

note: a flow rate from node x to node y represents recirculation flow

TRACI VERSION 1.0

JSN 11750

Mar 26 1996 16:51:16 page L - 18
preparer: wmb

calc. title: Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A

TIME STEP NUMBER 2 - .5000E+00 to .2000E+01 (hours)

CONTROL ROOM FILTER EFFICIENCY FRACTION AND FLOW (gpm) - MODEL 2

filt_cr	.1646E+05	filtered intake rate
unfilt_cr	.7480E+02	unfiltered intake rate
recirc_cr	.7106E+05	recirculation rate
exhaust_cr	.1653E+05	exhaust rate from control room

ISOTOPE GROUP FILTER EFFICIENCY FRACTION
INTAKE RECIRCULATION

ELEM. I	.9886E+00	.9500E+00
ORG. I	.9432E+00	.9500E+00
PART. I	.9900E+00	.9900E+00
NOB. GAS	.0000E+00	.0000E+00
Cs, Rb	.0000E+00	.0000E+00
Te, Se	.0000E+00	.0000E+00
Sr, Ba	.0000E+00	.0000E+00
NOB. MEY.	.0000E+00	.0000E+00
RARE EARTH	.0000E+00	.0000E+00
MISC.	.0000E+00	.0000E+00
HALOGENS	.0000E+00	.0000E+00

TRACI VERSION 1.0

JSN 11750

Mar 26 1996 16:51:25

page L - 19

preparer: wmb

calc. title: Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A

TIME STEP NUMBER 3 - .2000E+01 to .8000E+01 (hours)

TIME DEPENDENT INPUT
(REPEATED FOR EACH TIME STEP)

itime_step	3	time step which corresponds to the time dependent data
iunfilt	1	read in unfiltered flow data for this time step 0 = no / 1 = yes
ifilt	1	read in filtered flow data for this time step 0 = no / 1 = yes
ifilt_remove	0 0 0 0 0 0 0 0 0 0 0	read in filter removal effic. for each isotope group for this time step. 0 = no / 1= yes ie. (ifilt_remove(1)=1 : read in group 1 data)
iremove	0	read in removal constants for this time step 0 = no/ 1 = yes (in units "1/tstep_unit") (1/hours)
ioccupancy	0	read in occupancy factors for this time step 0 = no/ 1 = yes (in units of %/day)
ibreath_rate	0	read in breathing rates for this time step 0 = no/ 1 = yes (in units of m3/sec)
icontrol	1	read in control room data 0 = no/ 1 = yes

TRACI VERSION 1.0

JSN 11750
calc. title: Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A

page l - 20
preparer: kmb

Mar 26 1996

16:51:25

TIME STEP NUMBER: 3 - .2000E+01 to .8000E+01 (hours)

UNFILTERED FLOW RATE BETWEEN NODES - VARIABLE "UNFILT_FLOW" (gpm)

TO NODES	1	2	3	4	5	8	
NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm	environment
FROM NODE							
1	.000E+00	.101E+02	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
2	.000E+00	.000E+00	.000E+00	.195E-03	.000E+00	.020E+00	.244E+02
3	.000E+00	.000E+00	.000E+00	.333E-02	.000E+00	.C00E+00	.411E+03
4	.000E+00	.000E+00	.000E+00	.000E+00	.917E-04	.000E+00	.000E+00
5	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
8	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00

FILTERED FLOW RATE BETWEEN NODES - VARIABLE "FILT_FLOW" (gpm)

TO NODES	1	2	3	4	5	8	
NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm	environment
FROM NODE							
1	.000E+00	.000E+00	.273E+00	.000E+00	.000E+00	.000E+00	.000E+00
2	.000E+00	.000E+00	.000E+00	.145E-01	.000E+00	.000E+00	.000E+00
3	.000E+00	.000E+00	.000E+00	.249E+00	.000E+00	.000E+00	.000E+00
4	.000E+00	.000E+00	.000E+00	.355E-05	.000E+00	.000E+00	.000E+00
5	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
8	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00

note: a flow rate from node x to node y represents recirculation flow

TRACI VERSION 1.0

JSN 11750

Mar 26 1996 16:51:26 page L - 21
calc. title: Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A
preparer: wmb

TIME STEP NUMBER 3 ~ .2000E+01 to .8000E+01 (hours)

CONTROL ROOM FILTER EFFICIENCY FRACTION AND FLOW (gpm) - MODEL 2

filt_cr	.1646E+05	filtered intake rate
unfilt_cr	.7480E+02	unfiltered intake rate
recirc_cr	.7106E+05	recirculation rate
exhaust_cr	.103E+05	exhaust rate from control room

ISOTOPE GROUP FILTER EFFICIENCY FRACTION
INTAKE RECIRCULATION

ELEM. I	.9886E+00	.9500E+00
ORG. I	.9432E+00	.9500E+00
PART. I	.9900E+00	.9900E+00
NOB. GAS	.0000E+00	.0000E+00
Cs, Rb	.0000E+00	.0000E+00
Te, Se	.0000E+00	.0000E+00
Sr, Ba	.0000E+00	.0000E+00
NOB. MET.	.0000E+00	.0000E+00
RARE EARTH	.0000E+00	.0000E+00
MISC.	.0000E+00	.0000E+00
HALOGENS	.0000E+00	.0000E+00

TRACI VERSION 1.0

JSN 11750

Mar 26 1996 16:52:02 page L - 22

calc. title: Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A

preparer: wmb

TIME STEP NUMBER 4 - .8000E+01 to .2400E+02 (hours)

TIME DEPENDENT INPUT
(REPEATED FOR EACH TIME STEP)

itime_step 4 time step which corresponds
to the time dependent data
iunfilt 1 read in unfiltered flow data for this time step
0 = no / 1 = yes
ifilt 1 read in filtered flow data for this time step
0 = no / 1 = yes
ifilt_remove 0 0 0 0 0 read in filter removal effic. for each isotope
group for this time step. 0 = no / 1= yes
0 ie. (ifilt_remove(1)=1 : read in group 1 data)
iremove 0 read in removal constants for this time step
0 = no/ 1 = yes (in units "1/tstep_unit")
(1/hours)
ioccupancy 1 read in occupancy factors for this time step
0 = no/ 1 = yes (in units of %/day)
ibreath_rate 1 read in breathing rates for this time step
0 = no/ 1 = yes (in units of m3/sec)
icontrol 1 read in control room data
0 = no/ 1 = yes

TRACK VERSION 1.0

ISBN 11750

page 1 - 23

CALC. TITLE: LAST CLOUD; REV. 1; HOLD ACCIDENTS LOCATED

LINFILTERED FLOW RATE BETWEEN NODES - VARIABLE INFILTRATION FLOW

FILTERED FLOW RATE BETWEEN NODES - VARIABLE "FILT FLOW" (OPEN)

note: a flow rate from node x to node y represents recirculation flow

BREATHING RATE (CM³/SEC) - OCCUPANCY FACTORS (%/TIME STEP)

NODES	1	2	3	4	5	8	9	10
NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm epz		lpz
BREATH. RATE	.367E-03	.347E-03	.347E-03	.347E-03	.347E-03	.347E-03	.175E-03	.175E-03
OCCIDIANI-Y	100E+01	100E+01	100E+01	100E+01	100E+01	-100E+01	-100E+01	-100E+01

TRACI VERSION 1.0

JSH 11750

Mar 26 1996 16:52:03 page L - 24
calc. title: Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A
preparer: wmb

TIME STEP NUMBER 4 - .8000E+01 to .2400E+02 (hours)

CONTROL ROOM FILTER EFFICIENCY FRACTION AND FLOW (gpm) - MODEL 2

filt_cr	.1646E+05	filtered intake rate
unfilt_cr	.7480E+02	unfiltered intake rate
recirc_cr	.7106E+05	recirculation rate
exhaust_cr	.1653E+05	exhaust rate from control room

ISOTOPE GROUP FILTER EFFICIENCY FRACTION
INTAKE RECIRCULATION

ELEM. I	.9886E+00	.9500E+00
ORG. I	.9432E+00	.9500E+00
PART. I	.9900E+00	.9900E+00
NOB. GAS	.0000E+00	.0000E+00
Cs, Rb	.0000E+00	.0000E+00
Te, Se	.0000E+00	.0000E+00
Sr, Ba	.0000E+00	.0000E+00
NOB. MET.	.0000E+00	.0000E+00
RARE EARTH	.0000E+00	.0000E+00
MISC.	.0000E+00	.0000E+00
HALOGENS	.0000E+00	.0000E+00

TRACI VERSION 1.0

JSN 11750

Mar 26 1996 16:53:41

page L - 25
preparer: wmb

calc. title: Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A

TIME STEP NUMBER 5 = .2400E+02 to .9600E+02 (hours)

TIME DEPENDENT INPUT
(REPEATED FOR EACH TIME STEP)

itime_step 5 time step which corresponds
 to the time dependent data
 iunfilt 0 read in unfiltered flow data for this time step
 0 = no / 1 = yes
 ifilt 0 read in filtered flow data for this time step
 0 = no / 1 = yes
 ifilt_remove 0 0 0 0 0 read in filter removal effic. for each isotope
 group for this time step. 0 = no / 1= yes
 0 ie. (ifilt_remove(1)=1 : read in group 1 data)
 iremove 0 read in removal constants for this time step
 0 = no/ 1 = yes (in units "1/tstep_unit")
 (1/hours)
 ioccupancy 1 read in occupancy factors for this time step
 0 = nc/ 1 = yes (in units of %/day)
 ibreath_rate 1 read in breathing rates for this time step
 0 = no/ 1 = yes (in units of m3/sec)
 icontrol 1 read in control room data
 0 = no/ 1 = yes

BREATHING RATE (M3/SEC), OCCUPANCY FACTORS (%/TIME STEP)

NODES	1	2	3	4	5	8	9	10
NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm epz		lpz
BREATH. RATE	.347E-03	.347E-03	.347E-03	.347E-03	.347E-03	.347E-03	.232E-03	.232E-03
OCCUPANCY	.600E+00	.600E+00	.600E+00	.600E+00	.600E+00	.600E+00	.100E+01	.100E+01

TRACI VERSION 1.0

JSN 11750

Mar 26 1996 16:53:41 page L - 26

calc. title: Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A

preparer: wmb

TIME STEP NUMBER 5 - .2400E+02 to .9600E+02 (hours)

CONTROL ROOM FILTER EFFICIENCY FRACTION AND FLOW (gpm) - MODEL 2

filt_cr	.1646E+05	filtered intake rate
unfilt_cr	.7480E+02	unfiltered intake rate
recirc_cr	.7106E+05	recirculation rate
exhaust_cr	.1653E+05	exhaust rate from control room

ISOTOPE GROUP FILTER EFFICIENCY FRACTION
INTAKE RECIRCULATION

ELEM. I	.9886E+00	.9500E+00
ORG. I	.9432E+00	.9500E+00
PART. I	.9900E+00	.9900E+00
NOB. GAS	.0000E+00	.0000E+00
Cs, Rb	.0000E+00	.0000E+00
Te, Se	.0000E+00	.0000E+00
Sr, Ba	.0000E+00	.0000E+00
NOB. MET.	.0000E+00	.0000E+00
RARE EARTH	.0000E+00	.0000E+00
MISC.	.0000E+00	.0000E+00
HALOGENS	.0000E+00	.0000E+00

TRACI VERSION 1.0

JSN 11750

Mar 26 1996 17:01:09 page L - 27
preparer: wmb

calc. title: Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A

TIME STEP NUMBER 6 - .9600E+02 to .7200E+03 (hours)

TIME DEPENDENT INPUT
(REPEATED FOR EACH TIME STEP)

itime_step 6 time step which corresponds
 to the time dependent data
 iunfilt 0 read in unfiltered flow data for this time step
 0 = no / 1 = yes
 ifilt 0 read in filtered flow data for this time step
 0 = no / 1 = yes
 ifilt_remove 0 0 0 0 0 read in filter removal effic. for each isotope
 group for this time step. 0 = no / 1= yes
 0 ie. (ifilt_remove(1)=1 : read in group 1 data)
 iremove 0 read in removal constants for this time step
 0 = no/ 1 = yes (in units "1/tstep_unit")
 (1/hours)
 ioccupancy 1 read in occupancy factors for this time step
 0 = no/ 1 = yes (in units of %/day)
 ibreath_rate 1 read in breathing rates for this time step
 0 = no/ 1 = yes (in units of m3/sec)
 icontrol 1 read in control room data
 0 = no/ 1 = yes

BREATHING RATE (M3/SEC), OCCUPANCY FACTORS (%/TIME STEP)

NODES	1	2	3	4	5	8	9	10
NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm epz		lpz
BREATH. RATE	.347E-03	.347E-03	.347E-03	.347E-03	.347E-03	.347E-03	.232E-03	.232E-03
OCCUPANCY	.400E+00	.400E+00	.400E+00	.400E+00	.400E+00	.400E+00	.100E-01	.100E+01

TRACI VERSION 1.0
calc. title: Case C2_nc5061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A
Mar 26 1996 17:01:00 page L - 28
preparer: smbd

TIME STEP NUMBER 6 - .9600E+02 to .7200E+03 (hours)

CONTROL ROOM FILTER EFFICIENCY FRACTION AND FLOW (gpm) - MODEL 2

filter_cr	.1646E+05	filtered intake rate
unfilt_cr	.7480E+02	unfiltered intake rate
recirc_cr	.7106E+05	recirculation rate
exhaust_cr	.1653E+05	exhaust rate from control room

ISOTOPE GROUP	FILTER EFFICIENCY FRACTION	
	INTAKE	RECIRCULATION
ELEM. I	.9886E+00	.9500E+00
ORG. I	.9432E+00	.9500E+00
PART. I	.9900E+00	.9900E+00
NOB. GAS	.0000E+00	.0000E+00
Cs, Rb	.0000E+00	.0000E+00
Te, Se	.0000E+00	.0000E+00
Sr, Ba	.0000E+00	.0000E+00
NOB. MET.	.0000E+00	.0000E+00
RARE EARTH	.0000E+00	.0000E+00
MISC.	.0000E+00	.0000E+00
HALOGENS	.0000E+00	.0000E+00

TRACI VERSION 1.0

JSN 11750

Mar 26 1996 18:10:30 page L - 29
calc. title: Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A
preparer: wmb

NODE NAME: RCS

SUMMARY OF CUMULATIVE DOSE FOR NODE 1 (REM) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.2865E+10	.1093E+08	.2940E+07
.5000E+00 to .2000E+01	.1122E+11	.3455E+08	.9823E+07
.2000E+01 to .8000E+01	.4165E+11	.8195E+08	.2587E+08
.8000E+01 to .2400E+02	.1109E+12	.1337E+09	.4584E+08
.2400E+02 to .9600E+02	.2490E+12	.1749E+09	.6253E+08
.9600E+02 to .7200E+03	.5070E+12	.2194E+09	.7886E+08

TRACI VERSION 1.0

JSN 11750

Mar 26 1996 18:10:30 page L - 30

calc. title: Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A

preparer: wmb

NODE NAME: AFF. SG

SUMMARY OF CUMULATIVE DOSE FOR NODE 2 (REM) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.2626E+08	.9720E+05	.2636E+05
.5000E+00 to .2000E+01	.4086E+09	.1134E+07	.3321E+06
.2000E+01 to .8000E+01	.6025E+10	.9239E+07	.3124E+07
.8000E+01 to .2400E+02	.2701E+11	.2491E+08	.9172E+07
.2400E+02 to .9600E+02	.6880E+11	.3737E+08	.1423E+08
.9600E+02 to .7200E+03	.1469E+12	.5086E+08	.1917E+08

TRACI VERSION 1.0

JSN 11750

Mar 26 1996 18:10:30 page L - 31
calc. title: Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A
preparer: wmb

NODE NAME: UNAFF SG

SUMMARY OF CUMULATIVE DOSE FOR NODE 3 (REM) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.6823E+04	.2575E+02	.6947E+01
.5000E+00 to .2000E+01	.5442E+05	.1564E+03	.4533E+02
.2000E+01 to .8000E+01	.6104E+06	.9641E+03	.3232E+03
.8000E+01 to .2400E+02	.2618E+07	.2463E+04	.9018E+03
.2400E+02 to .9600E+02	.6617E+07	.3656E+04	.1385E+04
.9600E+02 to .7200E+03	.1409E+08	.4947E+04	.1858E+04

TRACI VERSION 1.0

JSN 11750

Mar 26 1996 18:10:31 page L - 32
calc. title: Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A
preparer: wmb

NODE NAME: TSC

SUMMARY OF CUMULATIVE DOSE FOR NODE 4 (REM) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.4365E+01	.5220E-03	.4351E-02
.5000E+00 to .2000E+01	.9735E+01	.1052E-02	.9001E-02
.2000E+01 to .8000E+01	.5175E+02	.3025E-02	.2985E-01
.8000E+01 to .2400E+02	.5319E+02	.3077E-02	.3044E-01
.2400E+02 to .9600E+02	.5319E+02	.3077E-02	.3044E-01
.9600E+02 to .7200E+03	.5319E+02	.3077E-02	.3044E-01

TRAC! VERSION 1.0

JSN 11750

Mar 26 1996 18:10:31 page L - 33
calc. title: Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A
preparer: wmb

NODE NAME: DUMMY ENV

SUMMARY OF CUMULATIVE DOSE FOR NODE 5 (REM) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.3413E+00	.1237E-02	.3374E-03
.5000E+00 to .2000E+01	.6756E+01	.1906E-01	.5557E-02
.2000E+01 to .8000E+01	.9156E+02	.1383E+00	.4688E-01
.8000E+01 to .2400E+02	.5007E+03	.4439E+00	.1648E+00
.2400E+02 to .9600E+02	.1316E+04	.6871E+00	.2634E+00
.9600E+02 to .7200E+03	.2840E+04	.9502E+00	.3599E+00

TRACI VERSION 1.0

JSN 11750

Mar 26 1996 18:10:31 page L - 34
calc. title: Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A
preparer: wmb

NODE NAME: control rm

SUMMARY OF CUMULATIVE DOSE FOR NODE 8 (REM) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.1630E+01	.3497E-03	.1621E-02
.5000E+00 to .2000E+01	.6516E+01	.1208E-02	.5817E-02
.2000E+01 to .8000E+01	.3533E+02	.3636E-02	.2008E-01
.8000E+01 to .2400E+02	.3838E+02	.3830E-02	.2129E-01
.2400E+02 to .9600E+02	.3838E+02	.3830E-02	.2129E-01
.9600E+02 to .7200E+03	.3838E+02	.3830E-02	.2129E-01

TRACI VERSION 1.0

JSN 11750

calc. title: Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A

Mar 26 1996 18:10:31 page L - 35
preparer: wmb

NODE NAME: epz

SUMMARY OF CUMULATIVE DOSE FOR NODE 9 (REM) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.1861E+03	.6889E+00	.1868E+00
.5000E+00 to .2000E+01	.2616E+03	.8935E+00	.2472E+00
.2000E+01 to .8000E+01	.2616E+03	.8935E+00	.2472E+00
.8000E+01 to .2400E+02	.2616E+03	.8935E+00	.2472E+00
.2400E+02 to .9600E+02	.2616E+03	.8935E+00	.2472E+00
.9600E+02 to .7200E+03	.2616E+03	.8935E+00	.2472E+00

TRACI VERSION 1.0

JSN 11750

Mar 26 1996 18:10:31 page i - 36
calc. title: Case C2-nc6061, rev. 1, MSLB Accident Iodines only, 10.42 gpm, HVAC 1A
preparer: wmb

NODE NAME: lpz

SUMMARY OF CUMULATIVE DOSE FOR NODE 10 (REM) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.5441E+02	.2014E+00	.5461E-01
.5000E+00 to .2000E+01	.7647E+02	.2612E+00	.7225E-01
.2000E+01 to .8000E+01	.2128E+03	.4579E+00	.1400E+00
.8000E+01 to .2400E+02	.2128E+03	.4579E+00	.1400E+00
.2400E+02 to .9600E+02	.2128E+03	.4579E+00	.1400E+00
.9600E+02 to .7200E+03	.2128E+03	.4579E+00	.1400E+00

Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7 N-1a
Preparer: wmb Reviewer:

Preparer: wmb

Reviewers:

#####

```
*****  
*           INSTALLATION OPERATING ENVIRONMENT  
* Wed Sep 13 07:54:03 CDT 1995  
*  
* AIX nfad 2 3 000510106700  
* XLFCMP.OBJ fortran compiler version 02.03.0000.0000  
* XLF RTE.OBJ fortran runtime environment version 02.03.0000.0000  
*
```

```
*****  
*          CURRENT OPERATING ENVIRONMENT  
* Wed Mar 27 08:25:43 CST 1996  
*  
* AIX nfad 2 3 000510106700  
* XLFCMP.OBJ fortran compiler version 02.03.0000.0000  
* XLF RTE.OBJ fortran runtime environment version 02.03.0000.0000  
*  
*****
```

Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7 N-1b
Preparer: wmb Reviewer:

```
*****  
*Dose Conversion Factors "dcf_input.f" were User supplied*  
*****
```

Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7 N-1c
Preparer: wmb Reviewer:

```
#  #  #  #####  #  #  #####
#  ##  #  #  #  #  #  #
#  # #  #  #  #  #  #
#  # # #  #####  #  #  #
#  #  ## #  #  #  #
#  #  #  #  #####  #

$ngeneral
preparer = 'wmb',
inode8 = 2,
ioffsite =1,
calc_title = 'Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7',
page_prefix = 'N',
print_dcf = 1,
print_instantaneous_activity = 0,
print_instantaneous_dose_rate = 0,
print_instantaneous_dose =0,
print_cumulative_dose = 0,
print_summary_dose =1,
print_laserjet = 1,
idebug = 0,
sub_time_step =10.0000,
$end
$nsource_term
num_isotope= 13,
iactivity_unit=0,
num_sources=1,
fract_activity_node= 1.0, 9.00e-7, 1.67e-6, 5*0.0,
fract_release = .91, 4.0E-2, 5.0E-02, 8*1.0,
$end
$nsource1
activity1_name='rcs ',
activity1= 7.00e+4, 1.50e+5, 1.85e+4, 2.75e+5, 3.95e+5,
        4.85e+5, 3.85e+3, 1.65e+5, 1.15e+6, 2.30e+5,
        3.25e+5, 1.00e+6, 9.50e+5,
activity1_unit= 'Ci          ',
activity1_mult=1.0
activity1_mult_unit= '          ',
activity1_mult_name= '          ';
$end
$nnodes
num_nodes=5,
node_volume_unit = 3,
flow_unit = 3,
ispray_cutoff = 0,
spray_df = 11*0.0,
node_name = ' RCS      ','AFF. SG  ','UNAFF SG  ',
        ' TSC      ','DUMMY ENV ','node 66666',
        'node 77777','control rm','epz      ','lpz      ',
node_volume = 6.88e+4,1.66e+4, 4.97e+4, 3.60e+5, 1e+6, 2*0.0, 2.050e+6,
geometry_factor = 3*1.0,0.0,3*1.0, 0.0,
$end
$ntime_steps
num_tsteps = 5,
tstep_unit = 1,
ieq_tstep = 0,
sdtime = 0.0,
first_tstep = 00.0 ,
last_tstep = 96.,
tstep = 0, .5, 2, 8, 24, 96,
```

Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7 N-1d
Preparer: wmb Reviewer:

```
$end
$nchi_over_q_cr
chi_over_q_control_room = 3*1.06e-3, 38*0.0,
$end
$nchi_over_q_offsite
chi_over_q_epz = 2*1.30e-4, 38*0.0,
chi_over_q_lpz = 2*3.80e-5, 1.6e-5, 1.1e-5, 4.3e-6, 1.2e-6, 34*0.0,
$end
$nread
itime_step = 1, iunfilt = 1, ifilt =1, ifilt_remove = 1,1,1,0,7*0,
iremove = 0, ibreath_rate = 1, ioccupancy =1, icontrol = 1,
$end
$unfilt_flow
unfilt_flow =
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
1.470e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 6.920e-3, 4.260e-3, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 9.170e+3, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 8.540e+2, 5.260e+2, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
$end
$nfilt_flow
filt_flow =
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
2.730e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 5.170e-1, 3.180e-1, 3.550e+4, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
$end
$nfilt_remove1
filt_remove1=
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
9.900e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 9.900e-1, 9.900e-1, 9.900e-1, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
$end
$nfilt_remove2
filt_remove2=
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
9.900e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 9.900e-1, 9.900e-1, 9.900e-1, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
```

Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7 N-1e
Preparer: wmb Reviewer:

```

$end
$nfilt_remove3
filt_remove3=
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
9.900e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 9.900e-1, 9.900e-1, 9.900e-1, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
$end
$occupcupbr
occupancy = 10*1.0,
br = 10*3.47e-4,
$end
$control
filt_cr = 24684.0, unfilt_cr = 74.8,
filt_remove_cr = 0.9900, 0.9817, 0.99, 8*0.0,
filt_recirc_cr = 0.9333, 0.7333, 0.99, 8*0.0,
exhaust_cr = 24758.8, recirc_cr= 1.066e+5,
$end
$read
itime_step = 2, iunfilt = 1, ifilt =1, ifilt_remove = 0,0,0,0,7*0,
iremove = 0,ibreath_rate = 0, ioccupancy =0, icontrol = 1,
$end
$unfilt_flow
unfilt_flow =
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
1.470e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 1.130e-4, 4.260e-3, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 9.170e+3, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
$end
$filt_flow
filt_flow =
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
2.730e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 8.480e-3, 3.180e-1, 3.550e+4, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
$end
$control
filt_cr = 24684.0, unfilt_cr = 74.8,
filt_remove_cr = 0.9900, 0.9817, 0.99, 8*0.0,
filt_recirc_cr = 0.9333, 0.7333, 0.99, 8*0.0,
exhaust_cr = 24758.8, recirc_cr= 1.066e+5,
$end
$read
itime_step = 3, iunfilt = 1, ifilt =1, ifilt_remove = 0,0,0,0,7*0,
iremove = 0,ibreath_rate = 0, ioccupancy =0, icontrol = 1,

```

Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7 N-1f
Preparer: wmb Reviewer:

```
$end
$unfilt_flow
  unfilt_flow =
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
1.470e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 1.130e-4, 3.330e-3, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 9.170e+3, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 1.400e+1, 4.110e+2, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
$end
$nfilt_flow
  filt_flow =
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
2.730e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 8.480e-3, 2.490e-1, 3.550e+4, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
$end
$control
  filt_cr = 24684.0, unfilt_cr = 74.8,
  filt_remove_cr = 0.9900, 0.9817, 0.99, 8*0.0,
  filt_recirc_cr = 0.9333, 0.7333, 0.99, 8*0.0,
  exhaust_cr = 24758.8, recirc_cr= 1.066e+5,
$end
$read
  itime_step = 4, iunfilt = 1, ifilt =1, ifilt_remove = 0,0,0,0,7*0,
  iremove = 0, ibreath_rate = 1, ioccupancy =1, icontrol = 1,
$end
$unfilt_flow
  unfilt_flow =
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 9.170e+3, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
$end
$nfilt_flow
  filt_flow =
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 3.550e+4, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
$end
$occupbr
```

Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7 N-1g
Preparer: wmb Reviewer:

```
occupancy = 10*1.0,
br = 8*3.47e-4, 2*1.75e-4,
$end
$ncontrol
filt_cr = 24684.0, unfilt_cr = 74.8,
filt_remove_cr = 0.9900, 0.9817, 0.99, 8*0.0,
filt_recirc_cr = 0.9333, 0.7333, 0.99, 8*0.0,
exhaust_cr = 24758.8, recirc_cr= 1.066e+5,
$end
$nread
itime_step = 5, iunfilt = 0, ifilt =0, ifilt_remove = 0,0,0,0,7*0,
iremove = 0,ibreath_rate = 1, ioccupancy =1, icontrol = 1,
$end
$nooccupbr
occupancy = 8*0.6, 2*1.0,
br = 8*3.47e-4, 2*2.32e-4,
$end
$ncontrol
filt_cr = 24684.0, unfilt_cr = 74.8,
filt_remove_cr = 0.9900, 0.9817, 0.99, 8*0.0,
filt_recirc_cr = 0.9333, 0.7333, 0.99, 8*0.0,
exhaust_cr = 24758.8, recirc_cr= 1.066e+5,
$end
$nread
itime_step = 6, iunfilt = 0, ifilt =0, ifilt_remove = 0,0,0,0,7*0,
iremove = 0,ibreath_rate = 1, ioccupancy =1, icontrol = 1,
$end
$nooccupbr
occupancy = 8*0.4, 2*1.0,
br = 8*3.47e-4, 2*2.32e-4,
$end
$ncontrol
filt_cr = 24684.0, unfilt_cr = 74.8,
filt_remove_cr = 0.9900, 0.9817, 0.99, 8*0.0,
filt_recirc_cr = 0.9333, 0.7333, 0.99, 8*0.0,
exhaust_cr = 24758.8, recirc_cr= 1.066e+5,
$end
```

Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7 N-1h
Preparer: wmb Reviewer:

#

Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7 N-1i

Preparer: wmb

Reviewer:

*****TRACI VER. 1.0*****

Transient Radiological Assessment Code for

Isotopes

SOUTH TEXAS ELECTRIC GENERATING STATION

SEPTEMBER 24, 1992

CREATED BY WM. MARK BLUMBERG

RELOAD ENGINEERING SECTION

TRACI VERSION 1.0

JSN 44975

Mar 27 1996 08:25:45

page N - 1

calc. title: Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7

preparer: wmb

GENERAL DATA

preparer	wmb	preparer initials
iinode8	2	use node 8 0=no/ 1 =yes, treat as a region, 2=yes, model as control room
ioffsite	1	calculate offsite dose 0=no/1=yes

OUTPUT OPTIONS

PRINT FLAGS 0 = NO / 1 = YES

print_dc	1	print dose conversion factors
print_instantaneous_activity	0	print inst. activity for each time step as a function of isotope and node
print_instantaneous_dose_rate	0	print inst. dose rate for each time step as a function of isotope and node
print_instantaneous_dose	0	print accumulated dose for each time step as a function of isotope and node
print_cumulative_dose	0	print cumulative dose up to the ending time of each time step as a function of isotope and node
print_summary_dose	1	print summary of cumulative dose for all time steps as a function of whole body, skin & thyroid doses
idebug	0	print namelist variables as read in
print_laserjet	1	print laserjet compressed print
sub_time_step	.100E+02	time interval of sub_time_steps (in sec) note: if = 0.0, default time steps are used

TRACI VERSION 1.0

JSN 44975

Mar 27 1996 08:25:45 page N - 2
calc. title: Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7
preparer: wmb

SOURCE TERM

num_isotope	13	number of isotopes (default 27, max 50)
iactivity_unit	0 : Ci	units of act. of source term 0=Ci / 1= Ci/ml / 2 = Bq / 3 = Bq/m3
num_sources	1	number of sources at shutdown
fract_activity_node	.10E+01 .90E-06	fract. of total activity in each node
	.17E-05 .00E+00	
	.00E+00 .00E+00	
	.00E+00 .00E+00	
fract_release	.91E+00 .40E-01	fract. released from each isotope group
	.50E-01 .10E+01	
	.10E+01	

Note: the echo of fract_activity_node gives 8 values. Only "num_nodes" values will be used.

TRACI VERSION 1.0

JSN 44975

Mar 27 1996 08:25:45 page N - 3
calc. title: Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7
preparer: wmb

SOURCE #1

activity1_name	rcs	name of source and reference #
activity1	see note below	activity of source term at shutdown
activity1_unit	Ci	units of activity of source
activity1_mult	1.000	value multiplied by activity1 to get units of iactivity_unit
activity1_mult_unit		units of activity1_mult

note: values for activity1, activity2, & activity3 are given in table entitled: "calculation of initial activities"

TRACI VERSION 1.0

JSN 44975

Mar 27 1996 08:25:45

page N - 4

calc. title: Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7

preparer: wmb

NODES

num_nodes 5 number of nodes (max 7). Note: nodes
 8,9 & 10 are reserved for cr, epz and lpz

node_volume_unit 3 unit of node vol. 1=m3/ 2=ft3 /3=gallons

flow_unit 3 unit of flow 1=cu. m/sec, 2=cfm/ 3=gpm

ispray_cutoff 0 auto. spray cutoff option 0=no/ 1=yes

spray_df .0 .0 spray decon. factor (for each isotope grp)

.0 .0

.0 .0

.0 .0

.0 .0

.0

NODE VOLUMES (gal) AND GEOMETRY FACTORS (dimensionless)

NODE	1	2	3	4	5
------	---	---	---	---	---

NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV
VOLUME	.6880E+05	.1660E+05	.4970E+05	.3600E+06	.1000E+07
GF*	.1000E+01	.1000E+01	.1000E+01	.3067E+02	.1000E+01

NODE	6	7	8	9	10
------	---	---	---	---	----

NODE NAME	node 66666	node 77777	control rm	epz	lpz
VOLUME	.0000E+00	.0000E+00	.2050E+07		
GF*	.1000E+01	.1000E+01	.1703E+02		

Notes: Format for echo of spray_df is f7.1, ie.

values of spray_dcf >99,999.9 will not echo properly.

* If "geometry_factor" is entered as zero or not entered a geometry factor is calculated, otherwise the value entered is used.

TRACI VERSION 1.0

JSN 44975

Mar 27 1996 08:25:45 page N - 5
calc. title: Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7
preparer: wmb

TIME STEPS

num_tsteps 5 number of time steps
tstep_unit 1:hours units of time steps 0=sec/ 1=hr. / 2=days
ieq_tstep 0 equal time step 0 = no, input times in
variable "tstep"/ 1 = yes
sdtime .0000E+00 time between shutdown and beginning of
first time step
first_tstep .0000E+00 time of beginning of first time step
(units of tstep_unit)
last_tstep .9600E+02 time of end of last time_step
(units of tstep_unit)
tstep see table below beginning time of 5 time steps
(required only if ieq_tstep=0
ie. unequal time steps are used)

TIME STEP NUMBER	BEGINNING		TIME STEP NUMBER	BEGINNING	
	TIME (hours)	TIME (hours)		TIME (hours)	TIME (hours)
1	.0000E+00		3	.2000E+01	
2	.5000E+00		4	.8000E+01	
5	.2400E+02				

TRACI VERSION 1.0
calc. title: Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7
JSN 44975

Mar 27 1996 08:25:46 page N - 6
preparer: wmb

TIME STEP (hours)	CONTROL RM	CH1/Q (sec/cubic meter)		NODE 10 LP2
		NODE 8 EP2	NODE 9 EP2	
.0000E+00 to .5000E+00	.5000E+00	-1060E-02	-1300E-03	-3800E-04
.5000E+00 to .2000E+01	.2000E+01	-1060E-02	-1300E-03	-3800E-04
.2000E+01 to .8000E+01	.8000E+01	-1060E-02	.0000E+00	-1600E-04
.8000E+01 to .2400E+02	.2400E+02	.0000E+00	.0000E+00	-1100E-04
.2400E+02 to .9600E+02	.9600E+02	.0000E+01	.0000E+00	.4300E-05

TRACI VERSION 1.0

JSN 44975

Mar 27 1996 08:25:46 page N - 7

calc. title: Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7

preparer: wmb

DOSE CONVERSION FACTORS AND DECAY CONSTANTS

DOSE CONVERSION FACTORS				
ISOTOPE GROUP	DECAY CONSTANT (1/sec)	THYROID (rem/Ci)	BETA SKIN (rem * cu. meter)/(Ci * sec)	WHOLE BODY
Kr--83m	4	.105E-03	.000E+00	.240E-05
Kr--85m	4	.430E-04	.000E+00	.463E-01
Kr---85	4	.205E-08	.000E+00	.425E-01
Kr---87	4	.151E-03	.000E+00	.510E-03
Kr---88	4	.673E-04	.000E+00	.188E+00
Kr---89	4	.363E-02	.000E+00	.751E-01
Xe-131m	4	.682E-06	.000E+00	.466E+00
Xe-133m	4	.366E-05	.000E+00	.526E+00
Xe-133	4	.153E-05	.000E+00	.151E-01
Xe-135m	4	.738E-03	.000E+00	.290E-02
Xe--135	4	.211E-04	.000E+00	.932E-02
Xe--137	4	.302E-02	.000E+00	.989E-01
Xe--138	4	.815E-03	.000E+00	.538E-01

TRAC! VERSION 1.0
calc. title: Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7

JSN 44975
Mar 27 1996 08:25:46 page N - 8
MSLB Accident Nobles only, .42 gpm, HVAC 7
preparer: wmb

CALCULATION OF INITIAL ACTIVITIES - BEFORE SHUTDOWN

SOURCE NAME	UNITS	NUMBER	ISOTOPE	GROUP	COL. 1	COL. 2	COL. 3	COL. 4	COL. 5	COL. 6	COL. 7
	rcs		ci								
1	Kr-83m	4	-7000E+05	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.7000E+05
2	Kr-85m	4	.1500E+06	.1000E-01	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.1500E+06
3	Kr---85	4	.1850E+05	.1000E-01	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.1850E+05
4	Kr---87	4	.2750E+06	.1000E-01	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.2750E+06
5	Kr---86	4	.3950E+06	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.3950E+06
6	Kr---89	4	.4850E+06	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.4850E+06
7	Xe-131m	4	.3850E+04	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.3850E+04
8	Xe-133m	4	.1650E+06	.1000E-01	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.1650E+06
9	Xe-133	4	.1150E+07	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.1150E+07
10	Xe-135m	4	.2300E+06	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.2300E+06
11	Xe-135	4	.3250E+06	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.3250E+06
12	Xe-137	4	.1000E+07	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.1000E+07
13	Xe-138	4	.9500E+06	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.9500E+06

note: col. 7 = (col. 1*col. 2 + col. 3*col.4 + col. 5*col. 6)

TRACI VERSION 1.0
calc. title: Case C4-nc5061, rev. 1, MSLB Accident Nables only, .42 gpm, HVAC 7

JSN 44975
Mar 27 1996 08:25:46
page N - 9
preparer: wmb

NODAL DISTRIBUTION OF INITIAL ACTIVITIES - BEFORE SHUTDOWN (Ci)

NODES	1	2	3	4	5	8
NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm
ISOTOPE GROUP						
Kr--83m	4	.700E+05	.630E-01	.117E+00	.000E+00	.000E+00
Kr--85m	4	.150E+06	.135E+00	.250E+00	.000E+00	.000E+00
Kr--85	4	.185E+05	.166E-01	.309E-01	.000E+00	.000E+00
Kr--87	4	.275E+06	.247E+00	.459E+00	.000E+00	.000E+00
Kr--88	4	.395E+06	.355E+00	.660E+00	.000E+00	.000E+00
Kr--89	4	.485E+06	.436E+00	.810E+00	.000E+00	.000E+00
Xe-131m	4	.385E+04	.346E-02	.643E-02	.000E+00	.000E+00
Xe-133m	4	.165E+06	.148E+00	.276E+00	.000E+00	.000E+00
Xe-133	4	.115E+07	.103E+01	.192E+01	.000E+00	.000E+00
Xe-135m	4	.230E+06	.207E+00	.384E+00	.000E+00	.000E+00
Xe-135	4	.325E+06	.292E+00	.563E+00	.000E+00	.000E+00
Xe--137	4	.100E+07	.900E+00	.167E+01	.000E+00	.000E+00
Xe--138	4	.950E+06	.855E+00	.159E+01	.000E+00	.000E+00

TRACI VERSION 1.0
calc. title: Case C4-nc6061, rev. 1, MSLB Accident Nables only, .42 gpm, HVAC 7

JSN 44975

Mar 27 1996 08:25:46 page N - 10
preparer: web

ACTIVITIES - AFTER .0000E+00 hours (Ci)							
NODES	1	2	3	4	5	6	
NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm	
Kr--83m	4	.700E+05	.630E-01	.117E+00	.000E+00	.000E+00	
Kr--85m	4	.150E+06	.135E+00	.250E+00	.000E+00	.000E+00	
Kr---85	4	.185E+05	.166E-01	.309E-01	.000E+00	.000E+00	
Kr---87	4	.275E+06	.247E+00	.459E+00	.000E+00	.000E+00	
Kr---88	4	.395E+06	.355E+00	.660E+00	.000E+00	.000E+00	
Kr---89	4	.485E+06	.436E+00	.810E+00	.000E+00	.000E+00	
Xe-131m	4	.385E+04	.346E-02	.643E-02	.000E+00	.000E+00	
Xe-133m	4	.165E+06	.148E+00	.276E+00	.000E+00	.000E+00	
Xe--133	4	.115E+07	.103E+01	.192E+01	.000E+00	.000E+00	
Xe-135m	4	.230E+06	.207E+00	.384E+00	.000E+00	.000E+00	
Xe--135	4	.325E+06	.292E+00	.543E+00	.000E+00	.000E+00	
Xe--137	4	.100E+07	.900E+00	.167E+01	.000E+00	.000E+00	
Xe--138	4	.950E+06	.855E+00	.159E+01	.000E+00	.000E+00	

TRACI VERSION 1.0

JSM 44975

Mar 27 1996 08:25:46

page N - 11

calc. title: Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7

preparer: wmb

TIME STEP NUMBER 1 - .0000E+00 to .5000E+00 (hours)

TIME DEPENDENT INPUT
(REPEATED FOR EACH TIME STEP)

itime_step	1	time step which corresponds to the time dependent data.
iunfilt	1	read in unfiltered flow data for this time step 0 = no / 1 = yes
ifilt	1	read in filtered flow data for this time step 0 = no / 1 = yes
ifilt_remove	1 1 1 0 0 0 0 0 0 0 0	read in filter removal effic. for each isotope group for this time step. 0 = no / 1= yes ie. (ifilt_remove(1)=1 : read in group 1 data)
iremove	0	read in removal constants for this time step 0 = no/ 1 = yes (in units "1/tstep_unit") (1/hours)
ioccupancy	1	read in occupancy factors for this time step 0 = no/ 1 = yes (in units of %/day)
ibreath_rate	1	read in breathing rates for this time step 0 = no/ 1 = yes (in units of m ³ /sec)
icontrol	1	read in control room data 0 = no/ 1 = yes

TRACI VERSION 1.0

JSN 44975

Mar 27 1996 08:25:46

page N - 12

calc. title: Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7

preparer: wmb

TIME STEP NUMBER 1 - .0000E+00 to .5000E+00 (hours)

UNFILTERED FLOW RATE BETWEEN NODES - VARIABLE "UNFILT_FLOW" (gpm)

TO NODES	1	2	3	4	5	8		
NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm	environment	
FROM NODE								
1	.000E+00	.147E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	
2	.000E+00	.000E+00	.000E+00	.692E-02	.000E+00	.000E+00	.854E+03	
3	.000E+00	.000E+00	.000E+00	.426E-02	.000E+00	.000E+00	.526E+03	
4	.000E+00	.000E+00	.000E+00	.000E+00	.917E+04	.000E+00	.000E+00	
5	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	
8	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	

FILTERED FLOW RATE BETWEEN NODES - VARIABLE "FILT_FLOW" (gpm)

TO NODES	1	2	3	4	5	8		
NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm	environment	
FROM NODE								
1	.000E+00	.000E+00	.273E+00	.000E+00	.000E+00	.000E+00	.000E+00	
2	.000E+00	.000E+00	.000E+00	.517E+00	.000E+00	.000E+00	.000E+00	
3	.000E+00	.000E+00	.000E+00	.318E+00	.000E+00	.000E+00	.000E+00	
4	.000E+00	.000E+00	.000E+00	.355E+05	.000E+00	.000E+00	.000E+00	
5	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	
8	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	

note: a flow rate from node x to node x represents recirculation flow

TRACI VERSION 1.0 JSON 44975
calc. title: Case C4-nc0061. rev. 1. MSIB Accident Nobles only. 42 qm. HVAC 7
preparer: wmb
Mar 27 1996 08:25:46 page N = 14

TIME STEP NUMBER 1 - 0000E+00 10 5000E+00 (hours)

TIME STEP NUMBER 1 - 00000F+00 00 5000E+00 / hours

```

FOR: PART_1
      FILTERED REMOVAL EFFICIENCY BETWEEN NODES "FLIT_FLOW_REMOVE" ( IN EFFICIENCY FRACTION )

```

BREATHEING RATE (MIN/SEC) OCCUPANCY FACTORS (%/TIME STEPS)

TRACI VERSION 1.0

JSN 44975

Mar 27 1996 08:25:47 page N - 15

calc. title: Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7

preparer: wmb

TIME STEP NUMBER 1 - .0000E+00 to .5000E+00 (hours)

CONTROL ROOM FILTER EFFICIENCY FRACTION AND FLOW (gpm) - MODEL 2

filt_cr .2468E+05 filtered intake rate
unfilt_cr .7480E+02 unfiltered intake rate
recirc_cr .1066E+06 recirculation rate
exhaust_cr .2476E+05 exhaust rate from control room

ISOTOPE GROUP FILTER EFFICIENCY FRACTION
INTAKE RECIRCULATION

ELEM. I	.9900E+00	.9333E+00
ORG. I	.9817E+00	.7333E+00
PART. I	.9900E+00	.9900E+00
NOB. GAS	.0000E+00	.0000E+00
Cs, Rb	.0000E+00	.0000E+00
Te, Se	.0000E+00	.0000E+00
S, Ba	.0000E+00	.0000E+00
NOB. MET.	.0000E+00	.0000E+00
RARE EARTH	.0000E+00	.0000E+00
MISC.	.0000E+00	.0000E+00
HALOGENS	.0000E+00	.0000E+00

TRACE VERSION 1.0

JSN 44975

calc. title: Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7

Mar 27 1996 08:25:49

page N - 16

preparer: wmb

TIME STEP NUMBER 2 - .5000E+00 to .2000E+01 (hours)

TIME DEPENDENT INPUT
(REPEATED FOR EACH TIME STEP)

itime_step	2	time step which corresponds to the time dependent data
iunfilt	1	read in unfiltered flow data for this time step 0 = no / 1 = yes
ifilt	1	read in filtered flow data for this time step 0 = no / 1 = yes
ifilt_remove	0 0 0 0 0 0 0 0 0 0 0	read in filter removal effic. for each isotope group for this time step. 0 = no / 1= yes ie. (ifilt_remove(1)=1 : read in group 1 data)
iremove	0	read in removal constants for this time step 0 = no/ 1 = yes (in units "1/tstep_unit") (1/hours)
ioccupancy	0	read in occupancy factors for this time step 0 = no/ 1 = yes (in units of %/day)
ibreath_rate	0	read in breathing rates for this time step 0 = no/ 1 = yes (in units of m ³ /sec)
icontrol	1	read in control room data 0 = no/ 1 = yes

TRACI VERSION 1.0

calc. title: Case C4-ncd6061, rev. 1, MSLB Accident Nables only, .42 gpm, HVAC 7

TIME STEP NUMBER 2 - .5000E+00 to .2000E+01 (hours)

JSN 44975

Mar 27 1996 08:25:50 page N - 17
preparer: wmb

UNFILTERED FLOW RATE BETWEEN NODES - VARIABLE "UNFILT_FLOW" (gpm)

TO NODES	1	2	3	4	5	8
FROM NODE	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm environment
1	.000E+00	.147E+00	.000E+00	.000E+00	.000E+00	.000E+00
2	.000E+00	.000E+00	.000E+00	.113E-03	.000E+00	.140E+02
3	.000E+00	.000E+00	.000E+00	.426E-02	.000E+00	.526E+03
4	.000E+00	.000E+00	.000E+00	.000E+00	.917E+04	.000E+00
5	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
8	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00

FILTERED FLOW RATE BETWEEN NODES - VARIABLE "FILT_FLOW" (gpm)

TO NODES	1	2	3	4	5	8
FROM NODE	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm environment
1	.000E+00	.000E+00	.-273E+00	.000E+00	.000E+00	.000E+00
2	.000E+00	.000E+00	.000E+00	.848E-02	.000E+00	.000E+00
3	.000E+00	.000E+00	.000E+00	.318E+00	.000E+00	.000E+00
4	.000E+00	.000E+00	.000E+00	.355E+05	.000E+00	.000E+00
5	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
8	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00

note: a flow rate from node x to node y represents recirculation flow

TRACI VERSION 1.0

JSN 44975

Mar 27 1996 08:25:50 page N - 18
calc. title: Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7
preparer: wmb

TIME STEP NUMBER 2 - .5000E+00 to .2000E+01 (hours)

CONTROL ROOM FILTER EFFICIENCY FRACTION AND FLOW (gpm) - MODEL 2

filt_cr .2468E+05 filtered intake rate
unfilt_cr .7480E+02 unfiltered intake rate
recirc_cr .1066E+06 recirculation rate
exhaust_cr .2476E+05 exhaust rate from control room

ISOTOPE GROUP FILTER EFFICIENCY FRACTION
INTAKE RECIRCULATION

ELEM. I	.9900E+00	.9333E+00
ORG. I	.9817E+00	.7333E+00
PART. I	.9900E+00	.9900E+00
NOB. GAS	.0000E+00	.0000E+00
Cs, Rb	.0000E+00	.0000E+00
Te, Se	.0000E+00	.0000E+00
Sr, Ba	.0000E+00	.0000E+00
NOB. MET.	.0000E+00	.0000E+00
RARE EARTH	.0000E+00	.0000E+00
MISC.	.0000E+00	.0000E+00
HALOGENS	.0000E+00	.0000E+00

TRACI VERSION 1.0

JSN 44975

Mar 27 1996 08:25:58 page N - 19
calc. title: Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7
preparer: wmb

TIME STEP NUMBER 3 - .2000E+01 to .8000E+01 (hours)

TIME DEPENDENT INPUT
(REPEATED FOR EACH TIME STEP)

itime_step	3	time step which corresponds to the time dependent data
iunfilt	1	read in unfiltered flow data for this time step 0 = no / 1 = yes
ifilt	1	read in filtered flow data for this time step 0 = no / 1 = yes
ifilt_remove	0 0 0 0 0 0 0 0 0 0 0	read in filter removal effic. for each isotope group for this time step. 0 = no / 1= yes ie. (ifilt_remove(1)=1 : read in group 1 data)
iremove	0	read in removal constants for this time step 0 = no/ 1 = yes (in units "1/tstep_unit") (1/hours)
ioccupancy	0	read in occupancy factors for this time step 0 = no/ 1 = yes (in units of %/day)
ibreath_rate	0	read in breathing rates for this time step 0 = no/ 1 = yes (in units of m ³ /sec)
icontrol	1	read in control room data 0 = no/ 1 = yes

TRACI VERSION 1.0

calc. title: Case C4.ncd601, rev. 1, HSLB Accident Hobies only, .42 gpm, HVAC 7

TIME STEP NUMBER 3 - .2000E+01 to .8000E+01 (hours)

JSN 44975

Mar 27 1996 08:25:59 page N - 20
preparer: wmb

UNFILTERED FLOW RATE BETWEEN NODES - VARIABLE "UNFILT_FLOW" (gpm)

TO NODES	1	2	3	4	5	6	7	8
FROM NODE	NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm	environment
1		.000E+00	.147E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
2		.000E+00	.000E+00	.000E+00	.113E-03	.000E+00	.000E+00	.140E+02
3		.000E+C0	.000E+00	.000E+00	.333E-02	.000E+00	.000E+01	.411E-03
4		.000E+00	.000E+00	.000E+00	.000E+00	.917E+04	.000E+00	.000E+00
5		.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
6		.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
7		.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
8		.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00

FILTERED FLOW RATE BETWEEN NODES - VARIABLE "FILT_FLOW" (gpm)

TO NODES	1	2	3	4	5	6	7	8
FROM NODE	NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm	environment
1		.000E+00	.273E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
2		.000E+00	.000E+00	.000E+00	.848E-02	.0C3E+00	.000E+00	.000E+00
3		.000E+00	.000E+00	.000E+00	.249E+00	.000E+00	.000E+00	.000E+00
4		.000E+00	.000E+00	.000E+00	.355E+05	.000E+00	.000E+00	.000E+00
5		.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
6		.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
7		.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
8		.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00

note: a flow rate from node x to node y represents recirculation flow

TRACI VERSION 1.0

JSN 44975

Mar 27 1996 08:25:59 page N - 21
calc. title: Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7
preparer: wmb

TIME STEP NUMBER 3 + .2000E+01 to .8000E+01 (hours)

CONTROL ROOM FILTER EFFICIENCY FRACTION AND FLOW (gpm) - MODEL 2

filt_cr .2468E+05 filtered intake rate
unfilt_cr .7480E+02 unfiltered intake rate
recirc_cr .1066E+06 recirculation rate
exhaust_cr .2476E+05 exhaust rate from control room

ISOTOPE GROUP FILTER EFFICIENCY FRACTION
INTAKE RECIRCULATION

ELEM. I	.9900E+00	.9333E+00
ORG. I	.9817E+00	.7333E+00
PART. I	.9900E+00	.9900E+00
NOB. GAS	.0000E+00	.0000E+00
Cs, Rb	.0000E+00	.0000E+00
Te, Se	.0000E+00	.0000E+00
Sr, Ba	.0000E+00	.0000E+00
NOB. MET.	.0000E+00	.0000E+00
RARE EARTH	.0000E+00	.0000E+00
MISC.	.0000E+00	.0000E+00
HALOGENS	.0000E+00	.0000E+00

TRACI VERSION 1.0

JSN 44975

Mar 27 1996 08:26:33

page N - 22

preparer: wmb

calc. title: Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7

TIME STEP NUMBER 4 - .8000E+01 to .2400E+02 (hours)

TIME DEPENDENT INPUT
(REPEATED FOR EACH TIME STEP)

itime_step	4	time step which corresponds to the time dependent data
iunfilt	1	read in unfiltered flow data for this time step 0 = no / 1 = yes
ifilt	1	read in filtered flow data for this time step 0 = no / 1 = yes
ifilt_remove	0 0 0 0 0 0 0 0 0 0 0	read in filter removal effic. for each isotope group for this time step. 0 = no / 1= yes ie. (ifilt_remove(1)=1 : read in group 1 data)
iremove	0	read in removal constants for this time step 0 = no/ 1 = yes (in units "1/tstep_unit") (1/hours)
ioccupancy	1	read in occupancy factors for this time step 0 = no/ 1 = yes (in units of %/day)
ibreath_rate	1	read in breathing rates for this time step 0 = no/ 1 = yes (in units of m ³ /sec)
icontrol	1	read in control room data 0 = no/ 1 = yes

page N - 23
prepareer: mnb

Mar 27 1996 08:26:33

ISSN 47975

TRACI VERSION 1.0

1

TITAN

UNFILTERED FLOW RATE BETWEEN NODES - VARIABLE "UNFILT_FLOW" (9PM)

FILTERED FLOW RATE BETWEEN NODES = VARIABLE INFILT FLOW (gpm)

note: a flow rate from node x to node y represents recirculation flow

BREATHING RATE (M³/SEC) - OCCUPANCY FACTORS (%/TIME STEP)

TRACI VERSION 1.0

JSN 44975

Mar 27 1996 08:26:33 page N - 24
calc. title: Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7
preparer: wmb

TIME STEP NUMBER 4 - .8000E+01 to .2400E+02 (hours)

CONTROL ROOM FILTER EFFICIENCY FRACTION AND FLOW (gpm) - MODEL 2

filt_cr	.2468E+05	filtered intake rate
unfilt_cr	.7480E+02	unfiltered intake rate
recirc_cr	.1066E+06	recirculation rate
exhaust_cr	.2476E+05	exhaust rate from control room

ISOTOPE GROUP FILTER EFFICIENCY FRACTION
INTAKE RECIRCULATION

ELEM. I	.9900E+00	.9333E+00
ORG. I	.9817E+00	.7333E+00
PART. I	.9900E+00	.9900E+00
NOB. GAS	.0000E+00	.0000E+00
Cs, Rb	.0000E+00	.0000E+00
Te, Se	.0000E+00	.0000E+00
Sr, Ba	.0000E+00	.0000E+00
NOB. MET.	.0000E+00	.0000E+00
RARE EARTH	.0000E+00	.0000E+00
MISC.	.0000E+00	.0000E+00
HALOGENS	.0000E+00	.0000E+00

TRACE VERSION 1.0

JSN 44975

Mar 27 1996 08:28:46

page N - 25

calc. title: Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7

preparer: wmb

TIME STEP NUMBER 5 - .2400E+02 to .9600E+02 (hours)

TIME DEPENDENT INPUT
(REPEATED FOR EACH TIME STEP)

itime_step 5 time step which corresponds
 to the time dependent data
 iunfilt 0 read in unfiltered flow data for this time step
 0 = no / 1 = yes
 ifilt 0 read in filtered flow data for this time step
 0 = no / 1 = yes
 ifilt_remove 0 0 0 0 0 read in filter removal effic. for each isotope
 group for this time step. 0 = no / 1= yes
 0 ie. (ifilt_remove(1)=1 : read in group 1 data)
 iremove 0 read in removal constants for this time step
 0 = no/ 1 = yes (in units "1/tstep_unit")
 (1/hours)
 ioccupancy 1 read in occupancy factors for this time step
 0 = no/ 1 = yes (in units of %/day)
 ibreath_rate 1 read in breathing rates for this time step
 0 = no/ 1 = yes (in units of m3/sec)
 icontrol 1 read in control room data
 0 = no/ 1 = yes

BREATHING RATE (M3/SEC), OCCUPANCY FACTORS (%/TIME STEP)

NODES	1	2	3	4	5	8	9	10
NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm epz		lpz
BREATH. RATE	.347E-03	.347E-03	.347E-03	.347E-03	.347E-03	.347E-03	.232E-03	.232E-03
OCCUPANCY	.600E+00	.600E+00	.600E+00	.600E+00	.600E+00	.600E+00	.100E+01	.100E+01

TRACI VERSION 1.0

JSN 44975

Mar 27 1996 08:28:46 page N - 26
calc. title: Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7
preparer: wmb

TIME STEP NUMBER 5 - .2400E+02 to .9600E+02 (hours)

CONTROL ROOM FILTER EFFICIENCY FRACTION AND FLOW (gpm) - MODEL 2

filt_cr .2468E+05 filtered intake rate
unfilt_cr .7480E+02 unfiltered intake rate
recirc_cr .1066E+06 recirculation rate
exhaust_cr .2476E+05 exhaust rate from control room

ISOTOPE GROUP FILTER EFFICIENCY FRACTION
INTAKE RECIRCULATION

ELEM. I	.9900E+00	.9333E+00
ORG. I	.9817E+00	.7333E+00
PART. I	.9900E+00	.9900E+00
NOB. GAS	.0000E+00	.0000E+00
Cs, Rb	.0000E+00	.0000E+00
Te, Se	.0000E+00	.0000E+00
Sr, Ba	.0000E+00	.0000E+00
NOB. MET.	.0000E+00	.0000E+00
RARE EARTH	.0000E+00	.0000E+00
MISC.	.0000E+00	.0000E+00
HALOGENS	.0000E+00	.0000E+00

TRACI VERSION 1.0 JSN 44975
calc. title: Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7

Mar 27 1996 08:37:14 page N - 27
preparer: wmb

NODE NAME : RCS

SUMMARY OF CUMULATIVE DOSE FOR NODE 1 (REW) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.0000E+00	.3114E+07	.2111E+07
.5000E+00 to .2000E+01	.0000E+00	.7489E+07	.4456E+07
.2000E+01 to .8000E+01	.0000E+00	.1504E+08	.8688E+07
.8000E+01 to .2400E+02	.0000E+00	.2028E+08	.1381E+08
.2400E+02 to .9600E+02	.0000E+00	.2561E+08	.2092E+08

TRACI VERSION 1.0

JSN 44975

Mar 27 1996 08:37:14 page N - 28

calc. title: Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7

preparer: wmb

NODE NAME: AFF. SG

SUMMARY OF CUMULATIVE DOSE FOR NODE 2 (REM) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.0000E+00	.3604E+03	.2154E+03
.5000E+00 to .2000E+01	.0000E+00	.3112E+04	.1686E+04
.2000E+01 to .8000E+01	.0000E+00	.2088E+05	.1192E+05
.8000E+01 to .2400E+02	.0000E+00	.4319E+05	.3376E+05
.2400E+02 to .9600E+02	.0000E+00	.6588E+05	.6402E+05

TRACI VERSION 1.0

JSN 44975

Mar 27 1996 08:37:15 page N - 29
calc. title: Case C4-nc6961, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7
preparer: wmb

NODE NAME: UNAFF SG

SUMMARY OF CUMULATIVE DOSE FOR NODE 3 (REM) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.0000E+00	.2236E+03	.1337E+03
.5000E+00 to .2000E+01	.0000E+00	.1930E+04	.1046E+04
.2000E+01 to .8000E+01	.0000E+00	.1294E+05	.7390E+04
.8000E+01 to .2400E+02	.0000E+00	.2677E+05	.2092E+05
.2400E+02 to .9600E+02	.0000E+00	.4082E+05	.3967E+05

TRACI VERSION 1.0
calc. title: Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7

JSN 44975
Mar 27 1996 08:37:15 page N - 30
preparer: wmb

NODE NAME: TSC

SUMMARY OF CUMULATIVE DOSE FOR NODE 4 (REM) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.0000E+00	.1870E-03	.3275E-02
.5000E+00 to .2000E+01	.0000E+00	.1612E-02	.2663E-01
.2000E+01 to .8000E+01	.0000E+00	.1067E-01	.1871E+00
.8000E+01 to .2400E+02	.0000E+00	.1160E-01	.2076E+00
.2400E+02 to .9600E+02	.0000E+00	.1160E-01	.2076E+00

TRACI VERSION 1.0
calc. title: Case C4-nc606i, rev. 1, MSIB Accident Nables only, .42 gpm, HVAC 7

JSN 44975
page N - 31
preparer: wmb

Mar 27 1996 08:37:15

NODE NAME: DUMMY ENV

SUMMARY OF CUMULATIVE DOSE FOR NODE 5 (REM) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.0000E+00	.3987E-03	.2225E-03
.5000E+00 to .2000E+01	.0000E+00	.1703E-01	.9089E-02
.2000E+01 to .8000E+01	.0000E+00	.3997E+00	.2358E+00
.8000E+01 to .2400E+02	.0000E+00	.1300E+01	.1119E+01
.2400E+02 to .9600E+02	.0000E+00	.2226E+01	.2354E+01

TRACI VERSION 1.0
calc. title: Case C4-nc6061, rev. 1, MSLB Accident Nables only, .42 gpm, HVAC 7

JSN 44975
Mar 27 1996 08:37:15 page N - 32
preparer: wmb

NODE NAME: control rm

SUMMARY OF CUMULATIVE DOSE FOR NODE 8 (REM) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.0000E+00	.1747E-03	.1696E-02
.5000E+00 to .2000E+01	.0000E+00	.1892E-02	.1723E-01
.2000E+01 to .8000E+01	.0000E+00	.1565E-01	.1533E+00
.8000E+01 to .2400E+02	.0000E+00	.1859E-01	.1906E+00
.2400E+02 to .9600E+02	.0000E+00	.1859E-01	.1906E+00

TRACI VERSION 1.0
calc. title: Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7

JSN 44975
page N - 33
preparer: wmt

Mar 27 1996 08:37:15

NODE NAME: epz

SUMMARY OF CUMULATIVE DOSE FOR NODE 9 (REM) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.0000E+00	.3639E-02	.2086E-02
.5000E+00 to .2000E+01	.0000E+00	.1117E-01	.6189E-02
.2000E+01 to .8000E+01	.0000E+00	.1117E-01	.6189E-02
.8000E+01 to .2400E+02	.0000E+00	.1117E-01	.6189E-02
.2400E+02 to .9600E+02	.0000E+00	.1117E-01	.6189E-02

TRACI VERSION 1.0
calc. title: Case C4-nc6061, rev. 1, MSLB Accident Nobles only, .42 gpm, HVAC 7

JSN 44975
page N - 34
preparer: wmb

Mar 27 1996 08:37:15

NODE NAME: lpz

SUMMARY OF CUMULATIVE DOSE FOR NODE 10 (REM) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.0000E+00	.1020E-02	.6096E-03
.5000E+00 to .2000E+01	.0000E+00	.3264E-02	.1809E-02
.2000E+01 to .8000E+01	.0000E+00	.8084E-02	.4586E-02
.8000E+01 to .2400E+02	.0000E+00	.8084E-02	.4586E-02
.2400E+02 to .9600E+02	.0000E+00	.8084E-02	.4586E-02

Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7 P-1a
Preparer: wmb Reviewer:

```
# ##### #####
## # # # # #
# # # # # #
# ##### #####
# # # # # #####
# # # # #
##### ##### #####
### ##### # ##### ##### # ##### #####
# # # # # # # # # # # # # # # #
# # ##### # ##### # # # ##### #####
# # # # # # # # # # # # # # #
# # # # # # # # # # # # # # #
### ##### # ##### # # # ##### #####
### ##### # ##### # ##### # # # ##### #####
# # # # # ##### # # # # # # # # #
# # # # # # # # # # # # # # #
# # ##### # ##### # ##### # # # #
# # # # # # # # # # # # # # #
# # # # # # # # # # # # # # #
# # # # # # # # # # # # # # #
### ##### # ##### # ##### # # # ##### #
```

```
*****
*           INSTALLATION OPERATING ENVIRONMENT *
* Wed Sep 13 07:54:03 CDT 1995 *
*
* AIX nfad 2 3 000510106700 *
* XLFCMP.OBJ fortran compiler version 02.03.0000.0000 *
* XLF RTE.OBJ fortran runtime environment version 02.03.0000.0000 *
*
*****
```

```
*****
*           CURRENT OPERATING ENVIRONMENT *
* Wed Mar 27 08:26:37 CST 1996 *
*
* AIX nfad 2 3 000510106700 *
* XLFCMP.OBJ fortran compiler version 02.03.0000.0000 *
* XLF RTE.OBJ fortran runtime environment version 02.03.0000.0000 *
*
*****
```

** RTE Verified **

Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7 P-1b
Preparer: wmb Reviewer:

```
##### ##### ## #####
# # # # # # #
# # # # # # #
# ##### ##### # #
# # # # # # # #
# # # # # # #####
# # # # # # # #
```



```
#
# # ## ## #
# # # # # #
# # # # # #
# # # # #####
# # # # # # #
## ##### ##### # #
```

Dose Conversion Factors "dcf_input.f" were User supplied

Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7 P-1c
Preparer: wmb Reviewer:

```
# # # ##### # # #####  
# ## # # # # # #  
# # # # # # # #  
# # # # ##### # #  
# # # # # # # #  
# # # # ##### #  
  
$ngeneral  
preparer = 'wmb',  
inode8 = 2,  
ioffsite =1,  
calc_title = 'Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7',  
page_prefix = 'P',  
print_dcf = 1,  
print_instantaneous_activity = 0,  
print_instantaneous_dose_rate = 0,  
print_instantaneous_dose =0,  
print_cumulative_dose = 0,  
print_summary_dose =1,  
print_laserjet = 1,  
idebug = 0,  
sub_time_step =10.0000,  
$end  
$nsource_term  
num_isotope= 13,  
iactivity_unit=0,  
num_sources=1,  
fract_activity_node= 1.0, 9.00e-7, 1.67e-6, 5*0.0,  
fract_release = .91, 4.0E-2, 5.0E-02, 8*1.0,  
$end  
$nsource1  
activity1_name='rcs ',  
activity1= 7.00e+4, 1.50e+5, 1.85e+4, 2.75e+5, 3.95e+5,  
        4.85e+5, 3.85e+3, 1.65e+5, 1.15e+6, 2.30e+5,  
        3.25e+5, 1.00e+6, 9.50e+5,  
activity1_unit= 'Ci ',  
activity1_mult=1.0 ,  
activity1_mult_unit= ' ',  
activity1_mult_name= ' '  
$end  
$nnodes  
num_nodes=5,  
node_volume_unit = 3,  
flow_unit = 3,  
ispray_cutoff = 0,  
spray_df = 11*0.0,  
node_name = ' RCS      ','AFF. SG   ','UNAFF SG ',  
          ' TSC     ','DUMMY ENV ','node 66666',  
          'node 77777','control rm','epz      ','lpz      ',  
node_volume = 6.88e+4,1.66e+4, 4.97e+4, 3.60e+5, 1e+6, 2*0.0, 2.050e+6,  
geometry_factor = 3*1.0,0.0,3*1.0, 0.0,  
$end  
$ntime_steps  
num_tsteps = 5,  
tstep_unit = 1,  
ieq_tstep = 0,  
sdtime = 0.0,  
first_tstep = 00.0 ,  
last_tstep = 96.,  
tstep = 0, .5, 2, 8, 24, 96,
```

Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7 P-1d
Preparer: wmb Reviewer:

```
$end
$inchi_over_q_cr
chi_over_q_control_room = 3*1.06e-3, 38*0.0,
$end
$inchi_over_q_offsite
chi_over_q_epz = 2*1.30e-4, 38*0.0,
chi_over_q_lpz = 2*3.80e-5, 1.6e-5, 1.1e-5, 4.3e-6, 1.2e-6, 34*0.0,
$end
$read
itime_step = 1, iunfilt = 1, ifilt =1, ifilt_remove = 1,1,1,0,7*0,
iremove = 0,ibreath_rate = 1, ioccupancy =1, icontrol = 1,
$end
$unfilt_flow
unfilt_flow =
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
1.010e+1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 7.000e-3, 4.260e-3, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 9.170e+3, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 8.640e+2, 5.260e+2, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
$end
$nfilt_flow
filt_flow =
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
2.730e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 5.230e-1, 3.180e-1, 3.550e+4, 0.000e+^, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
$end
$nfilt_remove1
filt_remove1=
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
9.900e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 9.900e-1, 9.900e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
$end
$nfilt_remove2
filt_remove2=
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
9.900e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 9.900e-1, 9.900e-1, 9.900e-1, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
```

Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7 P-1e
Preparer: wmb Reviewer:

```
$end
$nfilt_remove3
filt_remove3=
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
9.900e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 9.900e-1, 9.900e-1, 9.900e-1, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
$end
$noccupbr
occupancy = 10*1.0,
br = 10*3.47e-4,
$end
$control
filt_cr = 24684.0, unfilt_cr = 74.8,
filt_remove_cr = 0.9900, 0.9817, 0.99, 8*0.0,
filt_recirc_cr = 0.9333, 0.7333, 0.99, 8*0.0,
exhaust_cr = 24758.8, recirc_cr= 1.066e+5,
$end
$read
itime_step = 2, iunfilt = 1, ifilt =1, ifilt_remove = 0,0,0,0,7*0,
iremove = 0,ibreath_rate = 0, ioccupancy =0, icontrol = 1,
$end
$unfilt_flow
unfilt_flow =
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
1.010e+1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 1.950e-4, 4.260e-3, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 9.170e+3, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 2.400e+1, 5.260e+2, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
$end
$filt_flow
filt_flow =
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
2.730e-1, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 1.450e-2, 3.180e-1, 3.550e+4, 0.000e+0, 0.000e+0, 0.000e+0,
0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0, 0.000e+0,
$end
$control
filt_cr = 24684.0, unfilt_cr = 74.8,
filt_remove_cr = 0.9900, 0.9817, 0.99, 8*0.0,
filt_recirc_cr = 0.9333, 0.7333, 0.99, 8*0.0,
exhaust_cr = 24758.8, recirc_cr= 1.066e+5,
$end
$read
itime_step = 3, iunfilt = 1, ifilt =1, ifilt_remove = 0,0,0,0,7*0,
iremove = 0,ibreath_rate = 0, ioccupancy =0, icontrol = 1,
```



```
occupancy = 10*1.0,
br = 8*3.47e-4, 2*1.75e-4,
$end
$ncontrol
filt_cr = 24684.0, unfilt_cr = 74.8,
filt_remove_cr = 0.9900, 0.9817, 0.99, 8*0.0,
filt_recirc_cr = 0.9333, 0.7333, 0.99, 8*0.0,
exhaust_cr = 24758.8, recirc_cr= 1.066e+5,
$end
$nread
itime_step = 5, iunfilt = 0, ifilt =0, ifilt_remove = 0,0,0,0,7*0,
iremove = 0,ibreath_rate = 1, ioccupancy =1, icontrol = 1,
$end
$nooccupbr
occupancy = 8*0.6, 2*1.0,
br = 8*3.47e-4, 2*2.32e-4,
$end
$ncontrol
filt_cr = 24684.0, unfilt_cr = 74.8,
filt_remove_cr = 0.9900, 0.9817, 0.99, 8*0.0,
filt_recirc_cr = 0.9333, 0.7333, 0.99, 8*0.0,
exhaust_cr = 24758.8, recirc_cr= 1.066e+5,
$end
$nread
itime_step = 6, iunfilt = 0, ifilt =0, ifilt_remove = 0,0,0,0,7*0,
iremove = 0,ibreath_rate = 1, ioccupancy =1, icontrol = 1,
$end
$nooccupbr
occupancy = 8*0.4, 2*1.0,
br = 8*3.47e-4, 2*2.32e-4,
$end
$ncontrol
filt_cr = 24684.0, unfilt_cr = 74.8,
filt_remove_cr = 0.9900, 0.9817, 0.99, 8*0.0,
filt_recirc_cr = 0.9333, 0.7333, 0.99, 8*0.0,
exhaust_cr = 24758.8, recirc_cr= 1.066e+5,
$end
```

Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7 P-1h
Preparer: wmb Reviewer:

#

Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7 P-1i

Preparer: wmb

Reviewer:

*****TRACI VER. 1.0*****

Transient Radiological Assessment Code for

Isotopes

SOUTH TEXAS ELECTRIC GENERATING STATION

SEPTEMBER 24, 1992

CREATED BY WM. MARK BLUMBERG

RELOAD ENGINEERING SECTION

TRACI VERSION 1.0

JSN 1884

calc. title: Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7

Mar 27 1996 08:26:41 page P - 1
preparer: wmb

GENERAL DATA

preparer	wmb	preparer initials
inode8	2	use node 8 0=no/ 1 =yes, treat as a region, 2=yes, model as control room
ioffsite	1	calculate offsite dose 0=no/1=yes

OUTPUT OPTIONS

PRINT FLAGS 0 = NO / 1 = YES		
print_dcf	1	print dose conversion factors
print_instantaneous_activity	0	print inst. activity for each time step as a function of isotope and node
print_instantaneous_dose_rate	0	print inst. dose rate for each time step as a function of isotope and node
print_instantaneous_dose	0	print accumulated dose for each time step as a function of isotope and node
print_cumulative_dose	0	print cumulative dose up to the ending time of each time step as a function of isotope and node
print_summary_dose	1	print summary of cumulative dose for all time steps as a function of whole body, skin & thyroid doses
idebug	0	print namelist variables as read in
print_laserjet	1	print laserjet compressed print
sub_time_step	.100E+02	time interval of sub_time_steps (in sec) note: if = 0.0, default time steps are used

TRACI VERSION 1.0

JSN 1884

Mar 27 1996 08:26:41 page P - 2
calc. title: Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7
preparer: wmb

SOURCE TERM

num_isotope	13	number of isotopes (default 27, max 50)
iactivity_unit	0 : Ci	units of act. of source term 0=Ci / 1= Ci/ml / 2 = Bq / 3 = Bq/m ³
num_sources	1	number of sources at shutdown
fract_activity_node	.10E+01 .90E-06	fract. of total activity in each node
	.17E-05 .00E+00	
	.00E+00 .00E+00	
	.00E+00 .00E+00	
fract_release	.91E+00 .40E-01	fract. released from each isotope group
	.50E-01 .10E+01	
	.10E+01 .10E+01	
	.10E+01 .10E+01	
	.10E+01 .10E+01	

Note: the echo of fract_activity_node gives 8 values. Only "num_nodes" values will be used.

TRACI VERSION 1.0

JSN 1884

calc. title: Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7

Mar 27 1996 08:26:41 page P - 3
preparer: wmb

SOURCE #1

activity1_name	rcs	name of source and reference #
activity1	see note below	activity of source term at shutdown
activity1_unit	Ci	units of activity of source
activity1_mult	1.000	value multiplied by activity1 to get units of activity_unit
activity1_mult_unit		units of activity1_mult

note: values for activity1, activity2, & activity3 are given in table entitled: "calculation of initial activities"

TRACI VERSION 1.0

JSN 1884

Mar 27 1996 08:26:41 page P - 4
calc. title: Case C6-nc6061, rev. 1, MSLB Accident Nables only, 10.42 gpm, HVAC 7
preparer: wmb

NODES

num_nodes	5	number of nodes (max 7). Note: nodes 8,9 & 10 are reserved for cr, epz and lpz
node_volume_unit	3	unit of node vol. 1= m3/ 2=ft3 /3=gallons
flow_unit	3	unit of flow 1=cu. m/sec, 2=cfm/ 3=gpm
ispray_cutoff	0	auto. spray cutoff option 0=no/ 1=yes
spray_df	.0	.0 spray decon. factor (for each isotope grp)
	.0	.0
	.0	.0
	.0	.0
	.0	.0
	.0	.0

NODE VOLUMES (gal) AND GEOMETRY FACTORS (dimensionless)

NODE	1	2	3	4	5
NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV
VOLUME	.6880E+05	.1660E+05	.4970E+05	.3600E+06	.1000E+07
GF*	.1000E+01	.1000E+01	.1000E+01	.3067E+02	.1000E+01
NODE	6	7	8	9	10
NODE NAME	node 66666	node 77777	control rm	epz	lpz
VOLUME	.0000E+00	.0000E+00	.2050E+07		
GF*	.1000E+01	.1000E+01	.1703E+02		

Notes: Format for echo of spray_df is f7.1, ie.
values of spray_dcf >99,999.9 will not echo properly.

* If "geometry_factor" is entered as zero or not entered a
geometry factor is calculated, otherwise the value entered is used.

TRACI VERSION 1.0

JSN 1884

Mar 27 1996 08:26:41

page P - 5

calc. title: Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7

preparer: wmb

TIME STEPS

num_tsteps 5 number of time steps
tstep_unit 1:hours units of time steps 0=sec/ 1=hr. / 2=days
ieq_tstep 0 equal time step 0 = no, input times in
variable "tstep"/ 1 = yes
sdtime .0000E+00 time between shutdown and beginning of
first time step
first_tstep .0000E+00 time of beginning of first time step
(units of tstep_unit)
last_tstep .9600E+02 time of end of last time_step
(units of tstep_unit)
tstep see table below beginning time of 5 time steps
(required only if ieq_tstep=0
ie. unequal time steps are used)

TIME STEP NUMBER	BEGINNING		TIME STEP NUMBER	BEGINNING	
	TIME (hours)	TIME (hours)		TIME (hours)	TIME (hours)
1	.0000E+00		3	.2000E+01	
2	.5000E+00		4	.8000E+01	
5	.2400E+02				

TRACI VERSION 1.0 JSN 18B4
calc. title: Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7

Mar 27 1996

08:26:41

page p - 6
preparer: wmb

CH1/Q (sec/cubic meter)

TIME STEP (hours)		NODE 8	NODE 9	NODE 10
		CONTROL RM	EP2	LP2
.0000E+00	to .5000E+00	.1060E-02	.1300E-03	.3800E-04
.5000E+00	to .2000E+01	.1060E-02	.1300E-03	.3800E-04
.2000E+01	to .8000E+01	.1060E-02	.0000E+00	.1600E-04
.8000E+01	to .2400E+02	.0000E+00	.0000E+00	.1100E-04
.2400E+02	to .9600E+02	.0000E+00	.0000E+00	.4300E-05

TRACI VERSION 1.0

JSN 1884

Mar 27 1996 08:26:41 page P - 7

calc. title: Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7

preparer: wmb

DOSE CONVERSION FACTORS AND DECAY CONSTANTS

DOSE CONVERSION FACTORS				
ISOTOPE GROUP	DECAY CONSTANT (1/sec)	THYROID (rem/Ci)	BETA SKIN (rem * ci/. meter)/(Ci * sec)	WHOLE BODY
Kr--83m	4 .105E-03	.000E+00	.000E+00	.240E-05
Kr--85m	4 .430E-04	.000E+00	.463E-01	.371E-01
Kr---85	4 .205E-08	.000E+00	.425E-01	.510E-03
Kr---87	4 .151E-03	.000E+00	.308E+00	.188E+00
Kr---88	4 .673E-04	.000E+00	.751E-01	.466E+00
Kr---89	4 .363E-02	.000E+00	.320E+00	.526E+00
Xe-131m	4 .682E-06	.000E+00	.151E-01	.290E-02
Xe-133m	4 .366E-05	.000E+00	.315E-01	.795E-02
Xe--133	4 .153E-05	.000E+00	.970E-02	.932E-02
Xe-135m	4 .738E-03	.000E+00	.225E-01	.989E-01
Xe--135	4 .211E-04	.000E+00	.589E-01	.538E-01
Xe--137	4 .302E-02	.000E+00	.387E+00	.450E-01
Xe--138	4 .815E-03	.000E+00	.131E+00	.280E+00

TRACI VERSION 1.0
calc. title: Case C6-nc6661, rev. 1, MSLB Accident Nables only, 10.42 gpm, HVAC 7

JSN 1884
Mar 27 1995 08:26:41 page P - 8
preparer: wmb

CALCULATION OF INITIAL ACTIVITIES - BEFORE SHUTDOWN

SOURCE NAME	UNITS	COL. 1	COL. 2	COL. 3	COL. 4	COL. 5	COL. 6	COL. 7
NUMBER	ISOTOPE	GROUP						TOTAL ACTIVITY
	rcs	Ci						Ci
1	Kr--83m	4	.7000E+05	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.7000E+05
2	Kr--85m	4	.1500E+06	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.1500E+06
3	Kr--85	4	.1850E+05	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.1850E+05
4	Kr--87	4	.2750E+06	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.2750E+06
5	Kr--88	4	.3950E+06	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.3950E+06
6	Kr--89	4	.4850E+06	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.4850E+06
7	Xe-131m	4	.3850E+04	.1000E-01	.0000E+00	.0000E+00	.0000E+00	.3850E+04
8	Xe-133m	4	.1650E+06	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.1650E+06
9	Xe-133	4	.1150E+07	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.1150E+07
10	Xe-135m	4	.2300E+06	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.2300E+06
11	Xe-135	4	.3250E+06	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.3250E+06
12	Xe-137	4	.1000E+07	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.1000E+07
13	Xe-138	4	.9500E+06	.1000E+01	.0000E+00	.0000E+00	.0000E+00	.9500E+06

note: col. 7 = (col. 1*col. 2 + col. 3*col.4 + col. 5*col. 6)

TEACI VERSION 1.0
calc. title: Case C6-nc061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7

JSN 1884

Mar 27 1996 08:26:41
page p - 9
preparer: wmb

NODAL DISTRIBUTION OF INITIAL ACTIVITIES - BEFORE SHUTDOWN (Ci)

NODES	1	2	3	4	5	6	7	8
NODE NAME	RCS	AFF.	SG	UNAFF SG	TSC	DUMMY ENV	control rm	
ISOTOPE GROUP								
Kr--83m	4	.700E+05	.630E-01	.117E+00	.000E+00	.000E+00	.000E+00	
Kr--85m	4	.150E+06	.135E+00	.250E+00	.000E+00	.000E+00	.000E+00	
Kr--85	4	.185E+05	.166E-01	.309E-01	.000E+00	.000E+00	.000E+00	
Kr--87	4	.275E+06	.247E+00	.459E+00	.000E+00	.000E+00	.000E+00	
Kr--88	4	.395E+06	.355E+00	.660E+00	.000E+00	.000E+00	.000E+00	
Kr--89	4	.485E+06	.436E+00	.810E+00	.000E+00	.000E+00	.000E+00	
Xe-131m	4	.385E+04	.346E-02	.643E-02	.000E+00	.000E+00	.000E+00	
Xe-133m	4	.165E+06	.148E+00	.276E+00	.000E+00	.000E+00	.000E+00	
Xe-133	4	.115E+07	.103E+01	.192E+01	.000E+00	.000E+00	.000E+00	
Xe-135m	4	.230E+06	.207E+00	.384E+00	.000E+00	.000E+00	.000E+00	
Xe-135	4	.325E+06	.292E+00	.543E+00	.000E+00	.000E+00	.000E+00	
Xe-137	4	.100E+07	.900E+00	.167E+01	.000E+00	.000E+00	.000E+00	
Xe-138	4	.950E+06	.855E+00	.159E+01	.000E+00	.000E+00	.000E+00	

TRACI VERSION 1.0
calc. title: Case C6-nc6061, rev. 1, HSLB Accident Nobles only, 10.42 rpm, HVAC 7

Mar 27 1996 08:26:42 page P - 10
preparer: kmb

ACTIVITIES - AFTER .0000E+00 hours (ci)

NODES	1	2	3	4	5	6	7	8
NODE NAME	RCS	AFF.	UNAFF SG	TSC	DUMMY / NV	control rm		
ISOTOPE GROUP								
Kr--83m	4	.709E+05	.630E-01	.117E+00	.000E+00	.000E+00	.000E+00	.000E+00
Kr--85m	4	.150E+06	.135E+00	.250E+00	.000E+00	.000E+00	.000E+00	.000E+00
Kr--85	4	.185E+05	.166E-01	.309E-01	.000E+00	.000E+00	.000E+00	.000E+00
Kr--87	4	.275E+06	.247E+00	.459E+00	.000E+00	.000E+00	.000E+00	.000E+00
Kr--88	4	.395E+06	.355E+00	.660E+00	.000E+00	.000E+00	.000E+00	.000E+00
Kr--89	4	.485E+06	.436E+00	.810E+00	.000E+00	.000E+00	.000E+00	.000E+00
Xe-131m	4	.385E+04	.346E-02	.643E-02	.000E+00	.000E+00	.000E+00	.000E+00
Xe-133m	4	.165E+06	.148E+00	.276E+00	.000E+00	.000E+00	.000E+00	.000E+00
Xe-133	4	.115E+07	.103E+01	.192E+01	.000E+00	.000E+00	.000E+00	.000E+00
Xe-135 <i>ii</i>	4	.230E+06	.207E+00	.384E+00	.000E+00	.000E+00	.000E+00	.000E+00
Xe-135	4	.325E+06	.292E+00	.543E+00	.000E+00	.000E+00	.000E+00	.000E+00
Xe-137	4	.100E+07	.900E+00	.167E+01	.000E+00	.000E+00	.000E+00	.000E+00
Xe-138	4	.950E+06	.855E+00	.159E+01	.000E+00	.000E+00	.000E+00	.000E+00

TRACI VERSION 1.0

JSN 1884

Mar 27 1996 08:26:42

page P - 11

calc. title: Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7

preparer: wmb

TIME STEP NUMBER 1 - .0000E+00 to .5000E+00 (hours)

TIME DEPENDENT INPUT
(REPEATED FOR EACH TIME STEP)

itime_step	1	time step which corresponds to the time dependent data
iunfilt	1	read in unfiltered flow data for this time step 0 = no / 1 = yes
ifilt	1	read in filtered flow data for this time step 0 = no / 1 = yes
ifilt_remove	1 1 1 0 0 0 0 0 0 0 0	read in filter removal effic. for each isotope group for this time step. 0 = no / 1= yes ie. (ifilt_remove(1)=1 : read in group 1 data)
iremove	0	read in removal constants for this time step 0 = no/ 1 = yes (in units "1/tstep_unit") (1/hours)
ioccupancy	1	read in occupancy factors for this time step 0 = no/ 1 = yes (in units of %/day)
ibreath_rate	1	read in breathing rates for this time step 0 = no/ 1 = yes (in units of m ³ /sec)
icontrol	1	read in control room data 0 = no/ 1 = yes

TRACI VERSION 1.0
calc. title: Case C6-nc6061, rev. 1, HSLB Accident Nobles only, 10.42 gpm, HVAC 7

JSN 1884
TIME STEP NUMBER 1 - .0000E+00 to .5000E+00 (hours)
Mar 27 1996 08:26:42 page P - 12
preparer: wmb

UNFILTERED FLOW RATE BETWEEN NODES - VARIABLE "UNFILT_FLOW" (gpm)

TO NODES	1	2	3	4	5	8	
FROM NODE	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm	environment
1	.000E+00	.101E+02	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
2	.000E+00	.000E+00	.000E+00	.700E-02	.000E+C0	.000E+00	.864E+03
3	.000E+00	.000E+00	.000E+00	.426E-02	.000E+00	.000E+00	.526E+03
4	.000E+00	.000E+00	.000E+00	.000E+00	.917E+04	.000E+00	.000E+00
5	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
8	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00

FILTERED FLOW RATE BETWEEN NODES - VARIABLE "FILT_FLOW" (gpm)

TO NODES	1	2	3	4	5	8	
FROM NODE	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm	environment
1	.000E+00	.000E+00	.273E+00	.000E+00	.000E+00	.000E+00	.000E+00
2	.000E+00	.000E+00	.000E+00	.523E+00	.000E+00	.000E+00	.000E+00
3	.000E+00	.000E+00	.000E+00	.318E+00	.000E+00	.000E+00	.000E+00
4	.000E+00	.000E+00	.000E+00	.355E+05	.000E+00	.000E+00	.000E+00
5	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
8	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00

note: a flow rate from node x to node y represents recirculation flow

TRACI VERSION 1.0

JSN 1384

Mar 27 1996 08:26:42

page P - 13

Prepared: 1978

TIME STEP NUMBER 1 : -0000E+00 to -5000E+00 (hours)

FOR: ELEM. 1

FILTERED REMOVAL EFFICIENCY BETWEEN NODES "FILT FLOW REMOVE" (IN EFFICIENCY FRACTION)

FOR: GRG, 1

FILTERED REMOVAL EFFICIENCY BETWEEN NODES "FILT FLOW REMOVE" (IN EFFICIENCY FRACTION)

TRACE: title: Case C6-DC6

ISBN 1984

Mar 27 1996 08:26:42 page # - 14
preparer: beth

TIME STEP NUMBER 1 = 0000E+00 to 5000E+00 (hours)

```

FOR: PART_I
      FILTERED REMOVAL EFFICIENCY BETWEEN NODES "N1 FILT FLOW REMOVE" ( IN EFFICIENCY FRACTION )

```

BREATHING RATE (M/S) OCCUPANCY FACTORS (%/TIME STEP)

TRACI VERSION 1.0

JSN 1884

Mar 27 1996 08:26:42 page P - 15

calc. title: Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7

preparer: wmb

TIME STEP NUMBER 1 - .0000E+00 to .5000E+00 (hours)

CONTROL ROOM FILTER EFFICIENCY FRACTION AND FLOW (gpm) - MODEL 2

filt_cr	.2468E+05	filtered intake rate
unfilt_cr	.7480E+02	unfiltered intake rate
recirc_cr	.1066E+06	recirculation rate
exhaust_cr	.2476E+05	exhaust rate from control room

ISOTOPE GROUP FILTER EFFICIENCY FRACTION
INTAKE RECIRCULATION

ELEM. I	.9900E+00	.9333E+00
ORG. I	.9817E+00	.7333E+00
PART. I	.9900E+00	.9900E+00
NOB. GAS	.0000E+00	.0000E+00
Cs, Rb	.0000E+00	.0000E+00
Te, Se	.0000E+00	.0000E+00
Sr, Ba	.0000E+00	.0000E+00
NOB. MET.	.0000E+00	.0000E+00
RARE EARTH	.0000E+00	.0000E+00
MISC.	.0000E+00	.0000E+00
HALOGENS	.0000E+00	.0000E+00

TRACI VERSION 1.0

JSN 1884

calc. title: Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7

Mar 27 1996 08:26:47 page P - 16
preparer: wmb

TIME STEP NUMBER 2 - .5000E+00 to .2000E+01 (hours)

TIME DEPENDENT INPUT
(REPEATED FOR EACH TIME STEP)

itime_step 2 time step which corresponds
to the time dependent data
iunfilt 1 read in unfiltered flow data for this time step
0 = no / 1 = yes
ifilt 1 read in filtered flow data for this time step
0 = no / 1 = yes
ifilt_remove 0 0 0 0 0 read in filter removal effic. for each isotope
0 0 0 0 0 group for this time step. 0 = no / 1= yes
0 ie. (ifilt_remove(1)=1 : read in group 1 data)
iremove 0 read in removal constants for this time step
0 = no/ 1 = yes (in units "1/tstep_unit")
(1/hours)
ioccupancy 0 read in occupancy factors for this time step
0 = no/ 1 = yes (in units of %/day)
ibreath_rate 0 read in breathing rates for this time step
0 = no/ 1 = yes (in units of m3/sec)
icontrol 1 read in control room data
0 = no/ 1 = yes

TRACI VERSION 1.0
calc. title: Case C6-nc6061, rev. 1, MSLB Accident Nables only, 10.42 gpm, HVAC 7

JSN 1884
TIME STEP NUMBER 2 - .5000E+00 to .2000E+01 (hours)
page p - 17
preparer: wmb

Mar 27 1996 08:26:47

UNFILTERED FLOW RATE BETWEEN NODES - VARIABLE "UNFILT_FLOW" (gpm)

TO NODES	1	2	3	4	5	8	
NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm	environment
FROM NODE							
1	.000E+00	.101E+02	.000E+00	.000E+00	.000E+00	.003E+00	.000E+00
2	.000E+00	.000E+00	.000E+00	.195E-03	.000E+00	.000E+00	.240E+02
3	.000E+00	.000E+00	.000E+00	.426E-02	.000E+00	.000E+00	.526E+03
4	.000E+00	.000E+00	.000E+00	.000E+00	.917E+04	.000E+00	.000E+00
5	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
8	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00

FILTERED FLOW RATE BETWEEN NODES - VARIABLE "FILT_FLOW" (gpm)

TO NODES	1	2	3	4	5	8	
NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm	environment
FROM NODE							
1	.000E+00	.001E+00	.273E+00	.000E+00	.000E+00	.000E+00	.000E+00
2	.000E+00	.000E+00	.000E+00	.145E-01	.000E+00	.000E+00	.000E+00
3	.000E+00	.000E+00	.000E+00	.318E+00	.000E+00	.000E+00	.000E+00
4	.000E+00	.000E+00	.000E+00	.355E+05	.000E+00	.000E+00	.000E+00
5	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
8	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00

note: a flow rate from node x to mode x represents recirculation flow

TRACI VERSION 1.0

JSN 1884

Mar 27 1996 08:26:47 page P - 18
calc. title: Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7
preparer: wmb

TIME STEP NUMBER 2 - .5000E+00 to .2000E+01 (hours)

CONTROL ROOM FILTER EFFICIENCY FRACTION AND FLOW (gpm) - MODEL 2

filt_cr	.2468E+05	filtered intake rate
unfilt_cr	.7480E+02	unfiltered intake rate
recirc_cr	.1066E+06	recirculation rate
exhaust_cr	.2476E+05	exhaust rate from control room

ISOTOPE GROUP FILTER EFFICIENCY FRACTION
INTAKE RECIRCULATION

ELEM. I	.9900E+00	.9333E+00
ORG. I	.9817E+00	.7333E+00
PART. I	.9200E+00	.9900E+00
NOB. GAS	.0000E+00	.0000E+00
Cs, Rb	.0000E+00	.0000E+00
Te, Se	.0000E+00	.0000E+00
Sr, Ba	.0000E+00	.0000E+00
NOB. MET.	.0000E+00	.0000E+00
RARE EARTH	.0000E+00	.0000E+00
MISC.	.0000E+00	.0000E+00
HALOGENS	.0000E+00	.0000E+00

TRACI VERSION 1.0

JSN 1884

calc. title: Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7

Mar 27 1996 08:26:59 page P - 19
preparer: wmb

TIME STEP NUMBER 3 - .2000E+01 to .8000E+01 (hours)

TIME DEPENDENT INPUT
(REPEATED FOR EACH TIME STEP)

<i>itime_step</i>	3	time step which corresponds to the time dependent data
<i>iunfilt</i>	1	read in unfiltered flow data for this time step 0 = no / 1 = yes
<i>ifilt</i>	1	read in filtered flow data for this time step 0 = no / 1 = yes
<i>ifilt_remove</i>	0 0 0 0 0 0 0 0 0 0 0	read in filter removal effic. for each isotope group for this time step. 0 = no / 1= yes ie. (ifilt_remove(1)=1 : read in group 1 data)
<i>iremove</i>	0	read in removal constants for this time step 0 = no/ 1 = yes (in units "1/tstep_unit") (1/hours)
<i>ioccupancy</i>	0	read in occupancy factors for this time step 0 = no/ 1 = yes (in units of %/day)
<i>ibreath_rate</i>	0	read in breathing rates for this time step 0 = no/ 1 = yes (in units of m ³ /sec)
<i>icontrol</i>	1	read in control room data 0 = no/ 1 = yes

TRACI VERSION 1.0

JSN 1884

Mar 27 1996 08:27:00 page P - 20
calc. title: Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7
preparer: wmb

TIME STEP NUMBER 3 - .2000E+01 to .8000E+01 (hours)

UNFILTERED FLOW RATE BETWEEN NODES - VARIABLE "UNFILT_FLOW" (gpm)

TO NODES	1	2	3	4	5	8	
NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm	environment
FROM NODE							
1	.000E+00	.101E+02	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
2	.000E+00	.000E+00	.000E+00	.195E-03	.000E+00	.000E+00	.240E+02
3	.000E+00	.000E+00	.000E+00	.333E-02	.000E+00	.000E+00	.411E+03
4	.000E+00	.000E+00	.000E+00	.000E+00	.917E+04	.000E+00	.000E+00
5	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
8	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00

FILTERED FLOW RATE BETWEEN NODES - VARIABLE "FILT_FLOW" (gpm)

TO NODES	1	2	3	4	5	8	
NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm	environment
FROM NODE							
1	.000E+00	.000E+00	.273E+00	.000E+00	.000E+00	.000E+00	.000E+00
2	.000E+00	.000E+00	.000E+00	.145E-01	.000E+00	.000E+00	.000E+00
3	.000E+00	.000E+00	.000E+00	.249E+00	.000E+00	.000E+00	.000E+00
4	.000E+00	.000E+00	.000E+00	.355E+05	.000E+00	.000E+00	.000E+00
5	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
8	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00

note: a flow rate from node x to node x represents recirculation flow

TRACI VERSION 1.0

JSN 1884

Mar 27 1996 08:27:00

page P - 21

calc. title: Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7

preparer: wmb

TIME STEP NUMBER 3 - .2000E+01 to .8000E+01 (hours)

CONTROL ROOM FILTER EFFICIENCY FRACTION AND FLOW (gpm) - MODEL 2

filt_cr	.2468E+05	filtered intake rate
unfilt_cr	.7480E+02	unfiltered intake rate
recirc_cr	.1066E+06	recirculation rate
exhaust_cr	.2476E+05	exhaust rate from control room

ISOTOPE GROUP FILTER EFFICIENCY FRACTION
INTAKE RECIRCULATION

ELEM. I	.9900E+00	.9333E+00
ORG. I	.9817E+00	.7333E+00
PART. I	.9900E+00	.9900E+00
NOB. GAS	.0000E+00	.0000E+00
Cs, Rb	.0000E+00	.0000E+00
Te, Se	.0000E+00	.0000E+00
Sr, Ba	.0000E+00	.0000E+00
NOB. MET.	.0000E+00	.0000E+00
RARE EARTH	.0000E+00	.0000E+00
MISC.	.0000E+00	.0000E+00
HALOGENS	.0000E+00	.0000E+00

TRACI VERSION 1.0

JSN 1884

Mar 27 1996 08:27:50

page P - 22

calc. title: Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7

preparer: wmb

TIME STEP NUMBER 4 - .8000E+01 to .2400E+02 (hours)

TIME DEPENDENT INPUT
(REPEATED FOR EACH TIME STEP)

itime_step 4 time step which corresponds
to the time dependent data
iunfilt 1 read in unfiltered flow data for this time step
0 = no / 1 = yes
ifilt 1 read in filtered flow data for this time step
0 = no / 1 = yes
ifilt_remove 0 0 0 0 0 read in filter removal effic. for each isotope
group for this time step. 0 = no / 1= yes
0 ie. (ifilt_remove(1)=1 : read in group 1 data)
iremove 0 read in removal constants for this time step
0 = no/ 1 = yes (in units "1/tstep_unit")
(1/hours)
ioccupancy 1 read in occupancy factors for this time step
0 = no/ 1 = yes (in units of %/day)
ibreath_rate 1 read in breathing rates for this time step
0 = no/ 1 = yes (in units of m3/sec)
icontrol 1 read in control room data
0 = no/ 1 = yes

TRACI

JSN 1894

VERSION 1.0

calc. title: Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7
 TIME STEP NUMBER 4 - .8000E+01 to .2400E+02 (hours)

UNFILTERED FLOW RATE BETWEEN NODES - VARIABLE "UNFILT_FLOW" (gpm)

TO NODES	1	2	3	4	5	6	7	8
NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm	environment	
FROM NODE								
1	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
2	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
3	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
4	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.917E+04	.000E+00	.000E+00
5	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
8	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00

FILTERED FLOW RATE BETWEEN NODES - VARIABLE "FILT_FLOW" (gpm)

TO NODES	1	2	3	4	5	6	7	8
NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm	environment	
FROM NODE								
1	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
2	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
3	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
4	.000E+00	.000E+00	.000E+00	.000E+00	.355E+05	.000E+00	.000E+00	.000E+00
5	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00
8	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00	.000E+00

note: a flow rate from node x to node y represents recirculation flow

BREATHING RATE (M3/SEC), OCCUPANCY FACTORS (%/TIME STEP)

NODES	1	2	3	4	5	6	7	8	9	10
NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm	epz	lpz		
BREATH. RATE	.347E-03	.347E-03	.347E-03	.347E-03	.347E-03	.347E-03	.175E-03	.175E-03		
OCCUPANCY	.100E+01	.100E+01	.100E+01	.100E+01	.100E+01	.100E+01	.100E+01	.100E+01		

TRACI VERSION 1.0

JSN 1884

Mar 27 1996 08:27:51

page P - 24

calc. title: Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7

preparer: wmb

TIME STEP NUMBER 4 - .8000E+01 to .2400E+02 (hours)

CONTROL ROOM FILTER EFFICIENCY FRACTION AND FLOW (gpm) - MODEL 2

filt_cr	.2468E+05	filtered intake rate
unfilt_cr	.7480E+02	unfiltered intake rate
recirc_cr	.1066E+06	recirculation rate
exhaust_cr	.2476E+05	exhaust rate from control room

ISOTOPE GROUP FILTER EFFICIENCY FRACTION
INTAKE RECIRCULATION

ELEM. I	.9900E+00	.9333E+00
ORG. I	.9817E+00	.7333E+00
PART. I	.9900E+00	.9900E+00
NOB. GAS	.0000E+00	.0000E+00
Cs, Rb	.0000E+00	.0000E+00
Te, Se	.0000E+00	.0000E+00
Sr, Ba	.0000E+00	.0000E+00
NOB. MET.	.0000E+00	.0000E+00
RARE EARTH	.0000E+00	.0000E+00
MISC.	.0000E+00	.0000E+00
HALOGENS	.0000E+00	.0000E+00

TRACI VERSION 1.0

JSN 1884

Mar 27 1996 08:30:03 page P - 25
preparer: wmb

calc. title: Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7

TIME STEP NUMBER 5 - .2400E+02 to .9600E+02 (hours)

TIME DEPENDENT INPUT
(REPEATED FOR EACH TIME STEP)

itime_step 5 time step which corresponds
to the time dependent data

iunfilt 0 read in unfiltered flow data for this time step
0 = no / 1 = yes

ifilt 0 read in filtered flow data for this time step
0 = no / 1 = yes

ifilt_remove 0 0 0 0 0 read in filter removal effic. for each isotope
group for this time step. 0 = no / 1= yes
0 ie. (ifilt_remove(1)=1 : read in group 1 data)

iremove 0 read in removal constants for this time step
0 = no/ 1 = yes (in units "1/tstep_unit")
(1/hours)

ioccupancy 1 read in occupancy factors for this time step
0 = no/ 1 = yes (in units of %/day)

ibreath_rate 1 read in breathing rates for this time step
0 = no/ 1 = yes (in units of m3/sec)

icontrol 1 read in control room data
0 = no/ 1 = yes

BREATHING RATE (M3/SEC), OCCUPANCY FACTORS (%/TIME STEP)

NODES	1	2	3	4	5	8	9	10
NODE NAME	RCS	AFF. SG	UNAFF SG	TSC	DUMMY ENV	control rm epz		lpz
BREATH. RATE	.347E-03	.347E-03	.347E-03	.347E-03	.347E-03	.347E-03	.232E-03	.232E-03
OCCUPANCY	.600E+00	.600E+00	.600E+00	.600E+00	.600E+00	.600E+00	.100E+01	.100E+01

TRACI VERSION 1.0

JSN 1884

Mar 27 1996 08:30:03 page P - 26

calc. title: Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7

preparer: wmb

TIME STEP NUMBER 5 - .2400E+02 to .9600E+02 (hours)

CONTROL ROOM FILTER EFFICIENCY FRACTION AND FLOW (gpm) - MODEL 2

filt_cr	.2468E+05	filtered intake rate
unfilt_cr	.7480E+02	unfiltered intake rate
recirc_cr	.1066E+06	recirculation rate
exhaust_cr	.2476E+05	exhaust rate from control room

ISOTOPE GROUP FILTER EFFICIENCY FRACTION
INTAKE RECIRCULATION

ELEM. I	.9900E+00	.9333E+00
ORG. I	.9817E+00	.7333E+00
PART. I	.9900E+00	.9900E+00
NOB. GAS	.0000E+00	.0000E+00
Cs, Rb	.0000E+00	.0000E+00
Te, Se	.0000E+00	.0000E+00
Sr, Ba	.0000E+00	.0000E+00
NOB. MET.	.0000E+00	.0000E+00
RARE EARTH	.0000E+00	.0000E+00
MISC.	.0000E+00	.0000E+00
HALOGENS	.0000E+00	.0000E+00

TRACI VERSION 1.0

JSH 1884

calc. title: Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7

Mar 27 1996 08:37:38

page P - 27

preparer: wmb

NODE NAME: RCS

SUMMARY OF CUMULATIVE DOSE FOR NODE 1 (REM) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.0000E+00	.3108E+07	.2108E+07
.5000E+00 to .2000E+01	.0000E+00	.7438E+07	.4429E+07
.2000E+01 to .8000E+01	.0000E+00	.1471E+08	.8497E+07
.8000E+01 to .2400E+02	.0000E+00	.1960E+08	.1328E+08
.2400E+02 to .9600E+02	.0000E+00	.2456E+08	.1991E+08

TRACI VERSION 1.0

JSN 1884

Mar 27 1996 08:37:38 page P - 28
calc. title: Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7
preparer: wmb

NODE NAME: AFF. SG

SUMMARY OF CUMULATIVE DOSE FOR NODE 2 (REM) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.0000E+00	.2394E+05	.1425E+05
.5000E+00 to .2000E+01	.0000E+00	.2108E+06	.1141E+06
.2000E+01 to .8000E+01	.0000E+00	.1403E+07	.8006E+06
.8000E+01 to .2400E+02	.0000E+00	.2882E+07	.2248E+07
.2400E+02 to .9600E+02	.0000E+00	.4387E+07	.4255E+07

TRACI VERSION 1.0

JSW 1884

Mar 27 1996 08:37:38 page P - 29
calc. title: Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7
preparer: wmb

NODE NAME: UNAFF SG

SUMMARY OF CUMULATIVE DOSE FOR NODE 3 (REM) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.0000E+00	.2233E+03	.1335E+03
.5000E+00 to .2000E+01	.0000E+00	.1920E+04	.1040E+04
.2000E+01 to .8000E+01	.0000E+00	.1269E+05	.7244E+04
.8000E+01 to .2400E+02	.0000E+00	.2605E+05	.2031E+05
.2400E+02 to .9600E+02	.0000E+00	.3963E+05	.3843E+05

TRACI VERSION 1.0

JSN 1884

Mar 27 1996 08:37:38 page P - 30
calc. title: Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7
preparer: wmb

NODE NAME: TSC

SUMMARY OF CUMULATIVE DOSE FOR NODE 4 (REM) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.0000E+00	.9069E-02	.1585E+00
.5000E+00 to .2000E+01	.0000E+00	.3475E-01	.5814E+00
.2000E+01 to .8000E+01	.0000E+00	.9769E-01	.1696E+01
.8000E+01 to .2400E+02	.0000E+00	.1041E+00	.1836E+01
.2400E+02 to .9600E+02	.0000E+00	.1041E+00	.1836E+01

TRACI VERSION 1.0 JSN 1884
calc. title: Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7

Mar 27 1996 08:37:38

page P - 31
preparer: wmb

NODE NAME: DUMMY ENV

SUMMARY OF CUMULATIVE DOSE FOR NODE 5 (REM) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.0000E+00	.1910E-01	.1065E-01
.5000E+00 to .2000E+01	.0000E+00	.4846E+00	.2595E+00
.2000E+01 to .8000E+01	.0000E+00	.3968E+01	.2296E+01
.8000E+01 to .2400E+02	.0000E+00	.1075E+02	.8924E+01
.2400E+02 to .9600E+02	.0000E+00	.1772E+02	.1825E+02

TRACI VERSION 1.0 JSON 1884
calc. title: Case C6-nc6061, rev. 1, HSLB Accident Nables only, 10.42 gpm, HVAC 7
Mar 27 1996 08:37:38 page P - 32
preparer: wmb

NODE NAME: control rm

SUMMARY OF CUMULATIVE DOSE FOR NODE 8 (REM) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.0000E+00	.8462E-02	.8198E-01
.5000E+00 to .2000E+01	.0000E+00	.4331E-01	.4004E+00
.2000E+01 to .8000E+01	.0000E+00	.1438E+00	.1389E+01
.8000E+01 to .2400E+02	.0000E+00	.1640E+00	.1645E+01
.2400E+02 to .9600E+02	.0000E+00	.1640E+00	.1645E+01

TRACI VERSION 1.0 JSON 1884
calc. title: Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7

Mar 27 1996 08:37:38 page p - 33
preparer: wmb

NODE NAME: epz

SUMMARY OF CUMULATIVE DOSE FOR NODE 9 (REM) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.0000E+00	.1704E+00	.1016E+00
.5000E+00 to .2000E+01	.0000E+00	.2147E+00	.1251E+00
.2000E+01 to .8000E+01	.0000E+00	.2147E+00	.1251E+00
.8000E+01 to .2400E+02	.0000E+00	.2147E+00	.1251E+00
.2400E+02 to .9600E+02	.0000E+00	.2147E+00	.1251E+00

TRACI VERSION 1.0

JSN 1884

Mar 27 1996 08:37:39

page P - 34

preparer: wmb

calc. title: Case C6-nc6061, rev. 1, MSLB Accident Nobles only, 10.42 gpm, HVAC 7


NODE NAME: lpz

SUMMARY OF CUMULATIVE DOSE FOR NODE 10 (REM) AS A FUNCTION OF TIME

TIME STEP (hours)	THYROID	WHOLE BODY	BETA
.0000E+00 to .5000E+00	.0000E+00	.4988E-01	.2969E-01
.5000E+00 to .2000E+01	.0000E+00	.6277E-01	.3658E-01
.2000E+01 to .8000E+01	.0000E+00	.9612E-01	.5578E-01
.8000E+01 to .2400E+02	.0000E+00	.9612E-01	.5578E-01
.2400E+02 to .9600E+02	.0000E+00	.9612E-01	.5578E-01

ATTACHMENT 4

**PLANT GENERAL ARRANGEMENT
DRAWINGS**



OVERSIZE DOCUMENT PAGE PULLED

SEE APERTURE CARDS

NUMBER OF OVERSIZE PAGES FILMED ON APERTURE CARDS

15

9605100128

129

131

135

136

137

139

140

141

142

143

145

146

149

150

APERTURE CARD/HARD COPY AVAILABLE FROM

RECORDS AND REPORTS MANAGEMENT BRANCH