



52003

UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

March 27, 1996

Mr. Nicholas J. Liparulo
Nuclear Safety and Regulatory Activities
Westinghouse Electric Corporation
P.O. Box 355
Pittsburgh, Pennsylvania 15230

SUBJECT: FOLLOWON QUESTIONS CONCERNING THE AP600 LEVEL 1 PROBABILISTIC RISK ASSESSMENT (PRA)

Dear Mr. Liparulo:

As a result of its review of the June 1992 application for design certification of the AP600, the staff has determined that it needs additional information in order to complete its review. Specifically, the enclosed questions are related to level 1 PRA results and insights associated with steam generator tube rupture accident sequences.

You have requested that portions of the information submitted in the June 1992 application for design certification be exempt from mandatory public disclosure. While the staff has not completed its review of your request in accordance with the requirements of 10 CFR 2.790, that portion of the submitted information is being withheld from public disclosure pending the staff's final determination. The staff concludes that these followon questions do not contain those portions of the information for which exemption is sought. However, the staff will withhold this letter from public disclosure for 30 calendar days from the date of this letter to allow Westinghouse the opportunity to verify the staff's conclusions. If, after that time, you do not request that all or portions of the information in the enclosures be withheld from public disclosure in accordance with 10 CFR 2.790, this letter will be placed in the NRC's Public Document Room.

These followon questions affect nine or fewer respondents, and therefore is not subject to review by the Office of Management and Budget under P.L. 96-511.

NRC FILE CENTER COPY

060019

9605060200 960327
PDR ADOCK 05200003
A PDR

DF03

Mr. Nicholas J. Liparulo

- 2 -

March 27, 1996

If you have any questions regarding this matter, you can contact me at (301) 415-1132.

Sincerely,

original signed by:

Joseph M. Sebrosky, Project Manager
Standardization Project Directorate
Division of Reactor Program Management
Office of Nuclear Reactor Regulation

Docket No. 52-003

Enclosure: As stated

cc w/enclosure:
See next page

DISTRIBUTION:

*Docket File
*PUBLIC
RArchitzel
DJackson
JSebrosky
WDean, EDO
MSeimien, OGC
ACRS (11)

*** HOLD FOR 30 DAYS**

PDST R/F
TQuay
WHuffman
TKenyon
NSaltos, 0-10 E4
JFlack, T-10 F13
EJordan, T-4 D18
JMoore, 0-15 B18

DOCUMENT NAME: A:SGTR PRA.SPL (3C AP600 DISK)

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM:PDST:DRPM	SC:PDST:DRPM					
NAME	JSebrosky <i>JMS</i>	RArchitzel <i>RA</i>					
DATE	03/27/96	03/27/96					

OFFICIAL RECORD COPY

Mr. Nicholas J. Liparulo
Westinghouse Electric Corporation

Docket No. 52-003
AP600

cc: Mr. B. A. McIntyre
Advanced Plant Safety & Licensing
Westinghouse Electric Corporation
Energy Systems Business Unit
P.O. Box 355
Pittsburgh, PA 15230

Mr. John C. Butler
Advanced Plant Safety & Licensing
Westinghouse Electric Corporation
Energy Systems Business Unit
Box 355
Pittsburgh, PA 15230

Mr. M. D. Beaumont
Nuclear and Advanced Technology Division
Westinghouse Electric Corporation
One Montrose Metro
11921 Rockville Pike
Suite 350
Rockville, MD 20852

Mr. S. M. Modro
Nuclear Systems Analysis Technologies
Lockheed Idaho Technologies Company
Post Office Box 1625
Idaho Falls, ID 83415

Enclosure to be distributed to the following addressees after the result of the proprietary evaluation is received from Westinghouse:

Mr. Ronald Simard, Director
Advanced Reactor Programs
Nuclear Energy Institute
1776 Eye Street, N.W.
Suite 300
Washington, DC 20006-3706

Ms. Lynn Connor
DOC-Searach Associates
Post Office Box 34
Cabin John, MD 20818

Mr. James E. Quinn, Projects Manager
LMR and SBWR Programs
GE Nuclear Energy
175 Curtner Avenue, M/C 165
San Jose, CA 95125

Mr. John E. Leatherman, Manager
SBWR Design Certification
GE Nuclear Energy, M/C 781
San Jose, CA 95125

Barton Z. Cowan, Esq.
Eckert Seamans Cherin & Mellott
600 Grant Street 42nd Floor
Pittsburgh, PA 15219

Mr. Sterling Franks
U.S. Department of Energy
NE-42
Washington, DC 20585

Mr. Frank A. Ross
U.S. Department of Energy, NE-42
Office of LWR Safety and Technology
19901 Germantown Road
Germantown, MD 20874

Mr. Charles Thompson, Nuclear Engineer
AP600 Certification
U.S. Department of Energy
NE-451
Washington, DC 20585

Mr. Ed Rodwell, Manager
PWR Design Certification
Electric Power Research Institute
3412 Hillview Avenue
Palo Alto, CA 94303

AP600 PRA REVIEW
REQUEST FOR ADDITIONAL INFORMATION

- 720.324 As part of the AP600 PRA review, the staff is performing confirmatory re-quantification of selected accident sequences. To compare with Westinghouse's results, lists of top minimum cutsets for each of the sequences quantified by Westinghouse are needed. Each list should provide an adequate number of cutsets to be used for a meaningful comparison of results (e.g., top 50 cutsets or, if less than 50, top cutsets contributing to 99 percent of the sequence frequency). Please provide such lists.
- 720.325 An important insight, reported by Westinghouse in Chapter 59 (Results) of Revision 6 of the PRA, is that the contribution of the SGTR event to the at power core damage frequency (CDF) is very small (about 1.5 percent). If true, given the low total CDF estimate for the AP600 design, this is a significant improvement with respect to operating pressurized water reactors (PWRs). One of the reasons, reported by Westinghouse, for the small contribution of SGTR to CDF is that "the first line of defense is the startup feedwater system (SFWS) and chemical and volume control system (CVCS)." Please provide documentation showing that operation of CVCS only provides adequate flow for inventory control and that there is sufficient time to stabilize the plant before core uncover occurs. Such documentation should clearly state all major assumptions made in the analysis.
- 720.326 Please provide the following information concerning the SGTR event tree model.
- a. The description of event CVCS in Section 4.10.2 (page 4-29), entitled "Event Tree Model and Nodes," is not referring to the function (i.e., inventory control) CVCS is assumed to serve in the SGTR event tree. Please explain.
 - b. Event SGISO (failure to isolate the ruptured steam generator (SG)), as modeled by Westinghouse, does not include the possibility of an unisolable leak (e.g., stuck open SG power-operated relief valves (PORVs)/safety valves or atmospheric dump valves (ADV)). If an unisolable path exists from the ruptured SG to the atmosphere, the differential pressure between the primary and the secondary side will remain high since the ruptured SG could be at or near atmospheric pressure. This scenario would require decreasing the primary pressure down to the atmospheric pressure to terminate the leak prior to depletion of the available RCS inventory. Please explain why this scenario is not modeled in the SGTR event tree. If your answer is that unisolable leaks cannot occur, include appropriate documentation to support this assumption.

Enclosure

- c. Please list and describe the specific AP600 design features that reduce the probability of SGTR events resulting in containment bypass with respect to operating reactors. Such features should improve SGTR diagnosis, increase the time available for operator actions, lead to less reliance on operator actions and reduce the likelihood of challenging the secondary side safety valves. Please refer to applicable event tree models and related analyses.
- d. It is stated in page 6-13 (Chapter 6, Success Criteria Analysis, of the PRA) that "the passive response paths on the SGTR event tree pessimistically model active SG isolation, which would not be required, since turbine trip would provide an alternative to active SG isolation." However, this is not a "pessimistic" modeling of the "passive response paths." On the contrary, credit is taken for SG isolation in all "passive response paths," as indicated by the multiplication of the frequency of these paths by the probability of failure to isolate the ruptured SG (events CIB and CIB/SGHL). Please clarify.
- e. Following the SGTR event, an Emergency Safeguard Features (ESF) actuation signal is generated due to low pressurizer pressure. The ESF signal is supposed to trip the RCPs and actuate the CMTs. However, a statement made in page 4-27 implies that the event can be terminated by use of nonsafety systems and operator actions only. Please explain.
- f. It seems that there are discrepancies between the PRA modeling of the SGTR accident sequences and the AP600 Emergency Response Guidelines (see Guideline AE-3, Revision 1, July 28, 1995). For example, Table 2-1 of the ERGs shows CMT and PRHR actuation and need for operator action to isolate them when certain conditions are met. Please provide documentation explaining how applicable emergency procedures are incorporated into the PRA models of SGTR accident sequences.
- g. The following statement is made (see Chapter 4, page 4-28 of Revision 2 of the PRA): "Analyses show that no overfilling occurs and no automatic depressurization is actuated, even if multiple tubes have ruptured in the steam generator." Please provide documentation justifying the reason for not modeling in the PRA multiple SGTR events. This should include, in addition to the frequency of the initiating event, time windows available for required operator actions to isolate the faulted SG and stabilize the plant.
- h. Please provide documentation justifying the reason for not modeling in the PRA SGTR coincident with loss of offsite power.