



52-003

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

May 2, 1996

APPLICANT: Westinghouse Electric Corporation
FACILITY: AP600
SUBJECT: SUMMARY OF AP600 DESIGN REVIEW MEETING REGARDING THE PASSIVE CONTAINMENT COOLING SYSTEM (PCS) AND WGOTHIC COMPUTER CODE

On April 22 and 23, 1996, representatives of the U.S. Nuclear Regulatory Commission (NRC), Scientech, Inc. (NRC consultant), and Westinghouse Electric Corporation (Westinghouse) met in Rockville, Maryland, to discuss the WGOTHIC computer code and PCS design review status. Attachment 1 is a list of participants.

Mass and energy transfer, changes to Westinghouse's approach for analyzing containment mixing and stratification, and scaling were discussed. Westinghouse is going to use only a lumped-parameter model to analyze all phases of the design basis accidents, rather than use both a distributed-parameter and lumped-parameter model. The use of the SATAN-VI and LOFTRAN computer codes for mass and energy calculations was discussed. Documentation on the version of LOFTRAN used by Westinghouse needs to be updated. Westinghouse indicated that LOFTRAN-AP was used and that the documentation would be changed. For scaling, a new pressure-rate-of-change calculation was recently completed and shared with the staff. It was agreed upon that Westinghouse could send in portions of the scaling work as it was completed to expedite the review. This information, in final form, will be included in the Applications Report. Issues identified that would rely on the scaled test were mixing and stratification, mass transfer, PCS natural air circulation, film stability, and heat transfer. Attachment 2 is the presentation materials provided by Westinghouse. Westinghouse informed the staff that none of this information was proprietary.

Westinghouse requested staff response to their characterization of the status of the PCS and WGOTHIC computer code validation review as it would be presented by Westinghouse to the Advisory Committee on Reactor Safeguards (ACRS) on May 9 and 10, 1996. These draft slides contained proprietary information and were used for discussion purposes only. The slides were collected at the conclusion of the meeting. Changes to the slides were mutually agreed upon to reflect the proper characterization of the issues and the status of the review.

The following are issues that will be addressed in future meetings and submittals:

1. Westinghouse needs to demonstrate that the seven nodes chosen by Westinghouse in the WGOTHIC computer code adequately models the AP600 design. Westinghouse indicated that this information would be included in the Applications Report, which is scheduled to be submitted on June 28, 1996.

9605060239 960502
PDR ADOCK 05200003
A PDR

NRC FILE CENTER COPY 060015

DF03

May 2, 1996

- 2. Westinghouse needs to demonstrate the sensitivity of the mixing above and below the operating deck. Westinghouse indicated that this information would be included in the Applications Report, which is scheduled to be submitted on June 28, 1996.
- 3. Westinghouse needs to justify the use of forced convection for mass transfer in the dome area.

original signed by:

Diane T. Jackson, Project Manager
 Standardization Project Directorate
 Division of Reactor Program Management
 Office of Nuclear Reactor Regulation

Docket No. 52-003

Attachments: As stated

cc w/attachments:
See next page

DISTRIBUTION w/attachment:

Docket File
 PUBLIC
 WHuffman
 JSebrosky

PDST R/F
 TQuay
 TKenyon

BGrimes
 RArchitzel
 DJackson

DISTRIBUTION: w/o attachment:

WRussell/FMiraglia, 0-12 G18
 EJordan, T-4 D18
 ACRS (11)
 KCampe, 0-8 E2

RZimmerman, 0-12 G18
 JMoore, 0-15 B18
 JKudrick, 0-8 H7
 JDawson, 0-8 H7

ATHadani, 0-12 G18
 WDean, EDO
 EThrom, 0-8 H7

DOCUMENT NAME: A:PCS4 22.MIN

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM:PDST:DRPM	PM:SCSB:DSSA	<input checked="" type="checkbox"/> E	SC:PDST:DRPM			
NAME	DJackson	EThrom	<i>End</i>	RArchitzel			
DATE	4/30/96	4/30/96		5/2/96			

OFFICIAL RECORD COPY

Westinghouse Electric Corporation

Docket No. 52-003

cc: Mr. Nicholas J. Liparulo, Manager
Nuclear Safety and Regulatory Analysis
Nuclear and Advanced Technology Division
Westinghouse Electric Corporation
P.O. Box 355
Pittsburgh, PA 15230

Mr. B. A. McIntyre
Advanced Plant Safety & Licensing
Westinghouse Electric Corporation
Energy Systems Business Unit
Box 355
Pittsburgh, PA 15230

Mr. John C. Butler
Advanced Plant Safety & Licensing
Westinghouse Electric Corporation
Energy Systems Business Unit
Box 355
Pittsburgh, PA 15230

Mr. M. D. Beaumont
Nuclear and Advanced Technology Division
Westinghouse Electric Corporation
One Montrose Metro
11921 Rockville Pike
Suite 350
Rockville, MD 20852

Mr. Sterling Franks
U.S. Department of Energy
NE-50
19901 Germantown Road
Germantown, MD 20874

Mr. S. M. Modro
Nuclear Systems Analysis Technologies
Lockheed Idaho Technologies Company
Post Office Box 1625
Idaho Falls, ID 83415

Mr. Charles Thompson, Nuclear Engineer
AP600 Certification
NE-50
19901 Germantown Road
Germantown, MD 20874

Dr. Lothar T. Wolf
University of Maryland
Dept of Materials and Nuclear Engr
College Park, MD 20742

Mr. Frank A. Ross
U.S. Department of Energy, NE-42
Office of LWR Safety and Technology
19901 Germantown Road
Germantown, MD 20874

Mr. Ronald Simard, Director
Advanced Reactor Program
Nuclear Energy Institute
1776 Eye Street, N.W.
Suite 300
Washington, DC 20006-3706

Ms. Lynn Connor
Doc-Search Associates
Post Office Box 34
Cabin John, MD 20818

Mr. James E. Quinn, Projects Manager
LMR and SBWR Programs
GE Nuclear Energy
175 Curtner Avenue, M/C 165
San Jose, CA 95125

Mr. John E. Leatherman, Manager
SBWR Design Certification
GE Nuclear Energy, M/C 781
San Jose, CA 95125

Barton Z. Cowan, Esq.
Eckert Seamans Cherin & Mellott
600 Grant Street 42nd Floor
Pittsburgh, PA 15219

Mr. Ed Rodwell, Manager
PWR Design Certification
Electric Power Research Institute
3412 Hillview Avenue
Palo Alto, CA 94303

Mr. Ben Gitnick
Sciotech, Inc.
1140 Rockville Pike, Suite 500
Rockville, MD 20850

Dr. Kazys K. Almenas
University of Maryland
Dept. of Mat. and Nuclear Engr
College Park, MD 20742

WESTINGHOUSE/NRC MEETING
PASSIVE CONTAINMENT COOLING SYSTEM
APRIL 22 AND 23, 1996
MEETING PARTICIPANTS

<u>NAME</u>	<u>ORGANIZATION</u>
KAZIMIERAS CAMPE (4/23)	NRC/NRR/DSSA/SASG
JACK DAWSON (4/23)	NRC/NRR/DSSA/SCSB
DIANE JACKSON	NRC/NRR/DRPM/PDST
JACK KUDRICK (4/23)	NRC/NRR/DSSA/SCSB
EDWARD THROM	NRC/NRR/DSSA/SCSB
KAZYS ALMENAS (4/22)	NRC CONSULTANT
BEN GITNICK	SCIENTECH, INC. (NRC CONSULTANT)
DAN PRELEWICZ	SCIENTECH, INC. (NRC CONSULTANT)
LOTHAR WOLF	NRC CONSULTANT
JOHN BUTLER	WESTINGHOUSE
JIM GRESHAM	WESTINGHOUSE
DAN SPENCER	WESTINGHOUSE
JOEL WOODCOCK	WESTINGHOUSE

WESTINGHOUSE PRESENTATION MATERIALS
FOR THE APRIL 22 AND 23, 1996, MEETING BETWEEN
WESTINGHOUSE AND THE NRC ON
PASSIVE CONTAINMENT COOLING SYSTEM

PCS DBA transient evaluation simplifications

- Temporal partitioning
- Spatial partitioning
 - Heat sink distribution among compartments
 - Circulation potential

Simplified flow network based on dominant heat sink content

Dead-ended compartments

AP600 PCS DBF - LOCA Temporal Partitioning






Figure 3 AP600 DECLG Mass Release

- LB LOCA (4 loop Plant)
- 0-12 s. Blowdown (ends with accum injection)
 - 12-33 s. Refill (ends when bottom of core is reached)
 - 36 s. Primary P=Cont. P.
 - 33-150 s. Reflood (ends when core is quenched)




256



— SHELL INSIDE

ABOVE DECK VOLUME



AP600 Simplified Flow Diagram

Mixing and stratification

- Summary results

LOCA biases for peak pressure

- For SG break case, lumped parameter can simulate circulation effects
- For CMT break case, $\sim 1/2$ CMT room heat sinks eliminated to account for potential for stratification
- Dead-ended compartments eliminated for $t > 30$ seconds
- Floors are eliminated in compartments

LOCA biases at 24 hours

- Lumped parameter predicts well mixed containment by 24 hours which is conservative for PCS heat removal

MSLB biased to maximize transient pressure

- Break is assumed in the Lumped Parameter node just above the operating deck to reduce steam access below deck

CMT Room Layout

