



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

November 5, 1984

Docket Nos: 50-369, 50-370
and 50-413, 50-414

Mr. H. B. Tucker, Vice President
Nuclear Production Department
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242

Dear Mr. Tucker:

Subject: Request for Additional Information Regarding Topical Report
on Physics Methodology for Reloads: McGuire and Catawba
Nuclear Station

In response to your letter of July 18, 1984, the NRC staff, with the technical assistance of Brookhaven National Laboratory (BNL), is reviewing Duke Power Company topical report DPC-NF-2010 which describes the nuclear physics methodology for reload design at the McGuire and Catawba Nuclear Stations. We find that additional information identified in the enclosure is needed to complete this review.

A reply at your earliest opportunity and no later than November 30, 1984, is needed for the staff to meet your requested review completion date of January 1985. A copy of your reply should also be forwarded directly to BNL at the address below.

Should you have questions or need to meet with the staff regarding the enclosure, contact Darl S. Hood at (301) 492-8408.

Sincerely,

Elinor G. Adensam

Elinor G. Adensam, Chief
Licensing Branch No. 4
Division of Licensing

Enclosure:
As stated

cc: Dr. John Carew
Building 475 B
Brookhaven National Laboratory
Upton, Long Island, N.Y. 11973

See next page

DESIGNATED ORIGINAL

Certified By *[Signature]*

CATAWBA

Mr. H. B. Tucker, Vice President
Nuclear Production Department
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242

cc: William L. Porter, Esq.
Duke Power Company
P.O. Box 33189
Charlotte, North Carolina 28242

J. Michael McGarry, III, Esq.
Bishop, Liberman, Cook, Purcell
and Reynolds
1200 Seventeenth Street, N.W.
Washington, D. C. 20036

North Carolina MPA-1
P.O. Box 95162
Raleigh, North Carolina 27625

Mr. F. J. Twogood
Power Systems Division
Westinghouse Electric Corp.
P.O. Box 355
Pittsburgh, Pennsylvania 15230

NUS Corporation
2536 Countryside Boulevard
Clearwater, Florida 33515

Mr. Jesse L. Riley, President
Carolina Environmental Study Group
854 Henley Place
Charlotte, North Carolina 28208

Richard P. Wilson, Esq.
Assistant Attorney General
S.C. Attorney General's Office
P.O. Box 11549
Columbia, South Carolina 29211

North Carolina Electric Membership
Corp.
3333 North Boulevard
P.O. Box 27306
Raleigh, North Carolina 27611

Saluda River Electric Cooperative,
Inc.
P.O. Box 929
Laurens, South Carolina 29360

Senior Resident Inspector
Route 2, Box 179N
York, South Carolina 29745

James P. O'Reilly, Regional Administrator
U.S. Nuclear Regulatory Commission,
Region II
101 Marietta Street, N.W., Suite 2900
Atlanta, Georgia 30323

Robert Guild, Esq.
P.O. Box 12097
Charleston, South Carolina 29412

Palmetto Alliance
2135 1/2 Devine Street
Columbia, South Carolina 29205

Karen E. Long
Assistant Attorney General
N.C. Department of Justice
P.O. Box 529
Raleigh, North Carolina 27602

cc: Spence Perry, Esquire
Associate General Counsel
Federal Emergency Management Agency
Room 840
500 C Street, S.W.
Washington, D. C. 20472

Mark S. Calvert, Esq.
Bishop, Liberman, Cook,
Purcell & Reynolds
1200 17th Street, N.W.
Washington, D. C. 20036

Mr. Michael Hirsch
Federal Emergency Management Agency
Office of the General Counsel
Room 840
500 C Street, S.W.
Washington, DC 20472

Brian P. Cassidy, Regional Counsel
Federal Emergency Management Agency,
Region I
J. W. McCormach POCH
Boston, Massachusetts 02109

McGuire

Mr. H. B. Tucker, Vice President
Nuclear Production Department
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242

cc: Mr. A. Carr
Duke Power Company
P. O. Box 33189
422 South Church Street
Charlotte, North Carolina 28242

Mr. F. J. Twogood
Power Systems Division
Westinghouse Electric Corp.
P. O. Box 355
Pittsburgh, Pennsylvania 15230

Mr. Robert Gill
Duke Power Company
Nuclear Production Department
P. O. Box 33189
Charlotte, North Carolina 28242

J. Michael McGarry, III, Esq.
Bishop, Liberman, Cook, Purcell
and Reynolds
1200 Seventeenth Street, N.W.
Washington, D. C. 20036

Mr. Wm. Orders
Senior Resident Inspector
c/o U.S. Nuclear Regulatory Commission
Route 4, Box 529
Hunterville, North Carolina 28078

James P. O'Reilly, Regional Administrator
U.S. Nuclear Regulatory Commission,
Region II
101 Marietta Street, N.W., Suite 2900
Atlanta, Georgia 30323

R. S. Howard
Operating Plants Projects
Regional Manager
Westinghouse Electric Corporation - R&D 701
P. O. Box 2728
Pittsburgh, Pennsylvania 15230

REQUEST FOR ADDITIONAL INFORMATION ON DUKE POWER COMPANY
TOPICAL REPORT DPC-NF-2010

1. Please provide additional information regarding the NUC-MARGINS code and its use in the Dropped Rod Analysis. Provide short descriptions of the input, output, calculational models used, benchmark calculations performed and the conservatisms assumed in the analysis.
2. Identify the nominal and various off-nominal cross-section sets that are generated in order to evaluate the different reactivity coefficients and defects.
3. Provide a short description of the PDQEDIT code and describe the verification program that was undertaken to test data generated with PDQEDIT for use in SNA-CORE.
4. Comment on the reasons for the 3.1% non-conservative bias in the calculated peak axial powers (Section 11.5.4). Describe the model refinements, if any, that have been undertaken to reduce this bias.
5. Duke Power Company's contention that no uncertainty in calculated pin powers needs to be accounted for has not been adequately established. One possible way to establish the uncertainty is to perform a standard problem. A standard problem recently developed at Brookhaven National Laboratory for a licensee to assess its ability to calculate typical PWR fuel assemblies, is attached. A solution of this problem or other justification for the assumed uncertainty should be provided.
6. Please provide the updates to DPC-NF-2010, if any, that will make it consistent with the methodologies currently being used by Duke Power.

FUEL ASSEMBLY STANDARD PROBLEM

The standard problem is to be calculated in two dimensions in an iterated-source mode using reflecting boundary conditions in the horizontal plane neglecting axial leakage. The following series of assembly depletion and reactivity defect calculations are to be calculated.

I. DEPLETION CALCULATIONS

Provide the following edited quantities for an assembly with and without burnable poison rods at BOL, 500, 5000, 10000, 20000, 30000 and 40000 Mwd/MT*:

1. Relative pin powers
2. Assembly volume averaged fuel pellet isotopics; U^{235} , U^{238} , Pu^{239} , Pu^{240} , Pu^{241} , Pu^{242} and calculated fission product densities [atom/barn-cm]
3. Assembly total reaction rates (A-absorption, F-fission)

a. Fuel

U^{235} (A)	Pu^{240} (A)
U^{235} (F)	Pu^{240} (F)
U^{238} (A)	Pu^{241} (A)
U^{238} (F)	Pu^{241} (F)
Pu^{239} (A)	Pu^{242} (A)
Pu^{239} (F)	Pu^{242} (F)

- b. Clad (A)
- c. Burnable Poison (A)
- d. Water (A)
- e. Control Rod (A)

4. Assembly Characteristics

- a. k_{∞} - Infinite Multiplication Factor
- b. M^2 - Migration Area [cm^2]
- c. B_M^2 - Material Buckling [cm^{-2}]
- d. β - Delayed Neutron Fraction
- e. Two-Group Inverse Neutron Velocity[†] [cm/sec]

5. Two-Group Collapsed Assembly Averaged Cross Sections[†]

$$D [cm], \Sigma_a [cm^{-1}], \Sigma_r [cm^{-1}],$$

$$\nu \Sigma_f [cm^{-1}], \kappa \Sigma_f [watt/cm], \Sigma_f [cm^{-1}]$$

* These are editing points and do not necessarily correspond to the depletion steps.

† Thermal breakpoint assumed at 0.625 [eV]

FUEL ASSEMBLY STANDARD PROBLEM

II. REACTIVITY DEFECT CALCULATIONS

Provide the following reactivity defects ($\% \Delta k/k$) for an assembly with and without burnable poison rods at BOL and EOL (30,000 Mwd/MT):

REACTIVITY DEFECT ($\% \Delta k/k$)*	UNPERTURBED CASE†	PERTURBED CASE
1. Fuel Temperature (T_{fuel})	T_{fuel}^{base}	$T_{moderator}^{base}$
2. Moderator Temperature ($T_{moderator}$)	$T_{moderator}^{base}$	$T_{moderator}^{base} - 25^{\circ}K$
3. Moderator & Fuel Temperature†† ($T_{Moderator}$ & T_{Fuel})	$T_{moderator}^{base}$	68°F
	T_{fuel}^{base}	68°F
4. Moderator & Fuel Temperature†† ($T_{Moderator}$ & T_{Fuel})	$T_{moderator}^{base}$	300°F
	T_{fuel}^{base}	300°F
5. Boron Concentration (N_{boron})	N_{boron}^{base}	0 ppm
6. Xenon Concentration (N_{xenon})	Equilibrium	0
7. Control Rod #	Unrodded	Rodded

* It is recommended that a full flux solution be carried out for each state-point.

† Unperturbed parameters are at their base values indicated in the Standard Problem definition.

In the case of the W (17x17) assembly only the unpoisoned assembly is required.

†† Pressure is to be maintained at base value.

DATA FOR FUEL ASSEMBLY STANDARD PROBLEM

17 x 17 W Type Fuel Assembly

1. General Characteristics

Power density (W/Gm-U)	38.4
Average fuel temperature (°K)	968
Average clad-temperature (°K)	600
Moderator temperature (°K)	560
Soluble boron concentration (ppm)	400
Average core pressure (psia)	2250
Xenon concentration	Equilibrium
Samarium concentration	Equilibrium

2. Configuration (1/8 assembly)

4	
1 1	
1 1 1	
2 1 1 3	1 - Fuel Rod
1 1 1 1 1	2 - Burnable Poison Rod (BPR)
1 1 1 1 1 2	3 - Guide Thimble
3 1 1 2 1 1 1	4 - Instrument Thimble
1 1 1 1 1 1 1 1	
1 1 1 1 1 1 1 1 1	

- Note: 1. For an unrodded or unpoisoned case replace all BPRs (2) with guide thimbles (3).
2. For a rodded case replace all BPRs (2) with control rods inserted in guide thimbles (3).

3. Fuel Assembly Data

Rod array	17 x 17
Fuel rods per assembly	264
Rod pitch (in)#	0.496
Assembly pitch (in)**	8.466 x 8.466
Assembly length (in)	151.0
Active fuel length (in)	144.0
Number of spacer grids†	8
Composition of spacer grid	Incone 718
Weight of spacer grids (lb)	12
Number of guide thimbles	24
Number of instrument thimbles	1

All dimensions are given at cold (68°F) conditions.

† Seven in active length.

** Center to center assembly pitch.

4. Fuel Rod Data

Clad O.D. (in)	0.374
Clad thickness (in)	0.0225
Diametral gap (in)	0.0065
Clad material	Zircaloy-4

5. Fuel Pellet Data

Material	UO ₂ - Undished
Density (% of theoretical)	95
Enrichment (w/o)	2.6
Diameter (in)	0.3225

6. Burnable Poison Rod Data (See Figure 1)



Number per assembly	16
Material	Borosilicate Glass
Density (Borosilicate glass) (gm/cm ³)	2.28
Outside clad O.D. (in)	0.381
Outside Clad I.D. (in)	0.348
Absorber O.D. (in)	0.344
Absorber I.D. (in)	0.185
Inner-tube O.D. (in)	0.1805
Inner-tube I.D. (in)	0.170
Clad material	Stainless Steel
Inner-tube material	Stainless Steel
Boron loading (w/o B ₂ O ₃ in glass rod)	12.5
Weight of Boron-10 (lb/ft)	0.000419

7. Guide Thimbles and Instrument Thimble Data

Number of guide thimbles	24
Number of instrument thimbles	1
Composition of thimbles	Zircaloy-4
Guide Thimble O.D. (in)	0.482
Guide Thimble I.D. (in)	0.450
Instrument Thimble O.D. (in)	0.482
Instrument Thimble I.D. (in)	0.450

8. Control Rod Data

Neutron absorber (w/o)	5% Cd, 15% In, 80% Ag
Absorber diameter (in)	0.341
Absorber density (lb/in ³)	0.367
Cladding material	304 Stainless Steel
Clad O.D. (in)	0.381
Clad thickness (in)	0.0185
Number of control rods	24



SECTION A-A
ENLARGED DETAIL

Figure 1. Burnable Poison Rod Configuration

DESCRIPTION OF CALCULATIONS AND METHODS

1. Name of code/code source/version
2. Reference for calculational method
3. Assembly solution method (Diffusion Theory, Collision Probability, Integral Transport, Monte Carlo, etc.)
4. Pin-cell solution method (if distinct from assembly solution method)
5. Spatial mesh assembly/pin-cell (nxm)
6. Neutron cross sections (ENDF/B or other identification)
7. Number of fast/thermal groups in assembly/pin-cell solution
8. Depletion steps