

Docket No. 50-336  
B15697

Attachment 1

Millstone Nuclear Power Station, Unit No. 2  
Proposed Revision to Technical Specifications  
Electrical Power Systems - Shutdown

Marked-up Pages

May 1996

9605070058 960503  
PDR ADOCK 05000336  
P PDR

August 1, 1975

ELECTRICAL POWER SYSTEMS

SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.B.1.2 As a minimum, the following A.C. electrical power sources shall be OPERABLE:

- a. One circuit between the offsite transmission network and the switchyard, and
- b. One diesel generator with a fuel oil supply tank containing a minimum of 12,000 gallons of fuel.

APPLICABILITY: MODES 5 and 6.

ACTION:

With less than the above minimum required A.C. electrical power sources OPERABLE, suspend all operations involving CORE ALTERATIONS or positive reactivity changes, ~~until the minimum required A.C. electrical power sources are restored to OPERABLE status.~~

or movement of irradiated fuel assemblies.

SURVEILLANCE REQUIREMENTS

4.B.1.2 The above required A.C. electrical power sources shall be demonstrated OPERABLE per Surveillance Requirements 4.B.1.1.1 and 4.B.1.1.2.

EXCEPT FOR TESTING PURSUANT TO SURVEILLANCE REQUIREMENTS 4.B.1.1.2.c.2, 4.C.5 and 4.C.6.

4.B.1.2.a.3

and

Docket No. 50-336  
B15697

Attachment 2

Millstone Nuclear Power Station, Unit No. 2  
Proposed Revision to Technical Specifications  
Electrical Power Systems - Shutdown

Retyped Pages

May 1996

## ELECTRICAL POWER SYSTEMS

### SHUTDOWN

#### LIMITING CONDITION FOR OPERATION

---

3.8.1.2 As a minimum, the following A.C. electrical power sources shall be OPERABLE:

- a. One circuit between the offsite transmission network and the switchyard, and
- b. One diesel generator with a fuel oil supply tank containing a minimum of 12,000 gallons of fuel.

APPLICABILITY: MODES 5 and 6.

#### ACTION:

With less than the above minimum required A.C. electrical power sources OPERABLE, suspend all operations involving CORE ALTERATIONS or positive reactivity changes or movement of irradiated fuel assemblies. |

#### SURVEILLANCE REQUIREMENTS

---

4.8.1.2 The above required A.C. electrical power sources shall be demonstrated OPERABLE per Surveillance Requirements 4.8.1.1.1 and 4.8.1.1.2, except for testing pursuant to Surveillance Requirements 4.8.1.1.2.a.3, 4.8.1.1.2.c.2, and 4.8.1.1.2.c.5. |