LICENSEE EVENT REPORT (LER)										U.S. NUCLEAR REGULATORY COMMISSION APPROVED OMB NO. 3150-0104 EXPIRES: 8/31/85											
PACILITY NAME (1)												(2)	-	PAGE (3)							
Monticello											0 5 0 0	10121613	1 0	FOR							
TITLE (4)		Mode	of EF	T Actuate	ed By Hy	drog	en Ch	lorid	e												
EVE	ENT DATE	(6)		LER NUMBER	(6)		PORT DAT			OTHE	A FACILITIES INVO	LVED (8)	7								
MONTH	DAY	YEAR	YEAR	SEQUENTIAL	REVISION NUMBER	MONTH	DAY	YEAR		FACILITY N	AMES	DOCKET NUMB									
												0 5 0	010111								
olı	2 9	8 5	8 5	-01013	1-010	0 2	2 8	8 5				0 5 0	0101	11							
	RATING DOE (9)		THIS REP	DAT IS SUBMITTE	D PURSUANT	TO THE A	EQUIREM	ENTS OF 10	CFR &: 10	Check one or more	of the followings (1	1)									
POWER LEVEL (10) 0 19 19			20.4 20.4 20.4 20.4	02(b) 05(a)(1)(i) 06(a)(1)(ii) 06(a)(1)(iii) 06(a)(1)(iv)	50.36(c 50.36(c 50.73(c 50.73(c	20.406(a) X 80.73(a)(b) 80.36(a)(1) 80.73(a)(c) 80.73(a)(c)(1) 80.73(a)(c) 80.73(a)(c)(1) 90.73(a)(c) 80.73(a)(c)(1) 90.73(a)(c) 80.73(a)(c)(1) 90.73(a)(c)					73,71(b) 73,71(c) OTHER Specify in Abstract below at d in Text, NRC Form 368A)										
NAME						ICENSEE	CONTACT	FOR THIS	LER (12)												
	Micha	ael F	. Ham	mer, I &	THE RESERVE AND ADDRESS OF THE PERSON NAMED IN	-						219 15 1-		15 11							
						EACH CO	MPONEN	TFAILURE	DESCRIBE	D IN THIS REPO	PRT (13)		D								
CAUSE	SYSTEM	COMPO	ONENT	MANUFAC- TURER	TO NPROS			CAUSE	SYSTEM	COMPONENT	MANUFAC- TURER	TO NPROS									
			ш	111						111	1111										
				TIL						111	1111			l.							
_				SUPPLEME	and the second second second second	X	NO NO				EXPECTI SUBMISSI CATE (1	ON	H DAY	EAR							

The EFT System (Control Room HVAC) transferred to the emergency mode as the result of a spurious trip of a hydrogen chloride monitor.

Investigation revealed no apparent cause for the trip; subsequent operation of the monitor has been satisfactory.

8503080098 850228 PDR ADOCK 05000268 PDR

> JEZZ Y

NRC Form 366A (9-63)	LICENSEE EVENT REPORT (LER) TEXT CONTINUATION											U.S. NUCLEAR REGULATORY COMMISSION APPROVED OMB NO. 3150-0104 EXPIRES: 8/31/85											
FACILITY NAME (1)		00	CKE	T NU	MBER	9 (2)				Г		LE	RNU	MBER	(6)					PA	GE (3)	
										Y	EAR			UENT			REVIS						
Monticello		0	5	10	10	10	12	16	13	8	15	_	0	101	3	_	01	0	0	2	OF	0	12

DCT (If more space is required, use additional NRC Form 366A's) (17)

During power operation on January 29, 1985, at approximately 1915, the EFT system (Control Room HVAC) (System Code VI) automatically transferred to the toxic chemical emergency mode (isolation of outside air intake and exhaust) as the result of a spurious trip of hydrogen chloride monitor AT-9036 (MDA Scientific Model 7025 FAN) (Component Code AA). The monitor was reset and the system returned to normal operation.

Investigation revealed no apparent cause for the spurious trip; subsequent operation of the monitor has been satisfactory. We have submitted a License Amendment Request to the NRC to permit removal of this monitor.

There was no effect on public health or safety because the safety function of the EFT system was initiated.

There have been two previous similar occurrences, LER's 84-002 and 84-031.





Northern States Power Company

414 Nicollet Mail Minneapolis, Minnesota 55401 Telephone (612) 330-5500

February 28, 1985

U S Nuclear Regulatory Commission Document Control Desk Washington, DC 20555

> MONTICELLO NUCLEAR GENERATING PLANT Docket No. 50-263 License No. DPR-22

E-Mode of EFT Actuated by Hydrogen Chloride

The License Event Report for this occurrence is attached.

This event was reported via Emergency Notification System per 10 CFR Part 72 on January 29, 1985.

Thomas Vik

David Musolf

Manager - Nuclear Support Services

DMM/MMV/jlk

c: Regional Administrator-III, NRC NRR Project Manager, NRC Resident Inspector, NRC MPCA

Attn: J W Ferman

Attachment

IE22

1/1