
Southern Nuclear Operating Company Post Office Box 1295 Birmingham, Alabama 35201 Telephone (205) 868-5131

Dave Morey Vice President Farley Project



May 3, 1996

Docket No.: 50-364

U. S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, D. C. 20555-0001

Joseph M. Farley Nuclear Plant - Unit 2
Steam Generator F* Technical Specification Amendment

Ladies and Gentlemen

By letter dated April 22, 1996, Southern Nuclear Operating Company requested an amendment to the Farley Unit 2 Technical Specifications concerning F*. The amendment revised the definition of the F* distance to 1.54 inches plus an allowance for eddy current uncertainty. In discussions with the NRC Staff, Southern Nuclear has been requested to revise the submittal to include a location where the eddy current uncertainty will be documented. Consequently, the amendment is being revised to state that the allowance for eddy current uncertainty will be documented in the steam generator eddy current inspection procedure.

A revised technical specification page is attached. As noted in the April 22, 1996 submittal, this revised technical specification page is based on approval of the alternate repair criteria for outside diameter stress corrosion cracking at tube support plate intersections.

The existing 10 CFR 50.92 Significant Hazards Evaluation is not affected by this change and remains valid.

070047

9505070199 960503 PDR ADOCK 05000364 PDR

50-364 P tody

If you have any questions, please advise.

Respectfully submitted,

SOUTHERN NUCLEAR OPERATING COMPANY

Dave Morey

Sworn to and subscribed before me this 3th day of May

Carol Louise Jaylor

Notary Public

My Commission Expires June 24, 1997

REM/clt: fstrrey doc

REM/clt:fstrrev.doc

Attachments

CC: Mr. S. D. Ebneter, Region II Administrator

Mr. B. L. Siegel, NRR Senior Project Manager

Mr. T. M. Ross, FNP Sr. Resident Inspector

Dr. D. E. Willliamson, State Department of Public Health

Mr. T. A. Reed, NRR Materials and Chemicals Engineering Branch