



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

NOV 21 1984

Docket No. 50-354

MEMORANDUM FOR: A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing

FROM: David H. Wagner, Project Manager  
Licensing Branch No. 2  
Division of Licensing

SUBJECT: FORTHCOMING MEETING WITH PUBLIC SERVICE  
ELECTRIC & GAS COMPANY (PSE&G) - HOPE CREEK

DATE & TIME: ~~Wednesday, December 5, 1984~~ **TUESDAY, DECEMBER 18, 1984**  
1:00 p.m.

LOCATION: ~~Phillips Building~~ **MARYLAND NATIONAL BANK BUILDING**  
~~Room 114~~ **ROOM 6110**  
~~7920 Norfolk Ave.~~ **7735 OLD GEDDGETOWN ROAD**  
Bethesda, Maryland

PURPOSE: Discussion of Riverborne Missiles (The comments contained in  
the Enclosure to this meeting notice will be discussed.)

PARTICIPANTS\*: NRC PSE&G  
J. Ridgely B. Preston  
O. Parr et. al.  
E. Simiu (EG&G)  
D. Wagner

David H. Wagner, Project Manager  
Licensing Branch No. 2  
Division of Licensing

cc: See next page

\*Meetings between NRC technical staff and applicants for licenses are open for interested members of the public, petitioners, intervenors, or other parties to attend as observers pursuant to "Open Meeting Statement of NRC Staff Policy", 43 Federal Register 28058, 6/28/78.

8412110018 841121  
PDR ADOCK 05000354  
A PDR

Hope Creek

Mr. R. L. Mittl, General Manager  
Nuclear Assurance & Regulation  
Public Service Electric & Gas Company  
80 Park Plaza T22A  
Newark, New Jersey 07101

cc:

Troy B. Conner, Jr. Esquire  
Conner & Wetterhahn  
1747 Pennsylvania Avenue N.W.  
Washington, D.C. 20006

Richard Fryling, Jr., Esquire  
Associate General Solicitor  
Public Service Electric & Gas Co.  
80 Park Plaza T5E  
Newark, New Jersey 07101

Mr. P.R.H. Landrieu  
Project Manager - Hope Creek  
Public Service Electric & Gas Co.  
80 Park Plaza T17A  
Newark, New Jersey 07101

Richard F. Engel  
Deputy Attorney General  
Division of Law  
Environmental Protection Section  
Richard J. Hughes Justice Complex CN-112  
Trenton, New Jersey 08625

Mr. David A. Caccia  
Box 70, A.R.D. #2  
Sewell, New Jersey 08080

Mr. R. P. Douglas  
Manager-Licensing & Analysis  
Public Service Electric & Gas Co.  
80 Park Plaza T22A  
Newark, New Jersey 07101

Mr. B. G. Markowitz, Project Manager  
Bechtel Power Corporation  
50 Beale Street  
P. O. Box 3965  
San Francisco, California 94119

Susan C. Remis  
Division of Public Interest Advocacy  
New Jersey State Department of  
the Public Advocate  
Richard J. Hughes Justice Complex  
CN-850  
Trenton, New Jersey 08625

Gregory Minor  
Richard Hubbard  
Dale Ridenbaur  
MHB Technical Associates  
1723 Hamilton Avenue, Suite K  
San Jose, California 95125

Office of Legal Counsel  
Department of Natural Resources  
and Environmental Control  
89 Kings Highway  
P.O. Box 1401  
Dover, Delaware 19903

Mr. K. W. Burrowes, Project Engineer  
Bechtel Power Corporation  
50 Beale Street  
P. O. Box 3965  
San Francisco, California 94119

Mr. W. H. Bateman  
Resident Inspector  
U.S.N.R.C.  
P. O. Box 241  
Hancocks Bridge, New Jersey 08038

Mr. J. M. Ashley  
Senior Licensing Engineer  
c/o PSE&G Company  
Bethesda Office Center, Suite 550  
4520 East-West Highway  
Bethesda, Maryland 20814

Mr. Robert J. Touhey, Acting Director  
DNREC - Division of Environmental Control  
89 Kings Highway  
P. O. Box 1401  
Dover, Delaware 19903

Mr. R. S. Salvesen  
General Manager-Hope Creek Operation  
Public Service Electric & Gas Co.  
P.O. Box A  
Hancocks Bridge, New Jersey 08038

Mr. B. A. Preston  
Principal Engineer  
Public Service Electric & Gas Co.  
80 Park Plaza T22A  
Newark, New Jersey 07101

Mr. A.E. Giardino  
Manager - Quality Assurance E&C  
Public Service Electric & Gas Co.  
P.O. Box A  
Hancocks Bridge, New Jersey 08038

Questions and Comments Pertaining to:  
Arthur D. Little, Inc. (ADL) Report C-50918 (September 1984); and  
Meteorological Evaluation Services, Inc. (MES) Reports on  
Hope Creek Generating Station Extreme Event Site Flooding Meteorology  
(July 1984 and August 1984)

1. On p. 5 of the ADL Report it is stated that grade level is approximately 14 ft above Mean Low Water Level. In Table 2, footnote 4, p. 7, it is stated that an increased water depth of 12 ft over Mean Low Water results in a water level which is about 3 ft below plant grade (rather than 2 ft, as would result from the statement on p. 5 of the ADL Report). Is there a reason for the difference between the statements in p. 5 and in Table 2?
2. It appears implicit in the estimate of the kinetic energy per unit area for a large recreational boat hitting a structure (p. 16) that the impact area is 100 ft<sup>2</sup>. Explain why the impact areas could not be significantly smaller than 100 ft<sup>2</sup>.
3. Explain why the chances of an unmanned vessel approaching within 10 miles of Hope Creek without a prior grounding are estimated on p. 44, Appendix C of the ADL Report, to be less than ten percent.
4. It is assumed in the ADL Report (p.45) that the probability per mile of simultaneous loss of power and steering is  $\lambda=10^{-5}$ /mile. This estimate is based on historical data contained in References 1 and 7. Do these historical data pertain to severe storm conditions? If not, are the estimates independent of whether storm conditions are present?
5. Explain why, once power and steering are lost, the vessel is more likely to head towards the target (rather than equally likely to move in any direction), by a factor of about 10 for the water intake structure and by a factor of about 100 for entering the Hope Creek site (see p. 47 of the ADL Report).
6. The probabilities of strike by a non-self-propelled vessel already within ten miles of Hope Creek striking the water intake structure are stated on p. 48 of the ADL Report to be  $1.2 \times 10^{-5}$ /vessel for the intake structure and  $3.1 \times 10^{-3}$ /vessel for the Hope Creek site. Were the same multiplication factors of 10 and 100 used in these estimates as in the estimates discussed in item 5 above?
7. In any given storm, wind speeds over water are higher than wind speeds over ground. It appears that this was not taken into account in the estimation of annual probabilities of extreme six-hour wind speeds at 33 ft elevation. Is this the case? If so, why?

8. In the July 1984 MES Report it is stated that the probability of occurrence in any one year of a "probable maximum hurricane,"  $H_{max}$ , having a direction of motion, D, capable of causing a very large tidal surge can be obtained as follows:

$$P(H_{max}, D) = P(H_{max}) P(D) \quad (1)$$

where  $P(H_{max})$  = probability of occurrence in any one year of a probable maximum hurricane regardless of trajectory, and  $P(D)$  = probability of occurrence in any one year of a storm having the direction of motion D. It is estimated in the above-mentioned Report that  $P(H_{max}) \approx 10^{-3}/\text{yr}$ . It is further estimated in the Report that  $P(D) \approx 10^{-2}/\text{yr}$ , the justification for that estimate being that only about one storm in 100 years was sufficiently strong and had the direction of motion needed to cause a significant tidal surge.

Actually,  $P(D)$  should represent the ratio of the number of storms having a direction of motion D to the total number of storms, regardless of their direction. For the area and time frame considered, it would follow from the Report that this ratio is about 5/39 (p.9). If the ratio 5/39 were used in Eq. 1 above, rather than the ratio 1/100, the estimated probability  $P(H_{max}, D)$  would increase by an order of magnitude, i.e., it would be about  $10^{-4}/\text{yr}$ , rather than  $10^{-5}/\text{yr}$  as estimated in the MES Report.

To summarize, it appears that the MES Report uses, in lieu of  $P(D)$ , a joint probability  $P(V,D)$ , where V is a relatively large wind speed such that  $P(V,D) \approx 10^{-2}/\text{yr}$ . An explanation is requested concerning this matter.

9. It is stated in the August 1984 MES Report (p. 4) that the NBS BSS-124 document "is based on actual hurricane climatology and statistics only insofar as the frequency of occurrence of hurricanes in various locations is concerned." Actually, NBS BSS-124 also uses statistics based on climatological data concerning the pressure difference between center and periphery of storms, radius of maximum wind speeds, speed of translation of storm, and direction of storm translation (see pp. 3 and 4 of NBS BSS 124).
10. In Table 1 of the August 1984 MES Report, were any of the storms of the thunderstorm type? This question is asked because, if indeed some of those storms were of that type, then the ratios FM/1H and FM/6H would be too high to be possibly representative of hurricane winds.
11. Page 7 of the August 1984 MES Report reproduces estimates of directional fastest-mile wind speeds from the NBS BSS-124 Report. However, the estimates of NBS BSS-124 pertain to winds blowing from a  $360^\circ/16 = 22.5^\circ$  sector, rather than from the  $79^\circ-170^\circ$  sector. Using data on which the NBS BSS-124 report is based (which are available on tape at NBS), the fastest-mile wind speeds at 10m over ground are estimated as

36 mph, 73 mph, and 85 mph for the 10-yr, 50-yr, and 100-yr mean recurrence intervals, respectively, rather than 25 mph, 57 mph, and 70 mph, as indicated on p. 7 of the August 1984 MES Report.

Date: 11/20/84

MEETING NOTICE DISTRIBUTION:

Document Control (50-354 )

NRC PDR

L. PDP

PRC

NSIC

LB#2 Reading

H. R. Denton/E. G. Case

D. G. Eisenhut/FMiraglia

T. M. Novak

B. J. Youngblood

A. Schwencer

G. W. Knighton

E. Adensam

Acting Chief, ORB#5

C. Grimes, SEPB

G. Holohan

C. Thomas

G. C. Lainas

S. Varga

D. Vassallo

J. R. Miller

J. Stolz

R. H. Vollmer

J. P. Knight

R. Bernero

L. Rubenstein

W. Houston

D. Muller

T. Speis

F. Schroeder

F. Rowsome

H. Thompson

T. W. Russell

ACRS (16)

OELD Attorney L. Dewey

E. L. Jordan, IE

N. Grace

F. Ingram, PA

Receptionist (if meeting held in Bethesda)

Project Manager D. Wagner

E. Hylton

Region 1

R. Jachowski, EHEB

I. Spickler, METB

J. Fairbent, METB

N. Choski, SGEB

C. Ferrell, SAB

NRC Participants

J. Ridgely

O. Parr

E. Simiu (EG&G)

D. Wagner

cc: Service List